Anniversary Date:

Published Date:

01-Apr-20

18-Mar-21



Licensee: Eurobodalla Shire Council EPL No.: 2851

Premises: Tomakin Sewage Treatment Plant

Address: George Bass Drive, Tomakin, NSW 2537

Licence Period: 01-Apr-20 31-Mar-21 EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183819&SYSUID=1&LICID=2851

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Licence Point / Type of Point:	Licence Point 1 - Discharge to Waters			
Parameters	Unit of Measure	50 percentile concentration limit	100 percentile concentration limit	_
Biological Oxygen Demand	(mg/L)	10	20	
Oil and Grease	(mg/L)	-	10	See Note
Total Nitrogen	(mg/L)	-	-	
Total Phosphorus	(mg/L)	-	-	
Total Suspended Solids	(mg/L)	15	30	_

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1 and Point 2.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Point 1 as described in Condition 13.

Licence Point / Type of Point:	Licence Point 3 - Effluent Quality Monitor	ing					
Sample Frequency	Monthly	Special Frequency 1	Monthly	Monthly	Monthly	Monthly	
 Sampling Method	Composite	Grab	Grab	Composite	Composite	Composite	
 Parameters	Biological Oxygen Demand	Chlorophyll a	Oil and Grease	Total Nitrogen	Total Phosphorus	Total Suspended Solids	
Unit of Measure	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	
 Sample Date							Obtained Date
23-Feb-21	<2	0.0007	<5	1.22	7.96	3	08-Mar-21
Minimuim Value	<2	0.0007	<5	1.22	7.96	3	
 Maximum Value	<2	0.0007	<5	1.22	7.96	3	

Licence Condition - 100 Percentile										
	Biological Oxygen Demand				Oil and Grease			Total Suspended Solids		
Sample Date	Measurement	Actual 100 Percentile to Sample Date	Exceedance	Measurement	Actual 100 Percentile to Sample Date	Exceedance	Measurement	Actual 100 Percentile to Sample Date	Exceedance	
23-Feb-21	<2	5	NO	<5	5	NO	3	3	NO	

Note 1: Special Frequency 1 means collect and store sample monthly, at the same time as Biochemical Oxygen Demand or Total Suspended Solids 100 percentile concentration limit is exceeded as per condition 13.3, then analyse the stored sample for chlorophyll a and

Note 2: For the purpose of this licence, a composite sample is defined as at least three grab samples forming a pooled sample, with the first and last samples taken at least seven hours apart.

Licence Point / Type of Point:	Licence Point 4 - Ambient Water Monitoring	
Sample Frequency	Special Frequency 2	
Sampling Method	Grab	
Parameters	Faecal Coliforms	
Unit of Measure	(cfu/100mL)	
Sample Date		Obtained Date
02-Feb-21	6	05-Feb-21
09-Feb-21	1	23-Feb-21
16-Feb-21	<1	19-Feb-21
23-Feb-21	110	08-Mar-21

Special Frequency 1 means collect and store sample monthly, at the same time as Biochemical Oxygen Demand or Total Suspended Solids sampling. If the Biochemical Oxygen Demand or Total Suspended Solids 100 percentile concentration limit is exceeded as per condition 13.3, then analyse the stored sample for chlorophyll a and report results to the EPA as soon as the results become available.

Special Frequency 2 means at least weekly during the months of November, December, January, February and March.

Note: For the purpose of this licence, a composite sample is defined as at least three grab samples forming a pooled sample, with the first and last sample taken at least seven hours apart.

Licensee: Eurobodalla Shire Council EPL No.:

Premises: Tomakin Sewage Treatment Plant Address: George Bass Drive, Tomakin, NSW 2537

31-Mar-21 Licence Period: 01-Apr-20

EPL Link: https://apps.epa.nsw.gov.au/proeoapp/ViewPOEOLicence.aspx?DOCID=183819&SYSUID=1&LICID=2851
POEO Public Register: https://apps.epa.nsw.gov.au/proeoapp/

Licence Point / Type of Point:	Licence Point 2 - Influent Volume Monito		
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	14000
Sampling Method	Ultrasonic Flow Meter		
Parameters	Rainfall	Flow	Exceedance
Unit of Measure	(mm)	(kL)	(YES/NO)
Sample Date			
1-Feb-21	6.5	1759.7	NO
2-Feb-21	37.5	2061.9	NO
3-Feb-21	0.5	2890.2	NO
4-Feb-21	0	1423.5	NO
5-Feb-21	0	1352.2	NO
6-Feb-21	0.5	1442.0	NO
7-Feb-21	1	1601.2	NO
8-Feb-21	0.5	1446.3	NO
9-Feb-21	1	1458.0	NO
10-Feb-21	1	1516.8	NO
11-Feb-21	0	1494.9	NO
12-Feb-21	0	2003.9	NO
13-Feb-21	1	1948.9	NO
14-Feb-21	0	2462.2	NO
15-Feb-21	1	1662.3	NO
16-Feb-21	5.5	1651.1	NO
17-Feb-21	4.5	1479.1	NO
18-Feb-21	1	1447.2	NO
19-Feb-21	2.5	1605.3	NO
20-Feb-21	1	1647.0	NO
21-Feb-21	0	1901.4	NO
22-Feb-21	0.5	1727.6	NO
23-Feb-21	0.5	1377.5	NO
24-Feb-21	0	1227.3	NO
25-Feb-21	4.5	1295.0	NO
26-Feb-21	0.5	1501.0	NO
27-Feb-21	0	2028.3	NO
28-Feb-21	0	1657.7	NO
Monthly Total		47069	
Monthly Minimum		1227	
Monthly Maximum	38	2890	



Anniversary Date: 01-Apr-20 Published Date: 18-Mar-21

Licensee: Eurobodalla Shire Council EPL No.:



Anniversary Date: Published Date: 01-Apr-20

18-Mar-21

Premises: Tomakin Sewage Treatment Plant Address: George Bass Drive, Tomakin, NSW 2537 Licence Period: 01-Apr-20

31-Mar-21 EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183819&SYSUID=1&LICID=2851

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

	Exceedance Report						
Date	Exceedance Type	Parameter	Description / Action				

Licensee: Eurobodalla Shire Council EPL No.:

Premises: Tomakin Sewage Treatment Plant Address: George Bass Drive, Tomakin, NSW 2537 Licence Period:

nce Period: 01-Apr-20 to 31-Mar-21

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183819&SYSUID=1&LICID=2851

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/



Anniversary Date: Published Date:

01-Apr-20 18-Mar-21

