

Moruya Sewage Treatment Plant - Monthly Result Summary - April 2023



Anniversary Date: 1-Apr-23
Published Date: 13-Jun-23

Licensee: Eurobodalla Shire Council
EPL No.: 1614
Premises: Moruya Sewage Treatment Plant
Address: Queen Street, Moruya, NSW 2537

Licence Period: 1-Apr-23 to 31-Mar-24

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206032&SYSUID=1&LICID=1614>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: **Apr-23**

Licence Point 6 (Discharge to Utilisation Area) & 11 (Discharge to Waters) - Concentration Limits			
Parameters	Unit of Measure	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	15
Oil and Grease	(mg/L)	5	10
pH	(pH Units)	-	6.5-8.5
Total Suspended Solids	(mg/L)	15	20
Chlorophyll a	(mg/m3)		
Faecal Coliforms	(CFU/100mL)	200	600
Total Nitrogen	(mg/L)	10	15
Total Phosphorus	(mg/L)	1	2
Ammonia	(mg/L)	2	5

See Note 1

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Points 6 and 11 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)										
Sample Frequency Sampling Method	Monthly Composite Sample	Monthly Grab Sample	Monthly Grab Sample	Monthly Composite Sample	Monthly Grab Sample	Monthly Grab Sample	Monthly Composite Sample	Monthly Composite Sample	Monthly Grab Sample	
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Chlorophyll a (mg/m3)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)	Obtained Date
18-Apr-23	3.00	<5	7.20	2.00	1.90	10000	9.03	0.67	0.50	2-May-23
100 Percentile Exceedance?	NO	NO	NO	NO	NO	YES	NO	NO	NO	

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)									
Year to Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Chlorophyll a (mg/m3)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)
Samples	1	1	1	1	1	1	1	1	1
Min	3.00	<5	7.20	2.00	1.90	10000	9.03	0.670	0.50
Mean	3.00	2.50	7.20	2.00	1.90	10000	9.03	0.670	0.50
Median (50th %ile)	3.00	2.50	7.20	2.00	1.90	10000	9.03	0.670	0.50
90th %ile	3.00	2.50	7.20	2.00	1.90	10000	9.03	0.670	0.50
Max (100th %ile)	3.00	<5	7.20	2.00	1.90	10000	9.03	0.670	0.50

Moruya Sewage Treatment Plant - Monthly Result Summary - April 2023

Licensee: Eurobodalla Shire Council
 EPL No.: 1614
 Premises: Moruya Sewage Treatment Plant
 Address: Queen Street, Moruya, NSW 2537



Anniversary Date: 1-Apr-23
 Published Date: 13-Jun-23

Licence Period: 1-Apr-23 to 31-Mar-24

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206032&SYSUID=1&LICID=1614>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Licence Point 2 - Influent Volume Monitoring			
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	14000
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall (mm)	Plant Inflow (kL)	Exceedance (YES/NO)
1-Apr-22	0	526.0	NO
2-Apr-22	0	510.0	NO
3-Apr-22	0	584.0	NO
4-Apr-22	0	521.0	NO
5-Apr-22	0	523.0	NO
6-Apr-22	7	587.0	NO
7-Apr-22	0	591.0	NO
8-Apr-22	2	609.0	NO
9-Apr-22	0	529.0	NO
10-Apr-22	0	573.0	NO
11-Apr-22	0	533.0	NO
12-Apr-22	0.6	539.0	NO
13-Apr-22	40.4	1534.0	NO
14-Apr-22	0	996.0	NO
15-Apr-22	0	727.0	NO
16-Apr-22	6	617.0	NO
17-Apr-22	0	741.0	NO
18-Apr-22	0	634.0	NO
19-Apr-22	0	679.0	NO
20-Apr-22	0	621.0	NO
21-Apr-22	0	590.0	NO
22-Apr-22	0	552.0	NO
23-Apr-22	0	515.0	NO
24-Apr-22	0	588.0	NO
25-Apr-22	0	528.0	NO
26-Apr-22	0	554.0	NO
27-Apr-22	0	551.0	NO
28-Apr-22	2.2	580.0	NO
29-Apr-22	6.2	533.0	NO
30-Apr-22	14	895.0	NO
Monthly Total	78.4	19060.0	
Monthly Minimum	0	510	
Monthly Mean	2.61	635.33	
Monthly Maximum	40.4	1534	
Year to Date Total	78.4	19060.0	
Year to Date Minimum	0.0	510.0	
Year to Date Mean	2.61	635.33	
Year to Date Maximum	40.4	1534.0	

Moruya Sewage Treatment Plant - Monthly Result Summary - April 2023

Licensee: Eurobodalla Shire Council

EPL No.: 1614

Premises: Moruya Sewage Treatment Plant

Address: Queen Street, Moruya, NSW 2537

Licence Period: 1-Apr-23 to 31-Mar-24

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206032&SYSUID=1&LICID=1614>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-23

Published Date: 13-Jun-23

Licence Point 7 - Ambient Water Monitoring (Monthly Result)

Frequency	Monthly	Monthly	
Sampling Method	Grab Sample	Grab Sample	
Sampled Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Obtained Date
18-Apr-23	2.01	0.077	2-May-23

Licence Point 8 - Ambient Water Monitoring (Monthly Result)

Frequency	Monthly	Monthly	
Sampling Method	Grab Sample	Grab Sample	
Sampled Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Obtained Date
18-Apr-23	1.11	0.042	2-May-23

Licence Point 7 - Ambient Water Monitoring (Year to Date Results)

Year to Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples	1	1
Min	2.01	0.077
Mean	2.01	0.077
Median (50th %ile)	2.01	0.077
90th %ile	2.01	0.077
Max (100th %ile)	2.01	0.077

Licence Point 8 - Ambient Water Monitoring (Year to Date Results)

Year to Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples	1	1
Min	1.11	0.042
Mean	1.11	0.042
Median (50th %ile)	1.11	0.042
90th %ile	1.11	0.042
Max (100th %ile)	1.11	0.042

Licence Point 9 - Ambient Water Monitoring (Monthly Result)

Frequency	Monthly		
Sampling Method	Grab Sample	Total Phosphorus	
Sampled Date	Total Nitrogen (mg/L)	(mg/L)	Obtained Date
18-Apr-23	0.27	0.014	2-May-23

Licence Point 10 - Ambient Water Monitoring (Monthly Result)

Frequency	Monthly		
Sampling Method	Grab Sample	Total Phosphorus	
Sampled Date	Total Nitrogen (mg/L)	(mg/L)	Obtained Date
18-Apr-23	0.23	0.014	2-May-23

Licence Point 9 - Ambient Water Monitoring (Year To Date Results)

Year to Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples	1	1
Min	0.27	0.014
Mean	0.27	0.014
Median (50th %ile)	0.27	0.014
90th %ile	0.27	0.014
Max (100th %ile)	0.27	0.014

Licence Point 10 - Ambient Water Monitoring (Year To Date Results)

Year to Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples	1	1
Min	0.23	0.014
Mean	0.23	0.014
Median (50th %ile)	0.23	0.014
90th %ile	0.23	0.014
Max (100th %ile)	0.23	0.014

Moruya Sewage Treatment Plant - Monthly Result Summary - April 2023

Licensee: Eurobodalla Shire Council
 EPL No.: 1614
 Premises: Moruya Sewage Treatment Plant
 Address: Queen Street, Moruya, NSW 2537
 Licence Period: 1-Apr-23 to 31-Mar-24
 EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206032&SYSUID=1&LICID=1614>
 POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-23
 Published Date: 13-Jun-23

Monthly Exceedance Report

Date	Exceedance Type	Parameter	Description / Action
18-Apr-23	Concentration Limit	Faecal Coliforms	Faecal Coliform result (10000 CFU/100mL) exceeded 100 percentile concentration limit (600 CFU/100mL) at monitoring point 3 (Prior to finishing pond)

EPA Licence Point Map

