eurobodalla shire council

Anniversary Date: Published Date: 1-Apr-23 29-Aug-23

Licensee: Eurobodalla Shire Council
EPL No.: 2851

Premises: Tomakin Sewage Treatment Plant Address: George Bass Drive, Tomakin, NSW 2537

Licence Period: 01-Apr-23 to 31-Mar-24

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206033&SYSUID=1&LICID=2851

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Required Month: Jun-23

Lie	cence Point 1 - Discharge to \	Waters - Concentration Limits		
Parameters	Unit of Measure	90 percentile concentration limit	100 percentile concentration limit	
Biological Oxygen Demand	(mg/L)	10	15	
Oil and Grease	(mg/L)	5	10	See Note 1
pH	(pH Units)	-	6.5-8.5	- 1
Total Suspended Solids	(mg/L)	15	20	
Chlorophyll a	(mg/m3)			
Faecal Coliforms	(CFU/100mL)	200	600	
Total Nitrogen	(mg/L)	10	15	
Total Phosphorus	(mg/L)	8	10	
Ammonia	(mg/L)	2	5	

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Point 1 as described in Condition L3.

			Lice	ence Point 3 - Effluent Quality	Monitoring (Monthly Results)				
Sample Frequency	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	
Sampling Method	Composite Sample	Grab Sample	Grab Sample	Composite Sample	Grab Sample	Composite Sample	Composite Sample	Grab Sample	
Sampled Date	Biological Oxygen Demand	Oil and Grease	рН	Total Suspended Solids	Chlorophyll a	Total Nitrogen	Total Phosphorus	Ammonia	Obtained Date
Jampieu Date	(mg/L)	(mg/L)	(pH Units)	(mg/L)	(mg/m3)	(mg/L)	(mg/L)	(mg/L)	Obtained Date
13-Jun-23	<2	<5	7.60	<2	2.90	1.49	8.16	0.09	23-Jun-23
100 Percentile Exceedance?	NO	NO	NO	NO	NO	NO	NO	NO	

	Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)							
Year to Date	Biological Oxygen Demand	Oil and Grease	pН	Total Suspended Solids	Chlorophyll a	Total Nitrogen	Total Phosphorus	Ammonia
real to bate	(mg/L)	(mg/L)	(pH Units)	(mg/L)	(mg/m3)	(mg/L)	(mg/L)	(mg/L)
Samples	3	3	3	3	3	3	3	3
Min	<2	<5	7.50	<2	2.90	1.49	7.360	0.09
Mean	1.00	2.50	7.53	2.67	4.40	2.67	7.893	0.43
Median (50th %ile)	1.00	2.50	7.50	2.00	3.80	2.60	8.160	0.11
90th %ile	1.00	2.50	7.58	4.40	5.96	3.66	8.160	0.89
Max (100th %ile)	<2	<5	7.60	5.00	6.50	3.93	8.160	1.08

Licensee: Eurobodalla Shire Council

Premises: Tomakin Sewage Treatment Plant Address: George Bass Drive, Tomakin, NSW 2537

01-Apr-23 31-Mar-24

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206033&SYSUID=1&LICID=2851

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

	Licence Point 2 - Influen	t Volume Monitoring	
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	14000
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall	Plant Inflow	Exceedance
Sample Date	(mm)	(kL)	(YES/NO)
1-Jun-23	0	1092.5	NO
2-Jun-23	0.5	1045.4	NO
3-Jun-23	0	1085.3	NO
4-Jun-23	0.5	1090.8	NO
5-Jun-23	0.5	1102.8	NO
6-Jun-23	1	1086.8	NO
7-Jun-23	0	1076.1	NO
8-Jun-23	0	1120.8	NO
9-Jun-23	1.5	1043.1	NO
10-Jun-23	0	1329.9	NO
11-Jun-23	0	1399.3	NO
12-Jun-23	0	1361.5	NO
13-Jun-23	0	1414.0	NO
14-Jun-23	1	1176.9	NO
15-Jun-23	0	1082.7	NO
16-Jun-23	0	1032.1	NO
17-Jun-23	0	1011.1	NO
18-Jun-23	0	1097.7	NO
19-Jun-23	0.5	1249.6	NO
20-Jun-23	0	1042.1	NO
21-Jun-23	0	1033.0	NO
22-Jun-23	0	1156.0	NO
23-Jun-23	1.5	1097.0	NO
24-Jun-23	0	1133.5	NO
25-Jun-23	0	1137.0	NO
26-Jun-23	0	1209.6	NO
27-Jun-23	0	1099.9	NO
28-Jun-23	0	1107.8	NO
29-Jun-23	0	1126.5	NO
30-Jun-23	0	1067.8	NO
Monthly Total	7.00	34108.35	
Monthly Minimum	0.00	1011.05	
Monthly Mean	0.23	1136.95	
Monthly Maximum	1.50	1413.99	
Year to Date Total	111.50	113957.84	
Year to Date Minimum	0.00	1011.05	
Year to Date Mean	1.23	1252.28	
Year to Date Maximum	25.50	2812.34	



1-Apr-23 29-Aug-23

eurobodalla Anniversary Date:
Shire council Published Date:

1-Apr-23

29-Aug-23

Licensee: Eurobodalla Shire Council
EPL No.: 2851

Premises: Tomakin Sewage Treatment Plant Address: George Bass Drive, Tomakin, NSW 2537

Licence Period: 01-Apr-23 to 31-Mar-24

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Licence Point 3 - Ambient Water Monitoring (Monthly Result)		
Frequency	Special Frequency 2*	
Sampling Method	Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date

	Monthly Result)	- Ambient Water Monitoring	Licence Point 4
		Special Frequency 2*	Frequency
		Grab Sample	Sampling Method
te	Obtained Date	Faecal Coliforms (CFU/100mL)	Sampled Date
te	Obtained Date		Sampled Date

^{*} Special Frequency 2: at least weekly during the months of November, December, January, February and March

Licence Point 3 - An	Licence Point 3 - Ambient Water Monitoring (Year to Date Results)		
Year to Date	Faecal Coliforms		
real to Date	(CFU/100mL)		
Samples			
Min	į		
Mean			
Median (50th %ile)			
90th %ile			
Max (100th %ile)			

Licence Point 4 - A	Licence Point 4 - Ambient Water Monitoring (Year to Date Results)		
Year to Date	Faecal Coliforms		
rear to Date	(CFU/100mL)		
Samples			
Min			
Mean			
Median (50th %ile)			
90th %ile			
Max (100th %ile)			

	Monthly Exceedance Report				
Date	Exceedance Type	Parameter	Description / Action		
13-Jun-23	Concentration limit	Total Phosphorus	Total Phosphorus result (8.16 mg/L) exceeded 90 percentile concentration limit (8 mg/L) at monitoring point 3		
į					
İ					
i	į				

Licensee: Eurobodalla Shire Council EPL No.:

Premises: Tomakin Sewage Treatment Plant Address: George Bass Drive, Tomakin, NSW 2537

Licence Period: 01-Apr-23 31-Mar-24

 $\textbf{EPL Link:} \ \ \underline{\text{https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206033\&SYSUID=1\&LICID=2851}$

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/



Published Date:

1-Apr-23 29-Aug-23

