

Narooma Sewage Treatment Plant - Monthly Result Summary - June 2026



Anniversary Date: 1-Apr-25  
Published Date: 10-Jul-26

Licensee: Eurobodalla Shire Council  
EPL No.: 1398  
Premises: Narooma Sewage Treatment Plant  
Address: Lakeside Drive, Narooma, NSW 2546  
Licence Period: 01-Apr-26 to 31-Mar-27  
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398>  
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: Jun-26

| Licence Point 1 - Discharge to Waters - Point 1 Concentration Limits |                 |                                   |                                    |
|----------------------------------------------------------------------|-----------------|-----------------------------------|------------------------------------|
| Parameters                                                           | Unit of Measure | 90 percentile concentration limit | 100 percentile concentration limit |
| Biological Oxygen Demand                                             | (mg/L)          | 10                                | 15                                 |
| Oil and Grease                                                       | (mg/L)          | 5                                 | 10                                 |
| pH                                                                   | (pH Units)      | -                                 | 6.5-8.5                            |
| Total Suspended Solids                                               | (mg/L)          | 15                                | 25                                 |
| Chlorophyll a                                                        | (mg/m3)         |                                   |                                    |
| Faecal Coliforms                                                     | (CFU/100mL)     | 200                               | 600                                |
| Total Nitrogen                                                       | (mg/L)          | 15                                | 20                                 |
| Total Phosphorus                                                     | (mg/L)          | 8                                 | 10                                 |
| Ammonia                                                              | (mg/L)          | 2                                 | 5                                  |

See Note 1

Note 1: A 100 Percentile Concentration Limit of “10 mg/L and no visible oil and grease” applies for Point 1.  
Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Point 1 as described in Condition L3.

| Licence Point 3 - Effluent Quality Monitoring (Monthly Results) |                                 |                       |                  |                               |                       |                       |                         |                  |               |
|-----------------------------------------------------------------|---------------------------------|-----------------------|------------------|-------------------------------|-----------------------|-----------------------|-------------------------|------------------|---------------|
| Sample Frequency                                                | 6 Times Per Year                | 6 Times Per Year      | 6 Times Per Year | 6 Times Per Year              | 6 Times Per Year      | 6 Times Per Year      | 6 Times Per Year        | 6 Times Per Year |               |
| Sampling Method                                                 | Composite Sample                | Grab Sample           | Grab Sample      | Composite Sample              | Grab Sample           | Composite Sample      | Composite Sample        | Grab Sample      |               |
| Sampled Date                                                    | Biological Oxygen Demand (mg/L) | Oil and Grease (mg/L) | pH (pH Units)    | Total Suspended Solids (mg/L) | Chlorophyll a (mg/m3) | Total Nitrogen (mg/L) | Total Phosphorus (mg/L) | Ammonia (mg/L)   | Obtained Date |
| 9-Jun-26                                                        | 4.00                            | <5                    | 7.80             | 3.00                          | 21.22                 | 9.67                  | 6.54                    | 0.14             | 19-Jun-26     |
| 100 Percentile Exceedance?                                      | NO                              | NO                    | NO               | NO                            | NO                    | NO                    | NO                      | NO               |               |

| Licence Point 3 - Effluent Quality Monitoring (Year To Date Results) |                                 |                       |               |                               |                       |                       |                         |                |
|----------------------------------------------------------------------|---------------------------------|-----------------------|---------------|-------------------------------|-----------------------|-----------------------|-------------------------|----------------|
| Year to Date                                                         | Biological Oxygen Demand (mg/L) | Oil and Grease (mg/L) | pH (pH Units) | Total Suspended Solids (mg/L) | Chlorophyll a (mg/m3) | Total Nitrogen (mg/L) | Total Phosphorus (mg/L) | Ammonia (mg/L) |
| Samples                                                              | 3                               | 3                     | 3             | 3                             | 3                     | 3                     | 3                       | 3              |
| Min                                                                  | <2                              | <5                    | 7.60          | <2                            | 0.27                  | 4.86                  | 5.030                   | 0.05           |
| Mean                                                                 | 2.00                            | 2.50                  | 7.67          | 1.67                          | 7.71                  | 6.49                  | 6.643                   | 0.22           |
| Median (50th %ile)                                                   | 1.00                            | 2.50                  | 7.60          | 1.00                          | 1.63                  | 4.93                  | 6.540                   | 0.14           |
| 90th %ile                                                            | 3.40                            | 2.50                  | 7.76          | 2.60                          | 17.30                 | 8.72                  | 7.996                   | 0.40           |
| Max (100th %ile)                                                     | 4.00                            | <5                    | 7.80          | 3.00                          | 21.22                 | 9.67                  | 8.360                   | 0.46           |

Narooma Sewage Treatment Plant - Monthly Result Summary - June 2026

Licensee: Eurobodalla Shire Council

EPL No.: 1398

Premises: Narooma Sewage Treatment Plant

Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-26 to 31-Mar-27

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25  
Published Date: 10-Jul-26

| Licence Point 2 - Influent Volume Monitoring |                       |                         |                     |
|----------------------------------------------|-----------------------|-------------------------|---------------------|
| Sample Frequency                             | Daily (Continuous)    | Maximum Daily flow (kL) | 20000               |
| Sampling Method                              | Ultrasonic Flow Meter |                         |                     |
| Sample Date                                  | Rainfall (mm)         | Plant Inflow (kL)       | Exceedance (YES/NO) |
| 1-Jun-26                                     | 0.2                   | 1491.1                  | NO                  |
| 2-Jun-26                                     | 0                     | 1395.1                  | NO                  |
| 3-Jun-26                                     | 0.2                   | 1450.8                  | NO                  |
| 4-Jun-26                                     | 0                     | 1407.5                  | NO                  |
| 5-Jun-26                                     | 0                     | 1460.9                  | NO                  |
| 6-Jun-26                                     | 0                     | 1586.5                  | NO                  |
| 7-Jun-26                                     | 0.2                   | 1589.6                  | NO                  |
| 8-Jun-26                                     | 0.2                   | 1529.3                  | NO                  |
| 9-Jun-26                                     | 1.2                   | 1407.8                  | NO                  |
| 10-Jun-26                                    | 0.8                   | 1388.2                  | NO                  |
| 11-Jun-26                                    | 0.2                   | 1429.3                  | NO                  |
| 12-Jun-26                                    | 0.2                   | 1403.3                  | NO                  |
| 13-Jun-26                                    | 0                     | 1392.6                  | NO                  |
| 14-Jun-26                                    | 0.2                   | 1350.7                  | NO                  |
| 15-Jun-26                                    | 0                     | 1372.7                  | NO                  |
| 16-Jun-26                                    | 0                     | 1392.7                  | NO                  |
| 17-Jun-26                                    | 0                     | 1315.2                  | NO                  |
| 18-Jun-26                                    | 0                     | 1325.4                  | NO                  |
| 19-Jun-26                                    | 0                     | 1308.8                  | NO                  |
| 20-Jun-26                                    | 0                     | 1380.4                  | NO                  |
| 21-Jun-26                                    | 0                     | 1355.7                  | NO                  |
| 22-Jun-26                                    | 0                     | 1388.3                  | NO                  |
| 23-Jun-26                                    | 0.4                   | 1375.1                  | NO                  |
| 24-Jun-26                                    | 0                     | 1375.1                  | NO                  |
| 25-Jun-26                                    | 0                     | 1352.3                  | NO                  |
| 26-Jun-26                                    | 1                     | 1346.7                  | NO                  |
| 27-Jun-26                                    | 0                     | 1352.5                  | NO                  |
| 28-Jun-26                                    | 0                     | 1387.6                  | NO                  |
| 29-Jun-26                                    | 4.8                   | 1438.9                  | NO                  |
| 30-Jun-26                                    | 0.2                   | 1373.0                  | NO                  |
| Monthly Total                                | 9.80                  | 42122.81                |                     |
| Monthly Minimum                              | 0.00                  | 1308.77                 |                     |
| Monthly Mean                                 | 0.33                  | 1404.09                 |                     |
| Monthly Maximum                              | 4.80                  | 1589.57                 |                     |
| Year to Date Total                           | 66.20                 | 135804.19               |                     |
| Year to Date Minimum                         | 0.00                  | 1294.10                 |                     |
| Year to Date Mean                            | 0.73                  | 1492.35                 |                     |
| Year to Date Maximum                         | 11.00                 | 3372.72                 |                     |

Narooma Sewage Treatment Plant - Monthly Result Summary - June 2026

Licensee: Eurobodalla Shire Council

EPL No.: 1398

Premises: Narooma Sewage Treatment Plant

Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-26 to 31-Mar-27

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25

Published Date: 10-Jul-26

| Licence Point 3 - Effluent Quality Monitoring (Monthly Results) |                              |               |
|-----------------------------------------------------------------|------------------------------|---------------|
| Frequency                                                       | Special Frequency 2*         |               |
| Sampling Method                                                 | Grab Sample                  |               |
| Sampled Date                                                    | Faecal Coliforms (CFU/100mL) | Obtained Date |
|                                                                 |                              |               |

| Licence Point 4 - Ambient Water Monitoring (Monthly Results) |                              |               |
|--------------------------------------------------------------|------------------------------|---------------|
| Frequency                                                    | Special Frequency 2*         |               |
| Sampling Method                                              | Grab Sample                  |               |
| Sampled Date                                                 | Faecal Coliforms (CFU/100mL) | Obtained Date |
|                                                              |                              |               |

| Licence Point 5 - Ambient Water Monitoring (Monthly Results) |                              |               |
|--------------------------------------------------------------|------------------------------|---------------|
| Frequency                                                    | Special Frequency 2*         |               |
| Sampling Method                                              | Grab Sample                  |               |
| Sampled Date                                                 | Faecal Coliforms (CFU/100mL) | Obtained Date |
|                                                              |                              |               |

\* Special Frequency 2: at least weekly during the months of November, December, January, February and March

| Licence Point 3 - Effluent Quality Monitoring (Year to Date Results) |  |  |
|----------------------------------------------------------------------|--|--|
|                                                                      |  |  |

| Licence Point 4 - Ambient Water Monitoring (Year to Date Results) |  |  |
|-------------------------------------------------------------------|--|--|
|                                                                   |  |  |

| Licence Point 5 - Ambient Water Monitoring (Year to Date Results) |  |  |
|-------------------------------------------------------------------|--|--|
|                                                                   |  |  |

| Monthly Exceedance Report |                 |           |                      |
|---------------------------|-----------------|-----------|----------------------|
| Date                      | Exceedance Type | Parameter | Description / Action |
|                           |                 |           |                      |

## Narooma Sewage Treatment Plant - Monthly Result Summary - June 2026

Licensee: Eurobodalla Shire Council

EPL No.: 1398

Premises: Narooma Sewage Treatment Plant

Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-26 to 31-Mar-27

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25

Published Date: 10-Jul-26

EPA Licence Point Map

