

Moruya Sewage Treatment Plant - Monthly Result Summary - April 2021



Anniversary Date: 1-Apr-21
Published Date: 18-May-21

Licensee: Eurobodalla Shire Council
EPL No.: 1614
Premises: Moruya Sewage Treatment Plant
Address: Queen Street, Moruya, NSW 2537
Licence Period: 1-Apr-21 to 31-Mar-22
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/viewPOEOLicence.aspx?DOCID=206032&SYSUID=1&LICID=1614>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: **Apr-21**

Licence Point 6 (Discharge to Utilisation Area) & 11 (Discharge to Waters) - Concentration Limits			
Parameters	Unit of Measure	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	15
Oil and Grease	(mg/L)	5	10
pH	(pH Units)	-	6.5-8.5
Total Suspended Solids	(mg/L)	15	20
Faecal Coliforms	(CFU/100mL)	200	600
Total Nitrogen	(mg/L)	10	15
Total Phosphorus	(mg/L)	1	2
Ammonia	(mg/L)	2	5

See Note 1

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Points 6 and 11 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)									
Sample Frequency Sampling Method	Monthly Composite Sample	Monthly Grab Sample	Monthly Grab Sample	Monthly Composite Sample	Monthly Grab Sample	Monthly Composite Sample	Monthly Composite Sample	Monthly Grab Sample	Obtained Date
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)	
20-Apr-21	3.00	<5	7.40	6.00	1300	5.04	0.24	0.01	5-May-21
100 Percentile Exceedance?	NO	NO	NO	NO	YES	NO	NO	NO	

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)								
Year to Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)
Total Samples	1	1	1	1	1	1	1	1
Minimum Result	3.00	<5	7.40	6.00	1300	5.04	0.24	0.01
Mean Result	3.00	2.50	7.40	6.00	1300	5.04	0.24	0.01
Median Result	3.00	2.50	7.40	6.00	1300	5.04	0.24	0.01
Maximum Result	3.00	<5	7.40	6.00	1300	5.04	0.24	0.01

Moruya Sewage Treatment Plant - Monthly Result Summary - April 2021

Licensee: Eurobodalla Shire Council
 EPL No.: 1614
 Premises: Moruya Sewage Treatment Plant
 Address: Queen Street, Moruya, NSW 2537
 Licence Period: 1-Apr-21 to 31-Mar-22
 EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206032&SYSUID=1&LICID=1614>
 POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-21
 Published Date: 18-May-21

Licence Point 2 - Influent Volume Monitoring

Sample Frequency	Daily (Continuous)	Maximum Daily flow (kl)	14000
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall (mm)	Plant Inflow (kl)	Exceedance (YES/NO)
1-Apr-21	2	1341.0	NO
2-Apr-21	0	907.0	NO
3-Apr-21	0	920.0	NO
4-Apr-21	0.2	866.0	NO
5-Apr-21	7.2	840.0	NO
6-Apr-21	9.4	952.0	NO
7-Apr-21	0.8	898.0	NO
8-Apr-21	0	934.0	NO
9-Apr-21	0.2	823.0	NO
10-Apr-21	0	748.0	NO
11-Apr-21	0.2	715.0	NO
12-Apr-21	0	1008.0	NO
13-Apr-21	0	1032.0	NO
14-Apr-21	0	986.0	NO
15-Apr-21	0	871.0	NO
16-Apr-21	0	705.0	NO
17-Apr-21	0	643.0	NO
18-Apr-21	0	617.0	NO
19-Apr-21	0	667.0	NO
20-Apr-21	0	633.0	NO
21-Apr-21	0	602.0	NO
22-Apr-21	0	683.0	NO
23-Apr-21	0		N/R
24-Apr-21	0	581.0	NO
25-Apr-21	0	588.0	NO
26-Apr-21	0	573.0	NO
27-Apr-21	0	568.0	NO
28-Apr-21	0	557.0	NO
29-Apr-21	0	578.0	NO
30-Apr-21	0	592.0	NO
Monthly Total	20	22428.0	
Monthly Minimum	0	557	
Monthly Mean	0.67	773.38	
Monthly Maximum	9.4	1341	
Year to Date Total	20	22428.0	
Year to Date Minimum	0	557	
Year to Date Mean	0.67	773.38	
Year to Date Maximum	9.4	1341	

Moruya Sewage Treatment Plant - Monthly Result Summary - April 2021

Licensee: Eurobodalla Shire Council
 EPL No.: 1614
 Premises: Moruya Sewage Treatment Plant
 Address: Queen Street, Moruya, NSW 2537
 Licence Period: 1-Apr-21 to 31-Mar-22
 EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206032&SYSUID=1&LICID=1614>
 POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-21
 Published Date: 18-May-21

Licence Point 7 - Ambient Water Monitoring (Monthly Result)

Frequency Sampling Method	Monthly Grab Sample	Monthly Grab Sample	
Sampled Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Obtained Date
20-Apr-21	1.22	0.040	5-May-21

Licence Point 8 - Ambient Water Monitoring (Monthly Result)

Frequency Sampling Method	Monthly Grab Sample	Monthly Grab Sample	
Sampled Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Obtained Date
20-Apr-21	1.54	0.028	5-May-21

Licence Point 7 - Ambient Water Monitoring (Year to Date Results)

Year to Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples to date	1	1
Minimum Result	1.22	0.040
Mean Result	1.22	0.040
Median Result	1.22	0.040
Maximum Result	1.22	0.040

Licence Point 8 - Ambient Water Monitoring (Year to Date Results)

Year to Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples to date	1	1
Minimum Result	1.54	0.028
Mean Result	1.54	0.028
Median Result	1.54	0.028
Maximum Result	1.54	0.028

Licence Point 9 - Ambient Water Monitoring (Monthly Result)

Frequency Sampling Method	Monthly Grab Sample	Monthly Grab Sample	
Sampled Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Obtained Date
20-Apr-21	0.17	0.007	5-May-21

Licence Point 10 - Ambient Water Monitoring (Monthly Result)

Frequency Sampling Method	Monthly Grab Sample	Monthly Grab Sample	
Sampled Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Obtained Date
20-Apr-21	0.19	0.008	5-May-21

Licence Point 9 - Ambient Water Monitoring (Year To Date Results)

Year to Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples to date	1	1
Minimum Result	0.17	0.007
Mean Result	0.17	0.007
Median Result	0.17	0.007
Maximum Result	0.17	0.007

Licence Point 10 - Ambient Water Monitoring (Year To Date Results)

Year to Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples to date	1	1
Minimum Result	0.19	0.008
Mean Result	0.19	0.008
Median Result	0.19	0.008
Maximum Result	0.19	0.008

Moruya Sewage Treatment Plant - Monthly Result Summary - April 2021

Licensee: Eurobodalla Shire Council
 EPL No.: 1614
 Premises: Moruya Sewage Treatment Plant
 Address: Queen Street, Moruya, NSW 2537
 Licence Period: 1-Apr-21 to 31-Mar-22
 EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206032&SYSUID=1&LICID=1614>
 POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-21
 Published Date: 18-May-21

Monthly Exceedance Report

Date	Exceedance Type	Parameter	Description / Action
20-Apr-21	Concentration Limit	Faecal Coliforms	100 Percentile concentration limit exceeded. Operators to assess UV system.

EPA Licence Point Map

