

Tuross Sewage Treatment Plant - Monthly Result Summary - July 2026



Anniversary Date: 1-Apr-25
Published Date: 12-Aug-26

Licensee: Eurobodalla Shire Council
EPL No.: 3108
Premises: Tuross Sewage Treatment Plant
Address: 217 Kelly Road, Bingie, NSW, 2537
Licence Period: 01-Apr-26 to 31-Mar-27
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: Jul-26

Licence Point 1 (Discharge to Waters) and 4 (Discharge to Utilisation Area) - Concentration Limits			
Parameters	Unit of Measure	50 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	15	20
Oil and Grease	(mg/L)		10
Total Suspended Solids	(mg/L)	20	30
Total Nitrogen	(mg/L)		
Total Phosphorus	(mg/L)		

See Note 1

Note 1: A 100 Percentile Concentration Limit of “10 mg/L and no visible oil and grease” applies for Point 1.
Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Points 1 and 4 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)						
Sample Frequency Sampling Method	Monthly Composite Sample	Monthly Grab Sample	Monthly Composite Sample	Monthly Composite Sample	Monthly Composite Sample	
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	Total Suspended Solids (mg/L)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Obtained Date
7-Jul-26	3.00	<5	6.00	4.96	3.67	16-Jul-26
100 Percentile Exceedance?	NO	NO	NO	NO	NO	

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)					
Year to Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	Total Suspended Solids (mg/L)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples	4	4	4	4	4
Min	<2	<5	4.00	3.00	1.05
Mean	2.25	2.50	7.25	5.53	3.82
Median (50th %ile)	2.50	2.50	7.50	4.82	3.60
90th %ile	3.00	2.50	9.70	8.12	6.03
Max (100th %ile)	3.00	<5	10.00	9.47	7.04

Tuross Sewage Treatment Plant - Monthly Result Summary - July 2026

Licensee: Eurobodalla Shire Council

EPL No.: 3108

Premises: Tuross Sewage Treatment Plant

Address: 217 Kelly Road, Bingie, NSW, 2537

Licence Period: 01-Apr-26 to 31-Mar-27

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25

Published Date: 12-Aug-26

Licence Point 2 - Influent Volume Monitoring			
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	7000
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall (mm)	Plant Inflow (kL)	Exceedance (YES/NO)
1-Jul-26	0	380.9	NO
2-Jul-26	0	415.6	NO
3-Jul-26	0	410.0	NO
4-Jul-26	0	438.0	NO
5-Jul-26	0	455.0	NO
6-Jul-26	0	409.3	NO
7-Jul-26	0	410.9	NO
8-Jul-26	0.2	435.2	NO
9-Jul-26	1.4	420.3	NO
10-Jul-26	0	437.0	NO
11-Jul-26	0	473.0	NO
12-Jul-26	0	438.7	NO
13-Jul-26	0	451.7	NO
14-Jul-26	0	400.6	NO
15-Jul-26	0	410.1	NO
16-Jul-26	0	403.0	NO
17-Jul-26	0	434.5	NO
18-Jul-26	0	441.5	NO
19-Jul-26	0	401.0	NO
20-Jul-26	0	404.4	NO
21-Jul-26	0	383.6	NO
22-Jul-26	0	383.6	NO
23-Jul-26	0	357.0	NO
24-Jul-26	0	395.5	NO
25-Jul-26	0	422.0	NO
26-Jul-26	0	413.7	NO
27-Jul-26	0	375.3	NO
28-Jul-26	0	368.8	NO
29-Jul-26	0	374.7	NO
30-Jul-26	0	360.5	NO
31-Jul-26	0	388.7	NO
Monthly Total	1.6	12693.9	
Monthly Minimum	0	356.95	
Monthly Mean	0.05	409.48	
Monthly Maximum	1.4	473	
Year to Date Total	84.8	52963.39	
Year to Date Minimum	0	316.8	
Year to Date Mean	0.70	434.13	
Year to Date Maximum	42	827.31	

Tuross Sewage Treatment Plant - Monthly Result Summary - July 2026

Licensee: Eurobodalla Shire Council
EPL No.: 3108
Premises: Tuross Sewage Treatment Plant
Address: 217 Kelly Road, Bingie, NSW, 2537
Licence Period: 01-Apr-26 to 31-Mar-27
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25
Published Date: 12-Aug-26

Monthly Exceedance Report				
Date	Exceedance Type	Parameter	Description / Action	

EPA Licence Point Map

