

Tuross Sewage Treatment Plant - Monthly Result Summary - May 2026



Anniversary Date: 1-Apr-25
Published Date: 5-Jun-26

Licensee: Eurobodalla Shire Council
EPL No.: 3108
Premises: Tuross Sewage Treatment Plant
Address: 217 Kelly Road, Bingie, NSW, 2537
Licence Period: 01-Apr-26 to 31-Mar-27
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: May-26

Licence Point 1 (Discharge to Waters) and 4 (Discharge to Utilisation Area) - Concentration Limits			
Parameters	Unit of Measure	50 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	15	20
Oil and Grease	(mg/L)		10
Total Suspended Solids	(mg/L)	20	30
Total Nitrogen	(mg/L)		
Total Phosphorus	(mg/L)		

See Note 1

Note 1: A 100 Percentile Concentration Limit of “10 mg/L and no visible oil and grease” applies for Point 1.
Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Points 1 and 4 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)						
Sample Frequency Sampling Method	Monthly Composite Sample	Monthly Grab Sample	Monthly Composite Sample	Monthly Composite Sample	Monthly Composite Sample	
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	Total Suspended Solids (mg/L)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Obtained Date
12-May-26	<2	<5	9.00	4.68	3.52	20-May-26
100 Percentile Exceedance?	NO	NO	NO	NO	NO	

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)					
Year to Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	Total Suspended Solids (mg/L)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples	2	2	2	2	2
Min	<2	<5	9.00	4.68	3.52
Mean	2.00	2.50	9.50	7.08	5.28
Median (50th %ile)	2.00	2.50	9.50	7.08	5.28
90th %ile	2.80	2.50	9.90	8.99	6.69
Max (100th %ile)	3.00	<5	10.00	9.47	7.04

Tuross Sewage Treatment Plant - Monthly Result Summary - May 2026

Licensee: Eurobodalla Shire Council

EPL No.: 3108

Premises: Tuross Sewage Treatment Plant

Address: 217 Kelly Road, Bingie, NSW, 2537

Licence Period: 01-Apr-26 to 31-Mar-27

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25

Published Date: 5-Jun-26

Licence Point 2 - Influent Volume Monitoring			
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	7000
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall (mm)	Plant Inflow (kL)	Exceedance (YES/NO)
1-May-26	0	394.0	NO
2-May-26	0	416.0	NO
3-May-26	0	420.6	NO
4-May-26	0	364.6	NO
5-May-26	0	386.2	NO
6-May-26	0	372.7	NO
7-May-26	0	372.9	NO
8-May-26	0	372.8	NO
9-May-26	0	316.8	NO
10-May-26	0	418.1	NO
11-May-26	0	388.8	NO
12-May-26	0	375.9	NO
13-May-26	13.2	371.1	NO
14-May-26	0	429.8	NO
15-May-26	4	370.5	NO
16-May-26	0	421.6	NO
17-May-26	0	437.5	NO
18-May-26	2.8	373.8	NO
19-May-26	9	413.2	NO
20-May-26	0.2	436.2	NO
21-May-26	0	346.4	NO
22-May-26	0	374.2	NO
23-May-26	0	401.4	NO
24-May-26	0	468.0	NO
25-May-26	0.8	406.5	NO
26-May-26	42	827.3	NO
27-May-26	0.2	700.7	NO
28-May-26	0	499.0	NO
29-May-26	1.2	515.2	NO
30-May-26	0	508.8	NO
31-May-26	0	512.7	NO
Monthly Total	73.4	13413.1	
Monthly Minimum	0	316.8	
Monthly Mean	2.37	432.68	
Monthly Maximum	42	827.31	
Year to Date Total	74.4	27549.41	
Year to Date Minimum	0	316.8	
Year to Date Mean	1.22	451.63	
Year to Date Maximum	42	827.31	

Tuross Sewage Treatment Plant - Monthly Result Summary - May 2026

Licensee: Eurobodalla Shire Council

EPL No.: 3108

Premises: Tuross Sewage Treatment Plant

Address: 217 Kelly Road, Bingie, NSW, 2537

Licence Period: 01-Apr-26 to 31-Mar-27

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date:

1-Apr-25

Published Date:

5-Jun-26

Monthly Exceedance Report

Date	Exceedance Type	Parameter	Description / Action

EPA Licence Point Map

