

Tuross Sewage Treatment Plant - Monthly Result Summary - June 2026



Anniversary Date: 1-Apr-25
Published Date: 10-Jul-26

Licensee: Eurobodalla Shire Council
EPL No.: 3108
Premises: Tuross Sewage Treatment Plant
Address: 217 Kelly Road, Bingie, NSW, 2537
Licence Period: 01-Apr-26 to 31-Mar-27
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: Jun-26

Licence Point 1 (Discharge to Waters) and 4 (Discharge to Utilisation Area) - Concentration Limits				See Note 1
Parameters	Unit of Measure	50 percentile concentration limit	100 percentile concentration limit	
Biological Oxygen Demand	(mg/L)	15	20	
Oil and Grease	(mg/L)		10	
Total Suspended Solids	(mg/L)	20	30	
Total Nitrogen	(mg/L)			
Total Phosphorus	(mg/L)			

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Points 1 and 4 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)						
Sample Frequency Sampling Method	Monthly Composite Sample	Monthly Grab Sample	Monthly Composite Sample	Monthly Composite Sample	Monthly Composite Sample	
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	Total Suspended Solids (mg/L)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Obtained Date
9-Jun-26	2.00	<5	4.00	3.00	1.05	17-Jun-26
100 Percentile Exceedance?	NO	NO	NO	NO	NO	

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)					
Year to Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	Total Suspended Solids (mg/L)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples	3	3	3	3	3
Min	<2	<5	4.00	3.00	1.05
Mean	2.00	2.50	7.67	5.72	3.87
Median (50th %ile)	2.00	2.50	9.00	4.68	3.52
90th %ile	2.80	2.50	9.80	8.51	6.34
Max (100th %ile)	3.00	<5	10.00	9.47	7.04

Tuross Sewage Treatment Plant - Monthly Result Summary - June 2026

Licensee: Eurobodalla Shire Council

EPL No.: 3108

Premises: Tuross Sewage Treatment Plant

Address: 217 Kelly Road, Bingie, NSW, 2537

Licence Period: 01-Apr-26 to 31-Mar-27

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25

Published Date: 10-Jul-26

Licence Point 2 - Influent Volume Monitoring			
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	7000
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall (mm)	Plant Inflow (kL)	Exceedance (YES/NO)
1-Jun-26	0	437.5	NO
2-Jun-26	0	413.3	NO
3-Jun-26	0	404.4	NO
4-Jun-26	0	423.8	NO
5-Jun-26	0	390.0	NO
6-Jun-26	0	497.6	NO
7-Jun-26	0	585.6	NO
8-Jun-26	0	766.1	NO
9-Jun-26	4.6	505.0	NO
10-Jun-26	3.2	380.7	NO
11-Jun-26	0	396.6	NO
12-Jun-26	0	416.7	NO
13-Jun-26	0	437.2	NO
14-Jun-26	0.6	382.1	NO
15-Jun-26	0	385.5	NO
16-Jun-26	0	384.4	NO
17-Jun-26	0	390.6	NO
18-Jun-26	0	363.9	NO
19-Jun-26	0	381.0	NO
20-Jun-26	0	415.0	NO
21-Jun-26	0	419.9	NO
22-Jun-26	0	382.0	NO
23-Jun-26	0	391.2	NO
24-Jun-26	0	378.4	NO
25-Jun-26	0.4	392.5	NO
26-Jun-26	0	402.1	NO
27-Jun-26	0	436.0	NO
28-Jun-26	0	399.3	NO
29-Jun-26	0	381.0	NO
30-Jun-26	0	380.9	NO
Monthly Total	8.8	12720.1	
Monthly Minimum	0	363.85	
Monthly Mean	0.29	424.00	
Monthly Maximum	4.6	766.1	
Year to Date Total	83.2	40269.5	
Year to Date Minimum	0	316.8	
Year to Date Mean	0.91	442.52	
Year to Date Maximum	42	827.31	

Tuross Sewage Treatment Plant - Monthly Result Summary - June 2026

Licensee: Eurobodalla Shire Council
EPL No.: 3108
Premises: Tuross Sewage Treatment Plant
Address: 217 Kelly Road, Bingie, NSW, 2537
Licence Period: 01-Apr-26 to 31-Mar-27
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25
Published Date: 10-Jul-26

Monthly Exceedance Report				
Date	Exceedance Type	Parameter	Description / Action	

EPA Licence Point Map

