euro	bodalla re council
Licensee:	Eurobodalla Shire Council
EPL No.:	1397
Premises:	Batemans Bay Sewage Treatment Plant

Address: George Bass Drive, Batemans Bay, NSW 2536

Licence Period: 1-Apr-20 to 31-Mar-21 EPL Link: https://apps.epa.nsw.gov.au/proeoapp/ViewPOEOLicence.aspx?DOCID=33192&SYSUID=1&LICID=1397

POEO Public Register: <u>https://apps.epa.nsw.gov.au/prpoeoapp/</u>

Required Month: Nov-20

Licence Point / Type of Point:	Licence Point 1 - Discharge to Wat	ters - Point 1 Concentration Lim	its
Parameters	Unit of Measure	50 percentile	100 percentile
Farameters	Unit of Measure	concentration limit	concentration limit
Biological Oxygen Demand	(mg/L)	10	20
Oil and Grease	(mg/L)	-	10
Total Suspended Solids	(mg/L)	15	30

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Point 1 as described in Condition L3.

Licence Point / Type of Point:	Licence Point 3 - Effluent Quality Me	onitoring					
Sample Frequency	Monthly	Special Frequency 1	Monthly	Monthly	Monthly	Monthly	
Sampling Method	Composite Sample	Grab Sample	Composite Sample	Grab Sample	Composite Sample	Composite Sample	
Parameters	Biological Oxygen Demand	Chlorophyll a	Total Nitrogen	Oil and Grease	Total Phosphorus	Total Suspended Solids	
Unit of Measure	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	
Sampled Date	Biological Oxygen Demand	Chlorophyll a	Total Nitrogen	Oil and Grease	Total Phosphorus	Total Suspended Solids	Obtained Date
3-Nov-20	<2	0.0007	4.85	<5	1.29	<2	12-Nov-20
Minimum Value	<2	0.0007	4.85	<5	1.29	<2	
Maximum Value	<2	0.0007	4.85	<5	1.29	<2	

100 Percentile - Licence Condition									
	Biological Oxygen Demand		Oil and Grease			Total Suspended Solids			
Sample Date	Measurement	Actual 100 Percentile to Sample Date	Exceedance	Measurement	Actual 100 Percentile to Sample Date	Exceedance	Measurement	Actual 100 Percentile to Sample Date	Exceedance
3-Nov-20	<2	2.00	NO	<5	5.00	NO	<2	3.00	NO

Special Frequency 1: means collect and store sample monthly, at the same time as Biochemical Oxygen Demand or Total Suspended Solids sampling. If the Biochemical Oxygen Demand or Total Suspended Solids 100 percentile concentration limit is exceeded as per condition 13.3, then analyse the stored sample for chlorophyll a and report results to the EPA as soon as the results become available.

Anniversary Date: 1-Apr-20 Published Date: 3-Dec-20

Licensee: Eurobodalla Shire Council

EPL No.: 1397

Premises: Batemans Bay Sewage Treatment Plant

Address: George Bass Drive, Batemans Bay, NSW 2536

Licence Period: 1-Apr-20 to 31-Mar-21

EPL Link: https://apps.epa.nsw.gov.au/orpoeoapp/ViewPOEOLicence.aspx?DOCID=33192&SYSUID=1&LICID=1397
POEO Public Register: https://apps.epa.nsw.gov.au/orpoeoapp/

Licence Point / Type of Point:	Licence Point 2 - Influent Volume N		
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	25000
Sampling Method	Ultrasonic Flow Meter		
Parameter	Rainfall	Plant Inflow	Exceedance
Unit of Measure	(mm)	(kL)	(YES/NO)
Sample Date			
1-Nov-20	73	14018.0	NO
2-Nov-20	1.5	19378.0	NO
3-Nov-20	0.5	9412.5	NO
4-Nov-20	0	6562.5	NO
5-Nov-20	17	6040.3	NO
6-Nov-20	10.5	11952.2	NO
7-Nov-20	0	8578.6	NO
8-Nov-20	0	6401.8	NO
9-Nov-20	0.5	5771.7	NO
10-Nov-20	0	5278.6	NO
11-Nov-20	0	5116.6	NO
12-Nov-20	0	4934.9	NO
13-Nov-20	1.5	4698.9	NO
14-Nov-20	0	4860.5	NO
15-Nov-20	0	4859.6	NO
16-Nov-20	0	4798.8	NO
17-Nov-20	1	4521.0	NO
18-Nov-20	0	4296.2	NO
19-Nov-20	0	4433.9	NO
20-Nov-20	0	4385.3	NO
21-Nov-20	5.5	4571.5	NO
22-Nov-20	0.5	4568.7	NO
23-Nov-20	6.5	4446.5	NO
24-Nov-20	15	5313.5	NO
25-Nov-20	0.5	4882.5	NO
26-Nov-20	0	4570.6	NO
27-Nov-20	0	4430.4	NO
28-Nov-20	0	4538.8	NO
29-Nov-20	1	4570.2	NO
30-Nov-20	0	4462.0	NO
Monthly Total	134.5	186654.6	
Monthly Minimum	0	4296.2	
Monthly Maximum	73	19378	



Anniversary Date: Published Date:

1-Apr-20 3-Dec-20

Licensee: Eurobodalla Shire Council

EPL No.: 1397

Premises: Batemans Bay Sewage Treatment Plant

Address: George Bass Drive, Batemans Bay, NSW 2536

Licence Period: 1-Apr-20 to 31-Mar-21

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp//iewPOEOLicence.aspx?DOCID=33192&SYSUID=1&LICID=1397
POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Monthly Grab Sample Faecal Coliforms		
Farmer Callfornia		
Faecal Coliforms		
cfu/100 mL		
		Obtained Date
4		12-Nov-20
	· · ·	

Minimum Value	4
Maximum Value	4

Maximum Value

Licence Point / Type of Point:	Licence Point 5 - Ambient Water Monitoring	
Sample Frequency	Monthly	
Sampling Method	Grab Sample	
Parameters	Faecal Coliforms	
Unit of Measure	cfu/100 mL	
Sampled Date		Obtained Date
3-Nov-20	1	12-Nov-20
Minimum Value	1	

1



Anniversary Date: Published Date:

1-Apr-20 3-Dec-20

eurobodalla shire council

Anniversary Date:

Published Date:

1-Apr-20

3-Dec-20

Licensee: Eurobodalla Shire Council EPL No.: 1397

Premises: Batemans Bay Sewage Treatment Plant

Address: George Bass Drive, Batemans Bay, NSW 2536

Licence Period: 1-Apr-20

to 31-Mar-21 EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=33192&SYSUID=1&LICID=1397

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Date	Exceedance Type	Parameter	Description / Action

