

Narooma Sewage Treatment Plant - Monthly Result Summary - March 2022



Anniversary Date: 1-Apr-21
Published Date: 23-May-22

Licensee: Eurobodalla Shire Council
EPL No.: 1398
Premises: Narooma Sewage Treatment Plant
Address: Lakeside Drive, Narooma, NSW 2546
Licence Period: 01-Apr-21 to 31-Mar-22
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: **Mar-22**

Licence Point 1 - Discharge to Waters - Point 1 Concentration Limits			
Parameters	Unit of Measure	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	15
Oil and Grease	(mg/L)	5	10
pH	(pH Units)	-	6.5-8.5
Total Suspended Solids	(mg/L)	15	25
Chlorophyll a	(mg/m3)		
Faecal Coliforms	(CFU/100mL)	200	600
Total Nitrogen	(mg/L)	15	20
Total Phosphorus	(mg/L)	8	10
Ammonia	(mg/L)	2	5

See Note 1

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Point 1 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)										
Sample Frequency	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	Special Frequency 2*	6 Times Per Year	6 Times Per Year	6 Times Per Year	
Sampling Method	Composite Sample	Grab Sample	Grab Sample	Composite Sample	Grab Sample	Grab Sample	Composite Sample	Composite Sample	Grab Sample	Obtained Date
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Chlorophyll a (mg/m3)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)	
22-Mar-22	<2	<5	7.40	<2	6.40	47	7.07	3.46	0.69	31-Mar-22
100 Percentile Exceedance?	NO	NO	NO	NO	NO	NO	NO	NO	NO	

* Special Frequency 2: at least weekly during the months of November, December, January, February and March

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)										
Year to Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Chlorophyll a (mg/m3)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)	
Samples	13	13	13	13	13	13	13	13	13	
Min	<2	<5	7.20	<2	0.60	2	4.30	2.800	0.04	
Mean	1.38	2.50	7.80	3.31	4.10	193	8.22	4.974	0.27	
Median (50th %ile)	1.00	2.50	7.60	1.00	2.80	60	8.40	4.780	0.12	
90th %ile	2.00	2.50	8.80	8.80	7.82	640	12.12	6.452	0.66	
Max (100th %ile)	3.00	<5	9.60	10.00	10.90	760	12.80	9.440	1.22	

Narooma Sewage Treatment Plant - Monthly Result Summary - March 2022

Licensee: Eurobodalla Shire Council
 EPL No.: 1398
 Premises: Narooma Sewage Treatment Plant
 Address: Lakeside Drive, Narooma, NSW 2546



Anniversary Date: 1-Apr-21
 Published Date: 23-May-22

Licence Period: 01-Apr-21 to 31-Mar-22

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOlicence.aspx?DOCID=206031&SYSUID=1&LICID=1398>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Licence Point 2 - Influent Volume Monitoring			
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	20000
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall (mm)	Plant Inflow (kL)	Exceedance (YES/NO)
1-Mar-22	4.4	3270.0	NO
2-Mar-22	16.4	8780.0	NO
3-Mar-22	38.2	8370.0	NO
4-Mar-22	18	5430.0	NO
5-Mar-22	0	3530.0	NO
6-Mar-22	25.4	7860.0	NO
7-Mar-22	21.4	10050.0	NO
8-Mar-22	50	11130.0	NO
9-Mar-22	87.6	7150.0	NO
10-Mar-22	2.4	4170.0	NO
11-Mar-22	0	3060.0	NO
12-Mar-22	0	2210.0	NO
13-Mar-22	1.6	2120.0	NO
14-Mar-22	0.2	2010.0	NO
15-Mar-22	0	1990.0	NO
16-Mar-22	4.8	1870.0	NO
17-Mar-22	3.4	1770.0	NO
18-Mar-22	0	1790.0	NO
19-Mar-22	0	3120.0	NO
20-Mar-22	15.4	2120.0	NO
21-Mar-22	0	1860.0	NO
22-Mar-22	0	1750.0	NO
23-Mar-22	0	1890.0	NO
24-Mar-22	6.2	1770.0	NO
25-Mar-22	0	1700.0	NO
26-Mar-22	0	1770.0	NO
27-Mar-22	0.8	2200.0	NO
28-Mar-22	6.4	1800.0	NO
29-Mar-22	0	1980.0	NO
30-Mar-22	0.2	2950.0	NO
31-Mar-22	8.4	2700.0	NO
Monthly Total	311.20	114170.00	
Monthly Minimum	0.00	1700.00	
Monthly Mean	10.04	3682.90	
Monthly Maximum	87.60	11130.00	
Year to Date Total	1275.66	793122.01	
Year to Date Minimum	0.00	1290.00	
Year to Date Mean	3.50	2172.94	
Year to Date Maximum	87.60	11130.00	

Narooma Sewage Treatment Plant - Monthly Result Summary - March 2022

Licensee: Eurobodalla Shire Council
 EPL No.: 1398
 Premises: Narooma Sewage Treatment Plant
 Address: Lakeside Drive, Narooma, NSW 2546
 Licence Period: 01-Apr-21 to 31-Mar-22
 EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewFOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398>
 POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-21
 Published Date: 23-May-22

Licence Point 4 - Ambient Water Monitoring (Monthly Result)		
Frequency	Special Frequency 2*	
Sampling Method	Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
1-Mar-22	920	4-Mar-22
8-Mar-22	420	18-Mar-22
15-Mar-22	4	19-Mar-22
22-Mar-22	23	31-Mar-22
29-Mar-22	2	2-Apr-22

Licence Point 5 - Ambient Water Monitoring (Monthly Result)		
Frequency	Special Frequency 2*	
Sampling Method	Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
1-Mar-22	<1	4-Mar-22
8-Mar-22	310	18-Mar-22
15-Mar-22	6	19-Mar-22
22-Mar-22	3	31-Mar-22
29-Mar-22	25	2-Apr-22

* Special Frequency 2: at least weekly during the months of November, December, January, February and March

Licence Point 4 - Ambient Water Monitoring (Year to Date Results)	
Year to Date	Faecal Coliforms (CFU/100mL)
Samples	22
Min	<1
Mean	332.68
Median (50th %ile)	12
90th %ile	12
Max (100th %ile)	5600

Licence Point 5 - Ambient Water Monitoring (Year to Date Results)	
Year to Date	Faecal Coliforms (CFU/100mL)
Samples	22
Min	<1
Mean	447.68
Median (50th %ile)	4
90th %ile	4
Max (100th %ile)	7900

Monthly Exceedance Report			
Date	Exceedance Type	Parameter	Description / Action

Narooma Sewage Treatment Plant - Monthly Result Summary - March 2022

Licensee: Eurobodalla Shire Council
EPL No.: 1398
Premises: Narooma Sewage Treatment Plant
Address: Lakeside Drive, Narooma, NSW 2546
Licence Period: 01-Apr-21 to 31-Mar-22
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewFOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-21
Published Date: 23-May-22

EPA Licence Point Map

