

Licensee: Eurobodalla Shire Council EPL No.: 1398 Premises: Narooma Sewage Treatment Plant Address: Lakeside Drive, Narooma, NSW 2546 Licence Period: 01-Apr-24 to 31-Mar-25 EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398 POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Required Month: Jun-24

Licene	ce Point 1 - Discharge to Wate	ers - Point 1 Concentration Lin	nits	
Parameters	Unit of Measure	90 percentile concentration limit	100 percentile concentration limit	
Biological Oxygen Demand	(mg/L)	10	15	
Oil and Grease	(mg/L)	5	10	See Note
pН	(pH Units)	-	6.5-8.5	
Total Suspended Solids	(mg/L)	15	25	
Chlorophyll a	(mg/m3)			
Faecal Coliforms	(CFU/100mL)	200	600	
Total Nitrogen	(mg/L)	15	20	
Total Phosphorus	(mg/L)	8	10	
Ammonia	(mg/L)	2	5	

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Point 1 as described in Condition L3.

	Licence Point 3 - Effluent Quality Monitoring (Monthly Results)								
Sample Frequency	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	
Sampling Method	Composite Sample	Grab Sample	Grab Sample	Composite Sample	Grab Sample	Composite Sample	Composite Sample	Grab Sample	
Sampled Date	Biological Oxygen Demand	Oil and Grease	рН	Total Suspended Solids	Chlorophyll a	Total Nitrogen	Total Phosphorus	Ammonia	Obtained Date
Sampled Date	(mg/L)	(mg/L)	(pH Units)	(mg/L)	(mg/m3)	(mg/L)	(mg/L)	(mg/L)	obtailled Date
11-Jun-24	2.00	<5	7.40	2.00	3.60	7.27	4.50	1.02	22-Jun-24
100 Percentile Exceedance?	NO	NO	NO	NO	NO	NO	NO	NO	

	Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)							
Year to Date	Biological Oxygen Demand	Oil and Grease	рН	Total Suspended Solids	Chlorophyll a	Total Nitrogen	Total Phosphorus	Ammonia
Tear to Date	(mg/L)	(mg/L)	(pH Units)	(mg/L)	(mg/m3)	(mg/L)	(mg/L)	(mg/L)
Samples	3	3	3	3	3	3	3	3
Min	<2	<5	7.10	2.00	2.60	7.27	3.660	0.78
Mean	1.33	2.50	7.30	6.67	3.30	8.86	4.340	1.21
Median (50th %ile)	1.00	2.50	7.40	8.00	3.60	7.81	4.500	1.02
90th %ile	1.80	2.50	7.40	9.60	3.68	10.76	4.788	1.68
Max (100th %ile)	2.00	<5	7.40	10.00	3.70	11.50	4.860	1.84

Licensee: Eurobodalla Shire Council

EPL No.: 1398

Premises: Narooma Sewage Treatment Plant

Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-24

to EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398

31-Mar-25

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Licence Point 2 - Influent Volume Monitoring				
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	20000	
Sampling Method	Ultrasonic Flow Meter			
Sample Date	Rainfall	Plant Inflow	Exceedance	
	(mm)	(kL)	(YES/NO)	
1-Jun-24	0	1329.6	NO	
2-Jun-24	0	1324.1	NO	
3-Jun-24	11.6	1547.7	NO	
4-Jun-24	0	1484.6	NO	
5-Jun-24	0	1347.8	NO	
6-Jun-24	23	1960.4	NO	
7-Jun-24	45.4	5984.9	NO	
8-Jun-24	0.2	4373.9	NO	
9-Jun-24	8	2654.8	NO	
10-Jun-24	0.4	2489.3	NO	
11-Jun-24	0.6	2219.8	NO	
12-Jun-24	2	1889.0	NO	
13-Jun-24	0	2614.0	NO	
14-Jun-24	10.5	2109.8	NO	
15-Jun-24	1.6	2317.3	NO	
16-Jun-24	0	1948.4	NO	
17-Jun-24	0	1674.4	NO	
18-Jun-24	0	1569.5	NO	
19-Jun-24	0	1549.3	NO	
20-Jun-24	0	1525.1	NO	
21-Jun-24	0	1510.0	NO	
22-Jun-24	0	1403.0	NO	
23-Jun-24	0	1423.4	NO	
24-Jun-24	0.2	1496.1	NO	
25-Jun-24	0	1431.0	NO	
26-Jun-24	0	1391.9	NO	
27-Jun-24	0	1407.1	NO	
28-Jun-24	0	1441.2	NO	
29-Jun-24	0	1412.1	NO	
30-Jun-24	2.6	1402.0	NO	
Monthly Total	106.10	58231.19		
Monthly Minimum	0.00	1324.06		
Monthly Mean	3.54	1941.04		
Monthly Maximum	45.40	5984.94		
Year to Date Total	463.10	203755.97		
ear to Date Minimum	0.00	1317.28		
Year to Date Mean	5.09	2239.08		
ear to Date Maximum	80.60	10775.24		



1-Apr-24 9-Jul-24

Licensee: Eurobodalla Shire Council

EPL No.: 1398

Premises: Narooma Sewage Treatment Plant

Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-24 to 31-Mar-25

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398
POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

to rubic negister. <u>meps//apps.epa.nsw.gov.au/prpocoapp/</u>

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)			
Frequency	Special Frequency 2*		
Sampling Method	Grab Sample		
Sampled Date	Faecal Coliforms	Obtained Date	
Sampled Date	(CFU/100mL)	Obtained Date	
	1		
	1		

Licence Point 4 - Ambient Water Monitoring (Monthly Results)			
Frequency	Special Frequency 2*		
Sampling Method	Grab Sample		
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date	

	Licence Point 5 - Ambient Water Monitoring (Monthly Results)				
Frequency	Special Frequency 2*				
Sampling Method	Grab Sample				
Sampled Date	Faecal Coliforms	Obtained Date			
Sampled Date	(CFU/100mL)	Obtailled Date			
	1				
	1				
	1				

Anniversary Date:

Published Date:

1-Apr-24

9-Jul-24

eurobodalla shire council

* Special Frequency 2: at least weekly during the months of November, December, January, February and March

Licence Point 3 - Effluent Quality Monitoring (Year to Date Results)		
Year to Date	Faecal Coliforms	
fear to Date	(CFU/100mL)	
Samples		
Min		
Mean		
Median (50th %ile)		
90th %ile		
Max (100th %ile)		

Licence Point 4 - Ambient Water Monitoring (Year to Date Results)			
Year to Date	Faecal Coliforms		
Year to Date	(CFU/100mL)		
Samples			
Min			
Mean			
Median (50th %ile)			
90th %ile			
Max (100th %ile)	4		

Licence Point 5 - Ambient Water Monitoring (Year to Date Results)			
Year to Date	Faecal Coliforms		
	(CFU/100mL)		
Samples			
Min			
Mean			
Median (50th %ile)			
90th %ile			
Max (100th %ile)			

	Monthly Exceedance Report			
	Date	Exceedance Type	Parameter	Description / Action
1				

eurobodalla shire council

Anniversary Date:

Published Date:

1-Apr-24

9-Jul-24

 Licensee:
 Eurobodalla Shire Council

 EPL No.:
 1398

 Premises:
 Naroana Sewage Treatment Plant

 Address:
 Lakeside Drive, Narooma, NSW 2546

 Licence Period:
 01-Apr-24
 to
 31-Mar-25

 EPL Link:
 https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398

 POEO Public Register:
 https://apps.epa.nsw.gov.au/prpoeoapp/

