

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - June 2025



Anniversary Date: 1-Apr-25
Published Date: 3-Jul-25

Licensee: Eurobodalla Shire Council
EPL No.: 1397
Premises: Batemans Bay Sewage Treatment Plant
Address: George Bass Drive, Batemans Bay, NSW 2536
Licence Period: 1-Apr-25 to 31-Mar-26
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: Jun-25

Licence Point 1 - Discharge to Waters - Point 1 Concentration Limits			
Parameters	Unit of Measure	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	15
Oil and Grease	(mg/L)	5	10
pH	(pH Units)	-	6.5-8.5
Total Suspended Solids	(mg/L)	15	20
Faecal Coliforms	(CFU/100mL)	200	600
Total Nitrogen	(mg/L)	10	15
Total Phosphorus	(mg/L)	5	8
Ammonia	(mg/L)	2	5

See Note 1

Note 1: A 100 Percentile Concentration Limit of “10 mg/L and no visible oil and grease” applies for Point 1.
Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Point 1 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)									
Sample Frequency	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	
Sampling Method	Composite Sample	Grab Sample	Grab Sample	Composite Sample	Grab Sample	Composite Sample	Composite Sample	Grab Sample	
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)	Obtained Date
10-Jun-25	4.00	<5	7.10	3.00	1	8.26	2.86	0.01	19-Jun-25
100 Percentile Exceedance?	NO	NO	NO	NO	NO	NO	NO	NO	

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)								
Year to Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)
Samples	3	3	3	3	3	3	3	3
Min	4.00	<5	7.10	3.00	1	1.46	2.57	<0.01
Mean	5.33	2.50	7.13	3.33	6	4.30	3.02	0.007
Median (50th %ile)	6.00	2.50	7.10	3.00	2	3.18	2.86	0.005
90th %ile	6.00	2.50	7.18	3.80	12	7.24	3.48	0.009
Max (100th %ile)	6.00	<5	7.20	4.00	14	8.26	3.64	0.01

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - June 2025

Licensee: Eurobodalla Shire Council
EPL No.: 1397
Premises: Batemans Bay Sewage Treatment Plant
Address: George Bass Drive, Batemans Bay, NSW 2536
Licence Period: 1-Apr-25 to 31-Mar-26
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25
Published Date: 3-Jul-25

Licence Point 2 - Influent Volume Monitoring			
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	26565
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall (mm)	Plant Inflow (kL)	Exceedance (YES/NO)
1-Jun-25	0	5585	NO
2-Jun-25	0	5543	NO
3-Jun-25	0	5521	NO
4-Jun-25	0	5224	NO
5-Jun-25	0	5154	NO
6-Jun-25	0	5470	NO
7-Jun-25	0	5038	NO
8-Jun-25	0	5276	NO
9-Jun-25	1	5288	NO
10-Jun-25	4.5	5204	NO
11-Jun-25	0	5087	NO
12-Jun-25	0	4959	NO
13-Jun-25	0	4897	NO
14-Jun-25	7.5	5316	NO
15-Jun-25	0.5	5405	NO
16-Jun-25	0	5037	NO
17-Jun-25	0	5044	NO
18-Jun-25	0	4927	NO
19-Jun-25	0	5706	NO
20-Jun-25	0	6429	NO
21-Jun-25	0	5053	NO
22-Jun-25	0	4733	NO
23-Jun-25	0	4759	NO
24-Jun-25	0	4663	NO
25-Jun-25	0	4631	NO
26-Jun-25	0	4710	NO
27-Jun-25	0	4524	NO
28-Jun-25	0	4648	NO
29-Jun-25	0	4715	NO
30-Jun-25	0	4914	NO
Monthly Total	13.5	153460	
Monthly Minimum	0	4524	
Monthly Mean	0.45	5115.33	
Monthly Maximum	7.5	6429	
Year to Date Total	233	511978	
Year to Date Minimum	0	4394	
Year to Date Mean	2.56	5626.13	
Year to Date Maximum	31	11199	

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - June 2025

Licensee: Eurobodalla Shire Council
EPL No.: 1397
Premises: Batemans Bay Sewage Treatment Plant
Address: George Bass Drive, Batemans Bay, NSW 2536
Licence Period: 1-Apr-25 to 31-Mar-26
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25
Published Date: 3-Jul-25

Licence Point 4 - Ambient Water Monitoring (Monthly Result)		
Frequency Sampling Method	Monthly Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
10-Jun-25	<1	19-Jun-25

Licence Point 4 - Ambient Water Monitoring (Year to Date Results)	
Year to Date	Faecal Coliforms (CFU/100mL)
Samples	3
Min	<1
Mean	3.00
Median (50th %ile)	0.00
90th %ile	7.20
Max (100th %ile)	9

Licence Point 5 - Ambient Water Monitoring (Monthly Result)		
Frequency Sampling Method	Monthly Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
10-Jun-25	<1	19-Jun-25

Licence Point 5 - Ambient Water Monitoring (Year To Date Results)	
Year to Date	Faecal Coliforms (CFU/100mL)
Samples	3
Min	<1
Mean	0.00
Median (50th %ile)	0.00
90th %ile	0.00
Max (100th %ile)	<1

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - June 2025

Licensee: Eurobodalla Shire Council
EPL No.: 1397
Premises: Batemans Bay Sewage Treatment Plant
Address: George Bass Drive, Batemans Bay, NSW 2536
Licence Period: 1-Apr-25 to 31-Mar-26
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25
Published Date: 3-Jul-25

Monthly Exceedance Report			
Date	Exceedance Type	Parameter	Description / Action

Batemans Bay STP EPA Licence Point Map

