

Moruya Sewage Treatment Plant - Monthly Result Summary - May 2020



Licensee: Eurobodalla Shire Council
 EPL No.: 1614
 Premises: Moruya Sewage Treatment Plant
 Address: Queen Street, Moruya, NSW 2537

Anniversary Date: 01-Apr-20
 Published Date: 05-Jun-20

Licence Period: 01-Apr-20 to 31-Mar-21

EPL Link: <http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=28981&SYSUID=1&LICID=1614>

POEO Public Register: <http://www.environment.nsw.gov.au/prpoeoapp/default.aspx>

Required Month: May-20

Licence Point / Type of Point: Licence Point 6 - Discharge to Utilisation Area

Parameters	Unit of Measure	50 percentile concentration limit	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	-	20
Oil and Grease	(mg/L)	-	-	10
Total Nitrogen	(mg/L)	-	15	-
Total Phosphorus	(mg/L)	-	1	-
Total Suspended Solids	(mg/L)	20	-	30

See Note 1

Licence Point/Type of Point Licence Point 11 - Discharge to Waters

Parameters	Unit of Measure	50 percentile concentration limit	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	-	20
Oil and Grease	(mg/L)	-	-	10
Total Nitrogen	(mg/L)	-	15	-
Total Phosphorus	(mg/L)	-	1	-
Total Suspended Solids	(mg/L)	20	-	30

See Note 1

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 11 and Point 6.

Note 2: The monitoring at Point 3 required by condition M2.1 is conducted by the licensee to determine compliance with limits specified for discharges to Point 11 and 6 as described in condition L3.

Licence Point / Type of Point: Licence Point 3 - Effluent Quality Monitoring

Sample Frequency	Monthly	Special Frequency 1	Monthly	Monthly	Monthly	Monthly	
Sampling Method	Composite	Grab	Grab	Composite	Composite	Composite	
Parameters	Biological Oxygen Demand	Chlorophyll a	Oil and Grease	Total Nitrogen	Total Phosphorus	Total Suspended Solids	
Unit of Measure	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	
Sample Date							Obtained Date
19-May-20	<2	0.002	<5	4.75	0.176	4	29/05/2020
Minimum Value	<2	0.002	<3	4.75	0.176	4	
Maximum Value	<2	0.002	<3	4.75	0.176	4	

Note 1: Special Frequency 1 means collect and store sample monthly, at the same time as Biochemical Oxygen Demand or Total Suspended Solids sampling. If the Biochemical Oxygen Demand or Total Suspended Solids 100 percentile concentration limit is exceeded as per condition L3.3, then analyse the

Note 2: For the purpose of this licence, a composite sample is defined as at least three grab samples forming a pooled sample, with the first and last samples taken at least seven hours apart.

100 Percentile - Licence Condition

Sample Date	Biological Oxygen Demand			Oil and Grease			Total Suspended Solids		
	Measurement	Actual 100 Percentile to Sample Date	Exceedance	Measurement	Actual 100 Percentile to Sample Date	Exceedance	Measurement	Actual 100 Percentile to Sample Date	Exceedance
19-May-20	<2	2	NO	<5	10	NO	4/01/1900	4	NO

Moruya Sewage Treatment Plant - Monthly Result Summary - May 2020

Licensee: Eurobodalla Shire Council
 EPL No.: 1614
 Premises: Moruya Sewage Treatment Plant
 Address: Queen Street, Moruya, NSW 2537

Licence Period: 01-Apr-20 to 31-Mar-21

EPL Link: <http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=28981&SYSUID=1&LICID=1614>

POEO Public Register: <http://www.environment.nsw.gov.au/prpoeoapp/default.aspx>



Anniversary Date: 01-Apr-20
 Published Date: 05-Jun-20

Licence Point / Type of Point: Licence Point 7 - Ambient Water Monitoring			
Sample Frequency	Monthly	Monthly	
Sampling Method	Grab	Grab	
Parameters	Total Nitrogen	Total Phosphorus	
Unit of Measure	(mg/L)	(mg/L)	
Sample Date			Obtained Date
19-May-20	2.7	0.022	29-May-20

Licence Point / Type of Point: Licence Point 9 - Ambient Water Monitoring			
Sample Frequency	Monthly	Monthly	
Sampling Method	Grab	Grab	
Parameters	Total Nitrogen	Total Phosphorus	
Unit of Measure	(mg/L)	(mg/L)	
Sample Date			Obtained Date
19-May-20	0.2	0.01	29-May-20

Licence Point / Type of Point: Licence Point 8 - Ambient Water Monitoring			
Sample Frequency	Monthly	Monthly	
Sampling Method	Grab	Grab	
Parameters	Total Nitrogen	Total Phosphorus	
Unit of Measure	(mg/L)	(mg/L)	
Sample Date			Obtained Date
19-May-20	2.3	0.015	29-May-20

Licence Point / Type of Point: Licence Point 10 - Ambient Water Monitoring			
Sample Frequency	Monthly	Monthly	
Sampling Method	Grab	Grab	
Parameters	Total Nitrogen	Total Phosphorus	
Unit of Measure	(mg/L)	(mg/L)	
Sample Date			Obtained Date
19-May-20	0.3	0.01	29-May-20

Moruya Sewage Treatment Plant - Monthly Result Summary - May 2020

Licensee: Eurobodalla Shire Council
 EPL No.: 1614
 Premises: Moruya Sewage Treatment Plant
 Address: Queen Street, Moruya, NSW 2537
 Licence Period: 01-Apr-20 to 31-Mar-21
 EPL Link: <http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=28981&SYSUID=1&LICID=1614>
 POEO Public Register: <http://www.environment.nsw.gov.au/prpoeoapp/default.aspx>



Anniversary Date: 01-Apr-20
 Published Date: 05-Jun-20

Licence Point / Type of Point: Licence Point 2 - Influent Volume Monitoring			
Sample Frequency	Daily (Continuous)	Maximum Daily Flow (kL)	14000
Sampling Method	Ultrasonic Flow Meter		
Parameters	Rainfall	Flow	Exceedance
Unit of Measure	(mm)	(kL)	(YES/NO)
Sample Date			
1-May-20	0	482	NO
2-May-20	0	484	NO
3-May-20	0	490	NO
4-May-20	0	521	NO
5-May-20	0	563	NO
6-May-20	0	589	NO
7-May-20	0	556	NO
8-May-20	0	507	NO
9-May-20	0	482	NO
10-May-20	0	455	NO
11-May-20	0	483	NO
12-May-20	0	493	NO
13-May-20	5.8	512	NO
14-May-20	0	528	NO
15-May-20	0	527	NO
16-May-20	0	471	NO
17-May-20	0	453	NO
18-May-20	0	472	NO
19-May-20	0	481	NO
20-May-20	0	472	NO
21-May-20	0	462	NO
22-May-20	0	472	NO
23-May-20	0	442	NO
24-May-20	0	465	NO
25-May-20	0.2	474	NO
26-May-20	0.4	450	NO
27-May-20	0	464	NO
28-May-20	0	501	NO
29-May-20	0	454	NO
30-May-20	0	442	NO
31-May-20	0	453	NO
Monthly Total	6	15100	
Monthly Minimum	0	442	
Monthly Maximum	6	589	

Moruya Sewage Treatment Plant - Monthly Result Summary - May 2020

Licensee: Eurobodalla Shire Council
EPL No.: 1614
Premises: Moruya Sewage Treatment Plant
Address: Queen Street, Moruya, NSW 2537

Licence Period: 01-Apr-20 to 31-Mar-21

EPL Link: <http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=28981&SYSUID=1&LICID=1614>

POEO Public Register: <http://www.environment.nsw.gov.au/prpoeoapp/default.aspx>



Anniversary Date: 01-Apr-20
Published Date: 05-Jun-20

Exceedance Report

Date	Exceedance Type	Parameter	Description / Action

Moruya Sewage Treatment Plant - Monthly Result Summary - May 2020

Licensee: Eurobodalla Shire Council
EPL No.: 1614
Premises: Moruya Sewage Treatment Plant
Address: Queen Street, Moruya, NSW 2537

Licence Period: 01-Apr-20 to 31-Mar-21

EPL Link: <http://www.environment.nsw.gov.au/prpoeapp/ViewPOEOLicence.aspx?DOCID=28981&SYSUID=1&LICID=1614>

POEO Public Register: <http://www.environment.nsw.gov.au/prpoeapp/default.aspx>



Anniversary Date: 01-Apr-20
Published Date: 05-Jun-20

