Anniversary Date: 01-Apr-20

06-Nov-20

Published Date:



Licensee: Eurobodalla Shire Council EPL No.: 3108

Premises: Tuross Sewage Treatment Plant Address: 217 Kelly Road, Bingie, NSW 2537

31-Mar-21 Licence Period: 01-Apr-20

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Required Month:

Licence Point / Type of Point:	Licence Point 1 - Discharge to Waters			
Parameters	Unit of Measure	50 percentile	100 percentile	
raiailleteis	Offic of Measure	concentration limit	concentration limit	
Biological Oxygen Demand	(mg/L)	15	20	
Oil and Grease	(mg/L)	-	10	S
Total Suspended Solids	(ma/L)	20	30	

Licence Point/Type of Point	Licence Point 4 - Discharge to Utili	isation Area		
Parameters	Unit of Measure	50 percentile concentration limit	100 percentile concentration limit	
Biological Oxygen Demand	(mg/L)	15	20	
Oil and Grease	(mg/L)	-	10	See No
Total Suspended Solids	(mg/L)	20	30	

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Point 1 as described in Condition L3.

Licence Point / Type of Point:	Licence Point 3 - Effluent Quality Mor	nitoring				
Sample Frequency	Monthly	Monthly	Monthly	Monthly	Monthly	
Sampling Method	Composite	Grab	Composite	Composite	Composite	
Parameters	Biological Oxygen Demand	Oil and Grease	Total Nitrogen	Total Phosphorus	Total Suspended Solids	
Unit of Measure	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	
Sample Date						Obtained Date
06-Oct-20	16	<10	11.9	0.91	25	16-Oct-20
Minimuim Value	16	<10	11.9	0.91	25	
Maximum Value	16	<10	11.9	0.91	25	

Licence Condition - 100 Percentile									
\ <u></u>	Biological Oxygen Demand			Oil and Grease			Total Suspended Solids		
Sample Date	Measurement	Actual 100 Percentile	Exceedance	Measurement	Actual 100 Percentile	Exceedance	Measurement	Actual 100 Percentile	Exceedance
Sample Date	Wedstrement	to Sample Date	to Sample Date	Wicasar Ciricit	to Sample Date	Execedance	Wedsarement	to Sample Date	Execcuance
06-Oct-20	16	16	NO	<10	10	NO	25	25	NO

Note: For the purpose of this licence, a composite sample is defined as at least three grab samples forming a pooled sample, with the first and last samples taken at least seven hours apart.

Licensee: Eurobodalla Shire Council EPL No.: 3108

Premises: Tuross Sewage Treatment Plant Address: 217 Kelly Road, Bingie, NSW 2537

Licence Period: 01-Apr-20 to 31-Mar-21

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Licence Point / Type of Point:	Licence Point 2 - Influent Volume M	onitoring	
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	7000
Sampling Method	Ultrasonic Flow Meter		
Parameters	Rainfall	Flow	Exceedance
Unit of Measure	(mm)	(kL)	(YES/NO)
Sample Date			
1-Oct-20	0	468.8	NO
2-Oct-20	0	529.8	NO
3-Oct-20	0	584.7	NO
4-Oct-20	0	622.6	NO
5-Oct-20	0	537.4	NO
6-Oct-20	5.6	408.6	NO
7-Oct-20	17.6	489.5	NO
8-Oct-20	7.8	548.0	NO
9-Oct-20	0	499.7	NO
10-Oct-20	0	476.2	NO
11-Oct-20	0	407.8	NO
12-Oct-20	0	387.6	NO
13-Oct-20	0.2	383.7	NO
14-Oct-20	1.6	357.3	NO
15-Oct-20	2.6	424.4	NO
16-Oct-20	5	388.7	NO
17-Oct-20	10.8	468.2	NO
18-Oct-20	1.8	480.2	NO
19-Oct-20	0	411.5	NO
20-Oct-20	0	385.9	NO
21-Oct-20	0	386.5	NO
22-Oct-20	0	382.6	NO
23-Oct-20	0	439.9	NO
24-Oct-20	8	426.8	NO
25-Oct-20	9.6	449.9	NO
26-Oct-20	16.2	584.9	NO
27-Oct-20	0	541.1	NO
28-Oct-20	0	511.2	NO
29-Oct-20	0	484.4	NO
30-Oct-20	2	443.5	NO
31-Oct-20	44.6	1073.8	NO
Monthly Total	133	14985	
Monthly Minimum	0	357	
Monthly Maximum	45	1074	



Anniversary Date: Published Date: 01-Apr-20 06-Nov-20

Licensee: Eurobodalla Shire Council EPL No.: 3108 Premises: Tuross Sewage Treatment Plant Address: 217 Kelly Road, Bingie, NSW 2537



Anniversary Date: 01-Apr-20 Published Date: 06-Nov-20

Licence Period: 01-Apr-20 to 31-Mar-21 EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108
POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

			Exceedance Report
Date	Exceedance Type	Parameter	Description / Action
			!
		ŧ	•

EPA License Point 2 - Influent volume monitoring EPA License Point 3 - Effluent quality monitoring

EPA Licence Point 4 - Discharge to Utilisation Area

Licensee: Eurobodalla Shire Council EPL No.:

Premises: Tuross Sewage Treatment Plant Address: 217 Kelly Road, Bingie, NSW 2537

31-Mar-21

Licence Period:



EPA Licence Point 1 - Discharge to Waters

eurobodalla shire council

LEGEND

Sewerage Treatment Plant Boundary ∇ EPA License Points Sewerage Treatment Plant Facility

Anniversary Date:

Published Date:

01-Apr-20

06-Nov-20