## Tuross Sewage Treatment Plant - Monthly Result Summary - May 2021





Required Month: May-21

Licence Point 1 (Disch	narge to Waters) and 4 (Discharg	ge to Utilisation Area) - Conce	ntration Limits	
Parameters	Unit of Measure	50 percentile concentration limit	100 percentile concentration limit	
Biological Oxygen Demand	(mg/L)	15	20	
Oil and Grease	(mg/L)		10	See No
Total Suspended Solids	(mg/L)	20	30	
Total Nitrogen	(mg/L)			
Total Phosphorus	(mg/L)			

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Points 1 and 4 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)						
Sample Frequency	Monthly	Monthly	Monthly	Monthly	Monthly	
Sampling Method	Composite Sample	Grab Sample	Composite Sample	Composite Sample	Composite Sample	
Sampled Date	Biological Oxygen Demand	Oil and Grease	Total Suspended Solids	Total Nitrogen	Total Phosphorus	Obtained Date
Sumplea bate	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	obtailieu bute
18-May-21	5.00	<5	13.00	18.30	4.44	28-May-21
100 Percentile Exceedance?	NO	NO	NO	NO	NO	

\* Special Frequency 2: at least weekly during the months of November, December, January, February and March

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)						
Year to Date	Biological Oxygen Demand	Oil and Grease	Total Suspended Solids	Total Nitrogen	Total Phosphorus	
fear to bate	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	
Total Samples	2	2	2	2	2	
Minimum Result	5.00	<5	13.00	13.50	4.44	
Mean Result	5.00	2.50	14.50	15.90	4.98	
Median Result	5.00	2.50	14.50	15.90	4.98	
Maximum Result	5.00	<5	16.00	18.30	5.52	

## Tuross Sewage Treatment Plant - Monthly Result Summary - May 2021

Licensee: Eurobodalla Shire Council

EPL No.: 3108

Premises: Tuross Sewage Treatment Plant

Address: 217 Kelly Road, Bingie, NSW, 2537

 Licence Period:
 01-Apr-21
 to
 31-Mar-22

 EPL Link:
 https://apps.epa.nsw.gov.au/proeeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108

 POEO Public Register:
 https://apps.epa.nsw.gov.au/proeeoapp/

	Licence Point 2 - Influent Volume Monitoring				
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	7000		
Sampling Method	Ultrasonic Flow Meter				
Sample Date	Rainfall	Plant Inflow	Exceedance		
sample sate	(mm)	(kL)	(YES/NO)		
1-May-21	0.2	403.1	NO		
2-May-21	0	394.4	NO		
3-May-21	8.4	376.0	NO		
4-May-21	43.2	481.9	NO		
5-May-21	37.2	1162.4	NO		
6-May-21	15.8	1353.0	NO		
7-May-21	28.6	1730.1	NO		
8-May-21	0.2	995.3	NO		
9-May-21	0	694.4	NO		
10-May-21	0.2	585.8	NO		
11-May-21	1.6	490.4	NO		
12-May-21	0	467.7	NO		
13-May-21	0	449.6	NO		
14-May-21	0	423.5	NO		
15-May-21	0	430.9	NO		
16-May-21	0	436.9	NO		
17-May-21	0	387.9	NO		
18-May-21	0	363.4	NO		
19-May-21	0	366.7	NO		
20-May-21	0	369.9	NO		
21-May-21	0	384.0	NO		
22-May-21	0	405.5	NO		
23-May-21	0.4	386.8	NO		
24-May-21	0.8	369.3	NO		
25-May-21	0.2	364.1	NO		
26-May-21	0	359.8	NO		
27-May-21	0	364.8	NO		
28-May-21	0	360.3	NO		
29-May-21	0	402.5	NO		
30-May-21	0	413.2	NO		
31-May-21	0	388.3	NO		
Monthly Total	136.8	16561.9			
Monthly Minimum	0	359.8			
Monthly Mean	4.41	534.25			
Monthly Maximum	43.2	1730.1			
Year to Date Total	144.2	30285.0			
Year to Date Minimum	0	342.6			
Year to Date Mean	2.36	496.48			
Year to Date Maximum	43.2	1730.1			



## Tuross Sewage Treatment Plant - Monthly Result Summary - May 2021



Monthly Exceedance Report			
Date	Exceedance Type	Parameter	Description / Action

## **EPA Licence Point Map**

