

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - March 2024



Anniversary Date: 1-Apr-23
Published Date: 10-Apr-24

Licensee: Eurobodalla Shire Council
EPL No.: 1397
Premises: Batemans Bay Sewage Treatment Plant
Address: George Bass Drive, Batemans Bay, NSW 2536
Licence Period: 1-Apr-23 to 31-Mar-24
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: Mar-24

Licence Point 1 - Discharge to Waters - Point 1 Concentration Limits			
Parameters	Unit of Measure	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	15
Oil and Grease	(mg/L)	5	10
pH	(pH Units)	-	6.5-8.5
Total Suspended Solids	(mg/L)	15	20
Faecal Coliforms	(CFU/100mL)	200	600
Total Nitrogen	(mg/L)	10	15
Total Phosphorus	(mg/L)	5	8
Ammonia	(mg/L)	2	5

See Note 1

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Point 1 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)									
Sample Frequency Sampling Method	Monthly Composite Sample	Monthly Grab Sample	Monthly Grab Sample	Monthly Composite Sample	Monthly Grab Sample	Monthly Composite Sample	Monthly Composite Sample	Monthly Grab Sample	Obtained Date
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)	
19-Mar-24	<2	<5	7.30	<2	7	4.92	2.48	0.03	3-Apr-24
100 Percentile Exceedance?	NO	NO	NO	NO	NO	NO	NO	NO	

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)								
Year to Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)
Samples	13	13	13	13	13	13	13	13
Min	<2	<5	7.10	<2	1	1.53	0.38	0.02
Mean	2.46	2.50	7.38	3.92	12061	8.14	2.36	1.72
Median (50th %ile)	1.00	2.50	7.40	4.00	990	4.99	2.44	0.20
90th %ile	4.00	2.50	7.58	6.00	25400	18.62	3.40	5.66
Max (100th %ile)	9.00	<5	7.70	11.00	78000	24.10	3.82	6.33

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - March 2024

Licensee: Eurobodalla Shire Council
 EPL No.: 1397
 Premises: Batemans Bay Sewage Treatment Plant
 Address: George Bass Drive, Batemans Bay, NSW 2536
 Licence Period: 1-Apr-23 to 31-Mar-24
 EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>
 POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-23
 Published Date: 10-Apr-24

Licence Point 2 - Influent Volume Monitoring

Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	26565
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall (mm)	Plant Inflow (kL)	Exceedance (YES/NO)
1-Mar-24	0	2874.0	NO
2-Mar-24	0	2860.0	NO
3-Mar-24	0	2962.0	NO
4-Mar-24	0	3061.0	NO
5-Mar-24	0	2942.0	NO
6-Mar-24	0	2832.0	NO
7-Mar-24	0	2832.0	NO
8-Mar-24	0	5758.0	NO
9-Mar-24	0	3017.0	NO
10-Mar-24	0	3327.0	NO
11-Mar-24	0	3437.0	NO
12-Mar-24	0	3154.0	NO
13-Mar-24	0	3044.0	NO
14-Mar-24	0	2929.0	NO
15-Mar-24	2	3004.0	NO
16-Mar-24	14	3085.0	NO
17-Mar-24	2	3043.0	NO
18-Mar-24	23.5	3220.0	NO
19-Mar-24	11	5603.0	NO
20-Mar-24	8.5	3942.0	NO
21-Mar-24	1.5	4632.0	NO
22-Mar-24	2	3962.0	NO
23-Mar-24	0	3409.0	NO
24-Mar-24	4.5	3422.0	NO
25-Mar-24	1	3734.0	NO
26-Mar-24	0	3249.0	NO
27-Mar-24	0	2924.0	NO
28-Mar-24	0	3289.0	NO
29-Mar-24	1.5	3104.0	NO
30-Mar-24	0	3592.0	NO
31-Mar-24	0	3863.0	NO
Monthly Total	71.5	106106.0	
Monthly Minimum	0	2832	
Monthly Mean	2.31	3422.77	
Monthly Maximum	23.5	5758	
Year to Date Total	781.5	1554220.6	
Year to Date Minimum	0	1743.6	
Year to Date Mean	2.14	4246.50	
Year to Date Maximum	67	10185	

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - March 2024

Licensee: Eurobodalla Shire Council

EPL No.: 1397

Premises: Batemans Bay Sewage Treatment Plant

Address: George Bass Drive, Batemans Bay, NSW 2536

Licence Period: 1-Apr-23 to 31-Mar-24

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-23

Published Date: 10-Apr-24

Licence Point 4 - Ambient Water Monitoring (Monthly Result)

Frequency	Monthly	
Sampling Method	Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
19-Mar-24	1	3-Apr-24

Licence Point 4 - Ambient Water Monitoring (Year to Date Results)

Year to Date	Faecal Coliforms (CFU/100mL)
Samples	13
Min	<1
Mean	6.62
Median (50th %ile)	1.00
90th %ile	5.60
Max (100th %ile)	70

Licence Point 5 - Ambient Water Monitoring (Monthly Result)

Frequency	Monthly	
Sampling Method	Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
19-Mar-24	1	3-Apr-24

Licence Point 5 - Ambient Water Monitoring (Year To Date Results)

Year to Date	Faecal Coliforms (CFU/100mL)
Samples	13
Min	<1
Mean	409.92
Median (50th %ile)	1.00
90th %ile	15.60
Max (100th %ile)	5300

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - March 2024

Licensee: Eurobodalla Shire Council
 EPL No.: 1397
 Premises: Batemans Bay Sewage Treatment Plant
 Address: George Bass Drive, Batemans Bay, NSW 2536
 Licence Period: 1-Apr-23 to 31-Mar-24
 EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>
 POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-23
 Published Date: 10-Apr-24

Monthly Exceedance Report

Date	Exceedance Type	Parameter	Description / Action

Batemans Bay STP EPA Licence Point Map

