

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - April 2023



Anniversary Date: 1-Apr-23
Published Date: 12-Jun-23

Licensee: Eurobodalla Shire Council
EPL No.: 1397
Premises: Batemans Bay Sewage Treatment Plant
Address: George Bass Drive, Batemans Bay, NSW 2536
Licence Period: 1-Apr-23 to 31-Mar-24
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: Apr-23

Licence Point 1 - Discharge to Waters - Point 1 Concentration Limits			
Parameters	Unit of Measure	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	15
Oil and Grease	(mg/L)	5	10
pH	(pH Units)	-	6.5-8.5
Total Suspended Solids	(mg/L)	15	20
Faecal Coliforms	(CFU/100mL)	200	600
Total Nitrogen	(mg/L)	10	15
Total Phosphorus	(mg/L)	5	8
Ammonia	(mg/L)	2	5

See Note 1

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Point 1 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)									
Sample Frequency	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	
Sampling Method	Composite Sample	Grab Sample	Grab Sample	Composite Sample	Grab Sample	Composite Sample	Composite Sample	Grab Sample	
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)	Obtained Date
18-Apr-23	<2	<5	7.60	5.00	720	3.66	2.58	0.11	28-Apr-23
100 Percentile Exceedance?	NO	NO	NO	NO	YES	NO	NO	NO	

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)								
Year to Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)
Samples	1	1	1	1	1	1	1	1
Min	<2	<5	7.60	5.00	720	3.66	2.58	0.11
Mean	1.00	2.50	7.60	5.00	720	3.66	2.58	0.11
Median (50th %ile)	1.00	2.50	7.60	5.00	720	3.66	2.58	0.11
90th %ile	1.00	2.50	7.60	5.00	720	3.66	2.58	0.11
Max (100th %ile)	<2	<5	7.60	5.00	720	3.66	2.58	0.11

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - April 2023

Licensee: Eurobodalla Shire Council
 EPL No.: 1397
 Premises: Batemans Bay Sewage Treatment Plant
 Address: George Bass Drive, Batemans Bay, NSW 2536
 Licence Period: 1-Apr-23 to 31-Mar-24
 EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>
 POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-23
 Published Date: 12-Jun-23

Licence Point 2 - Influent Volume Monitoring

Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	26565
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall (mm)	Plant Inflow (kL)	Exceedance (YES/NO)
1-Apr-22	0	4447.0	NO
2-Apr-22	6.5	5560.0	NO
3-Apr-22	0	5595.0	NO
4-Apr-22	0	5604.0	NO
5-Apr-22	1	4500.0	NO
6-Apr-22	0	3712.3	NO
7-Apr-22	0	4330.1	NO
8-Apr-22	15.5	6445.5	NO
9-Apr-22	0	5910.4	NO
10-Apr-22	0	4988.6	NO
11-Apr-22	0	4514.1	NO
12-Apr-22	0	3358.6	NO
13-Apr-22	8	4481.9	NO
14-Apr-22	25	8397.8	NO
15-Apr-22	6	6332.1	NO
16-Apr-22	1	3373.5	NO
17-Apr-22	0	2670.4	NO
18-Apr-22	0	3590.1	NO
19-Apr-22	0	4997.7	NO
20-Apr-22	0	4812.7	NO
21-Apr-22	0	4209.2	NO
22-Apr-22	0	5093.8	NO
23-Apr-22	0	4802.5	NO
24-Apr-22	0	4648.3	NO
25-Apr-22	0	4591.9	NO
26-Apr-22	0	4575.4	NO
27-Apr-22	0	3055.6	NO
28-Apr-22	0	3789.5	NO
29-Apr-22	9	3265.5	NO
30-Apr-22	24	3964.4	NO
Monthly Total	96	139617.9	
Monthly Minimum	0	2670.4	
Monthly Mean	3.20	4653.93	
Monthly Maximum	25	8397.8	
Year to Date Total	96	139617.9	
Year to Date Minimum	0	2670.4	
Year to Date Mean	3.20	4653.93	
Year to Date Maximum	25	8397.8	

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - April 2023

Licensee: Eurobodalla Shire Council

EPL No.: 1397

Premises: Batemans Bay Sewage Treatment Plant

Address: George Bass Drive, Batemans Bay, NSW 2536

Licence Period: 1-Apr-23 to 31-Mar-24

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-23

Published Date: 12-Jun-23

Licence Point 4 - Ambient Water Monitoring (Monthly Result)

Frequency	Monthly	
Sampling Method	Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
18-Apr-23	1	28-Apr-23

Licence Point 4 - Ambient Water Monitoring (Year to Date Results)

Year to Date	Faecal Coliforms (CFU/100mL)
Samples	1
Min	1.00
Mean	1.00
Median (50th %ile)	1.00
90th %ile	1.00
Max (100th %ile)	1.00

Licence Point 5 - Ambient Water Monitoring (Monthly Result)

Frequency	Monthly	
Sampling Method	Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
18-Apr-23	1	28-Apr-23

Licence Point 5 - Ambient Water Monitoring (Year To Date Results)

Year to Date	Faecal Coliforms (CFU/100mL)
Samples	1
Min	1.00
Mean	1.00
Median (50th %ile)	1.00
90th %ile	1.00
Max (100th %ile)	1.00

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - April 2023

Licensee: Eurobodalla Shire Council
 EPL No.: 1397
 Premises: Batemans Bay Sewage Treatment Plant
 Address: George Bass Drive, Batemans Bay, NSW 2536



Anniversary Date: 1-Apr-23
 Published Date: 12-Jun-23

Licence Period: 1-Apr-23 to 31-Mar-24

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Monthly Exceedance Report

Date	Exceedance Type	Parameter	Description / Action
18-Mar-23	Concentration Limit	Faecal Coliforms	Faecal Coliform result (720 CFU/100mL) exceeded 100 percentile concentration limit (600 CFU/100mL) at monitoring point 3.

Batemans Bay STP EPA Licence Point Map

