

Tuross Sewage Treatment Plant - Monthly Result Summary - October 2025



Anniversary Date: 1-Apr-25
Published Date: 6-Nov-25

Licensee: Eurobodalla Shire Council
EPL No.: 3108
Premises: Tuross Sewage Treatment Plant
Address: 217 Kelly Road, Bingie, NSW, 2537
Licence Period: 01-Apr-25 to 31-Mar-26
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: Oct-25

Licence Point 1 (Discharge to Waters) and 4 (Discharge to Utilisation Area) - Concentration Limits			
Parameters	Unit of Measure	50 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	15	20
Oil and Grease	(mg/L)		10
Total Suspended Solids	(mg/L)	20	30
Total Nitrogen	(mg/L)		
Total Phosphorus	(mg/L)		

See Note 1

Note 1: A 100 Percentile Concentration Limit of “10 mg/L and no visible oil and grease” applies for Point 1.
Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Points 1 and 4 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)						
Sample Frequency Sampling Method	Monthly Composite Sample	Monthly Grab Sample	Monthly Composite Sample	Monthly Composite Sample	Monthly Composite Sample	
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	Total Suspended Solids (mg/L)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Obtained Date
28-Oct-25	<2	<5	5.00	6.42	1.76	6-Nov-25
100 Percentile Exceedance?	NO	NO	NO	NO	NO	

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)					
Year to Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	Total Suspended Solids (mg/L)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples	8	8	8	8	8
Min	<2	<5	3.00	5.31	0.72
Mean	2.38	2.50	5.75	10.81	2.44
Median (50th %ile)	2.50	2.50	5.00	8.44	2.91
90th %ile	4.00	2.50	8.50	17.60	3.55
Max (100th %ile)	4.00	<5	12.00	26.00	3.56

Tuross Sewage Treatment Plant - Monthly Result Summary - October 2025

Licensee: Eurobodalla Shire Council

EPL No.: 3108

Premises: Tuross Sewage Treatment Plant

Address: 217 Kelly Road, Bingie, NSW, 2537

Licence Period: 01-Apr-25 to 31-Mar-26

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25

Published Date: 6-Nov-25

Licence Point 2 - Influent Volume Monitoring			
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	7000
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall (mm)	Plant Inflow (kL)	Exceedance (YES/NO)
1-Oct-25	0	467.9	NO
2-Oct-25	0	453.4	NO
3-Oct-25	0	511.0	NO
4-Oct-25	0	568.6	NO
5-Oct-25	0	586.6	NO
6-Oct-25	0	533.0	NO
7-Oct-25	0	485.3	NO
8-Oct-25	0	468.0	NO
9-Oct-25	0	435.2	NO
10-Oct-25	0	474.0	NO
11-Oct-25	0	479.7	NO
12-Oct-25	0	438.5	NO
13-Oct-25	0.2	409.0	NO
14-Oct-25	0	412.0	NO
15-Oct-25	0	397.0	NO
16-Oct-25	0	377.7	NO
17-Oct-25	0	389.0	NO
18-Oct-25	0	415.3	NO
19-Oct-25	0.4	405.0	NO
20-Oct-25	0	401.0	NO
21-Oct-25	0	358.0	NO
22-Oct-25	0	381.2	NO
23-Oct-25	0	394.1	NO
24-Oct-25	0.6	370.6	NO
25-Oct-25	0	443.6	NO
26-Oct-25	0.8	386.0	NO
27-Oct-25	1.8	400.5	NO
28-Oct-25	0.2	369.8	NO
29-Oct-25	0.2	372.7	NO
30-Oct-25	0.2	394.6	NO
31-Oct-25	31	449.8	NO
Monthly Total	35.4	13428.1	
Monthly Minimum	0	358	
Monthly Mean	1.14	433.16	
Monthly Maximum	31	586.6	
Year to Date Total	501.2	124525.85	
Year to Date Minimum	0	346.3	
Year to Date Mean	2.34	581.90	
Year to Date Maximum	85	3365.3	

Tuross Sewage Treatment Plant - Monthly Result Summary - October 2025

Licensee: Eurobodalla Shire Council
EPL No.: 3108
Premises: Tuross Sewage Treatment Plant
Address: 217 Kelly Road, Bingie, NSW, 2537
Licence Period: 01-Apr-25 to 31-Mar-26
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25
Published Date: 6-Nov-25

Monthly Exceedance Report				
Date	Exceedance Type	Parameter	Description / Action	

EPA Licence Point Map

