

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - July 2026



Anniversary Date: 1-Apr-25
Published Date: 12-Aug-26

Licensee: Eurobodalla Shire Council
EPL No.: 1397
Premises: Batemans Bay Sewage Treatment Plant
Address: George Bass Drive, Batemans Bay, NSW 2536
Licence Period: 1-Apr-26 to 31-Mar-27
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: Jul-26

Licence Point 1 - Discharge to Waters - Point 1 Concentration Limits			
Parameters	Unit of Measure	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	15
Oil and Grease	(mg/L)	5	10
pH	(pH Units)	-	6.5-8.5
Total Suspended Solids	(mg/L)	15	20
Faecal Coliforms	(CFU/100mL)	200	600
Total Nitrogen	(mg/L)	10	15
Total Phosphorus	(mg/L)	5	8
Ammonia	(mg/L)	2	5

See Note 1

Note 1: A 100 Percentile Concentration Limit of “10 mg/L and no visible oil and grease” applies for Point 1.
Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Point 1 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)									
Sample Frequency	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	
Sampling Method	Composite Sample	Grab Sample	Grab Sample	Composite Sample	Grab Sample	Composite Sample	Composite Sample	Grab Sample	
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)	Obtained Date
7-Jul-26	<2	<5	7.40	<2	3	6.45	3.69	0.01	16-Jul-26
100 Percentile Exceedance?	NO	NO	NO	NO	NO	NO	NO	NO	

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)								
Year to Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)
Samples	4	4	4	4	4	4	4	4
Min	<2	<5	7.20	<2	<1	2.65	3.69	<0.01
Mean	1.50	2.50	7.28	1.25	1	6.68	3.84	0.096
Median (50th %ile)	1.00	2.50	7.25	1.00	1	7.10	3.82	0.010
90th %ile	2.40	2.50	7.37	1.70	2	9.24	3.98	0.255
Max (100th %ile)	3.00	<5	7.40	2.00	3	9.88	4.04	0.36

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - July 2026

Licensee: Eurobodalla Shire Council
EPL No.: 1397
Premises: Batemans Bay Sewage Treatment Plant
Address: George Bass Drive, Batemans Bay, NSW 2536
Licence Period: 1-Apr-26 to 31-Mar-27
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25
Published Date: 12-Aug-26

Licence Point 2 - Influent Volume Monitoring			
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	26565
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall (mm)	Plant Inflow (kL)	Exceedance (YES/NO)
1-Jul-26	0	4636	NO
2-Jul-26	1.5	4539	NO
3-Jul-26	0	4725	NO
4-Jul-26	0	4596	NO
5-Jul-26	0	4711	NO
6-Jul-26	0	4605	NO
7-Jul-26	0	4529	NO
8-Jul-26	0	4621	NO
9-Jul-26	5.5	4731	NO
10-Jul-26	0.5	4988	NO
11-Jul-26	0	4840	NO
12-Jul-26	0.5	4818	NO
13-Jul-26	0	4790	NO
14-Jul-26	0	4603	NO
15-Jul-26	0	4478	NO
16-Jul-26	0	4509	NO
17-Jul-26	0	4590	NO
18-Jul-26	0	4519	NO
19-Jul-26	0	4624	NO
20-Jul-26	0	4543	NO
21-Jul-26	1.5	4374	NO
22-Jul-26	0	4289	NO
23-Jul-26	0	4241	NO
24-Jul-26	0	4271	NO
25-Jul-26	0	4315	NO
26-Jul-26	0	4445	NO
27-Jul-26	0	4948	NO
28-Jul-26	0	4201	NO
29-Jul-26	0	4170	NO
30-Jul-26	0	4190	NO
31-Jul-26	0	4151	NO
Monthly Total	9.5	140590	
Monthly Minimum	0	4151	
Monthly Mean	0.31	4535.16	
Monthly Maximum	5.5	4988	
Year to Date Total	154	586053	
Year to Date Minimum	0	4151	
Year to Date Mean	1.21	4803.71	
Year to Date Maximum	25.5	8160	

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - July 2026

Licensee: Eurobodalla Shire Council
EPL No.: 1397
Premises: Batemans Bay Sewage Treatment Plant
Address: George Bass Drive, Batemans Bay, NSW 2536
Licence Period: 1-Apr-26 to 31-Mar-27
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25
Published Date: 12-Aug-26

Licence Point 4 - Ambient Water Monitoring (Monthly Result)		
Frequency Sampling Method	Monthly Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
7-Jul-26	6	16-Jul-26

Licence Point 4 - Ambient Water Monitoring (Year to Date Results)	
Year to Date	Faecal Coliforms (CFU/100mL)
Samples	4
Min	<1
Mean	1.50
Median (50th %ile)	0.00
90th %ile	4.20
Max (100th %ile)	6

Licence Point 5 - Ambient Water Monitoring (Monthly Result)		
Frequency Sampling Method	Monthly Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
7-Jul-26	1	16-Jul-26

Licence Point 5 - Ambient Water Monitoring (Year To Date Results)	
Year to Date	Faecal Coliforms (CFU/100mL)
Samples	4
Min	<1
Mean	0.25
Median (50th %ile)	0.00
90th %ile	0.70
Max (100th %ile)	1

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - July 2026

Licensee: Eurobodalla Shire Council
EPL No.: 1397
Premises: Batemans Bay Sewage Treatment Plant
Address: George Bass Drive, Batemans Bay, NSW 2536
Licence Period: 1-Apr-26 to 31-Mar-27
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25
Published Date: 12-Aug-26

Monthly Exceedance Report			
Date	Exceedance Type	Parameter	Description / Action

Batemans Bay STP EPA Licence Point Map

