

Tuross Sewage Treatment Plant - Monthly Result Summary - August 2026



Anniversary Date: 1-Apr-25  
Published Date: 3-Sep-26

Licensee: Eurobodalla Shire Council  
EPL No.: 3108  
Premises: Tuross Sewage Treatment Plant  
Address: 217 Kelly Road, Bingie, NSW, 2537  
Licence Period: 01-Apr-26 to 31-Mar-27  
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>  
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: Aug-26

| Licence Point 1 (Discharge to Waters) and 4 (Discharge to Utilisation Area) - Concentration Limits |                 |                                   |                                    |
|----------------------------------------------------------------------------------------------------|-----------------|-----------------------------------|------------------------------------|
| Parameters                                                                                         | Unit of Measure | 50 percentile concentration limit | 100 percentile concentration limit |
| Biological Oxygen Demand                                                                           | (mg/L)          | 15                                | 20                                 |
| Oil and Grease                                                                                     | (mg/L)          |                                   | 10                                 |
| Total Suspended Solids                                                                             | (mg/L)          | 20                                | 30                                 |
| Total Nitrogen                                                                                     | (mg/L)          |                                   |                                    |
| Total Phosphorus                                                                                   | (mg/L)          |                                   |                                    |

See Note 1

Note 1: A 100 Percentile Concentration Limit of “10 mg/L and no visible oil and grease” applies for Point 1.  
Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Points 1 and 4 as described in Condition L3.

| Licence Point 3 - Effluent Quality Monitoring (Monthly Results) |                                 |                       |                               |                          |                          |               |
|-----------------------------------------------------------------|---------------------------------|-----------------------|-------------------------------|--------------------------|--------------------------|---------------|
| Sample Frequency Sampling Method                                | Monthly Composite Sample        | Monthly Grab Sample   | Monthly Composite Sample      | Monthly Composite Sample | Monthly Composite Sample |               |
| Sampled Date                                                    | Biological Oxygen Demand (mg/L) | Oil and Grease (mg/L) | Total Suspended Solids (mg/L) | Total Nitrogen (mg/L)    | Total Phosphorus (mg/L)  | Obtained Date |
| 4-Aug-26                                                        | 4.00                            | <5                    | 17.00                         | 6.23                     | 3.11                     | 13-Aug-26     |
| 100 Percentile Exceedance?                                      | NO                              | NO                    | NO                            | NO                       | NO                       |               |

| Licence Point 3 - Effluent Quality Monitoring (Year To Date Results) |                                 |                       |                               |                       |                         |
|----------------------------------------------------------------------|---------------------------------|-----------------------|-------------------------------|-----------------------|-------------------------|
| Year to Date                                                         | Biological Oxygen Demand (mg/L) | Oil and Grease (mg/L) | Total Suspended Solids (mg/L) | Total Nitrogen (mg/L) | Total Phosphorus (mg/L) |
| Samples                                                              | 5                               | 5                     | 5                             | 5                     | 5                       |
| Min                                                                  | <2                              | <5                    | 4.00                          | 3.00                  | 1.05                    |
| Mean                                                                 | 2.60                            | 2.50                  | 9.20                          | 5.67                  | 3.68                    |
| Median (50th %ile)                                                   | 3.00                            | 2.50                  | 9.00                          | 4.96                  | 3.52                    |
| 90th %ile                                                            | 3.60                            | 2.50                  | 14.20                         | 8.17                  | 5.69                    |
| Max (100th %ile)                                                     | 4.00                            | <5                    | 17.00                         | 9.47                  | 7.04                    |

Tuross Sewage Treatment Plant - Monthly Result Summary - August 2026

Licensee: Eurobodalla Shire Council  
EPL No.: 3108  
Premises: Tuross Sewage Treatment Plant  
Address: 217 Kelly Road, Bingie, NSW, 2537  
Licence Period: 01-Apr-26 to 31-Mar-27  
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>  
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25  
Published Date: 3-Sep-26

| Licence Point 2 - Influent Volume Monitoring |                       |                         |                     |
|----------------------------------------------|-----------------------|-------------------------|---------------------|
| Sample Frequency                             | Daily (Continuous)    | Maximum Daily flow (kL) | 7000                |
| Sampling Method                              | Ultrasonic Flow Meter |                         |                     |
| Sample Date                                  | Rainfall (mm)         | Plant Inflow (kL)       | Exceedance (YES/NO) |
| 1-Aug-26                                     | 0                     | 410.0                   | NO                  |
| 2-Aug-26                                     | 0                     | 428.7                   | NO                  |
| 3-Aug-26                                     | 0                     | 369.7                   | NO                  |
| 4-Aug-26                                     | 0                     | 391.2                   | NO                  |
| 5-Aug-26                                     | 0                     | 378.3                   | NO                  |
| 6-Aug-26                                     | 0                     | 402.8                   | NO                  |
| 7-Aug-26                                     | 0                     | 395.0                   | NO                  |
| 8-Aug-26                                     | 0                     | 368.0                   | NO                  |
| 9-Aug-26                                     | 0.6                   | 364.2                   | NO                  |
| 10-Aug-26                                    | 3.2                   | 390.5                   | NO                  |
| 11-Aug-26                                    | 0                     | 407.1                   | NO                  |
| 12-Aug-26                                    | 0                     | 382.5                   | NO                  |
| 13-Aug-26                                    | 0                     | 387.5                   | NO                  |
| 14-Aug-26                                    | 0                     | 407.0                   | NO                  |
| 15-Aug-26                                    | 0.8                   | 393.9                   | NO                  |
| 16-Aug-26                                    | 22                    | 475.3                   | NO                  |
| 17-Aug-26                                    | 0.2                   | 376.7                   | NO                  |
| 18-Aug-26                                    | 0.6                   | 398.0                   | NO                  |
| 19-Aug-26                                    | 0                     | 399.0                   | NO                  |
| 20-Aug-26                                    | 0                     | 379.0                   | NO                  |
| 21-Aug-26                                    | 0                     | 407.5                   | NO                  |
| 22-Aug-26                                    | 0                     | 417.7                   | NO                  |
| 23-Aug-26                                    | 0                     | 383.7                   | NO                  |
| 24-Aug-26                                    | 4                     | 395.8                   | NO                  |
| 25-Aug-26                                    | 2.8                   | 285.0                   | NO                  |
| 26-Aug-26                                    | 0.4                   | 389.8                   | NO                  |
| 27-Aug-26                                    | 0                     | 386.1                   | NO                  |
| 28-Aug-26                                    | 0                     | 392.0                   | NO                  |
| 29-Aug-26                                    | 0                     | 424.7                   | NO                  |
| 30-Aug-26                                    | 0                     | 429.6                   | NO                  |
| 31-Aug-26                                    | 0                     | 400.0                   | NO                  |
| Monthly Total                                | 34.6                  | 12216.3                 |                     |
| Monthly Minimum                              | 0                     | 285                     |                     |
| Monthly Mean                                 | 1.12                  | 394.07                  |                     |
| Monthly Maximum                              | 22                    | 475.34                  |                     |
| Year to Date Total                           | 119.4                 | 65179.65                |                     |
| Year to Date Minimum                         | 0                     | 285                     |                     |
| Year to Date Mean                            | 0.78                  | 426.01                  |                     |
| Year to Date Maximum                         | 42                    | 827.31                  |                     |



Tuross Sewage Treatment Plant - Monthly Result Summary - August 2026

Licensee: Eurobodalla Shire Council  
EPL No.: 3108  
Premises: Tuross Sewage Treatment Plant  
Address: 217 Kelly Road, Bingie, NSW, 2537  
Licence Period: 01-Apr-26 to 31-Mar-27  
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>  
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25  
Published Date: 3-Sep-26

| Monthly Exceedance Report |                 |           |                      |  |
|---------------------------|-----------------|-----------|----------------------|--|
| Date                      | Exceedance Type | Parameter | Description / Action |  |
|                           |                 |           |                      |  |

EPA Licence Point Map

