

Narooma Sewage Treatment Plant - Monthly Result Summary - December 2024



Anniversary Date: 1-Apr-24
Published Date: 8-Jan-25

Licensee: Eurobodalla Shire Council

EPL No.: 1398

Premises: Narooma Sewage Treatment Plant

Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-24 to 31-Mar-25

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: **Dec-24**

Licence Point 1 - Discharge to Waters - Point 1 Concentration Limits			
Parameters	Unit of Measure	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	15
Oil and Grease	(mg/L)	5	10
pH	(pH Units)	-	6.5-8.5
Total Suspended Solids	(mg/L)	15	25
Chlorophyll a	(mg/m3)		
Faecal Coliforms	(CFU/100mL)	200	600
Total Nitrogen	(mg/L)	15	20
Total Phosphorus	(mg/L)	8	10
Ammonia	(mg/L)	2	5

See Note 1

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Point 1 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)									
Sample Frequency	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	
Sampling Method	Composite Sample	Grab Sample	Grab Sample	Composite Sample	Grab Sample	Composite Sample	Composite Sample	Grab Sample	
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Chlorophyll a (mg/m3)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)	Obtained Date
17-Dec-24	2.00	<5	9.00	3.00	35.99	4.85	5.84	0.25	28-Dec-24
100 Percentile Exceedance?	NO	NO	YES	NO	NO	NO	NO	NO	

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)								
Year to Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Chlorophyll a (mg/m3)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)
Samples	10	10	10	10	10	10	10	10
Min	<2	<5	7.10	<2	2.50	3.66	1.400	0.05
Mean	1.50	2.50	8.09	6.20	9.63	7.96	5.346	0.51
Median (50th %ile)	1.50	2.50	7.80	6.50	4.35	7.54	5.480	0.25
90th %ile	2.00	2.50	9.09	10.10	18.18	12.03	7.092	1.10
Max (100th %ile)	2.00	<5	9.90	11.00	35.99	14.10	7.380	1.84

Narooma Sewage Treatment Plant - Monthly Result Summary - December 2024

Licensee: Eurobodalla Shire Council
 EPL No.: 1398
 Premises: Narooma Sewage Treatment Plant
 Address: Lakeside Drive, Narooma, NSW 2546



Anniversary Date: 1-Apr-24
 Published Date: 8-Jan-25

Licence Period: 01-Apr-24 to 31-Mar-25

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Licence Point 2 - Influent Volume Monitoring			
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	20000
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall (mm)	Plant Inflow (kL)	Exceedance (YES/NO)
1-Dec-24	0.2	1820.4	NO
2-Dec-24	0	1633.0	NO
3-Dec-24	0	1488.1	NO
4-Dec-24	0	1449.0	NO
5-Dec-24	1.2	1493.2	NO
6-Dec-24	0.2	1530.6	NO
7-Dec-24	4	1512.4	NO
8-Dec-24	0	1530.3	NO
9-Dec-24	0.2	1519.2	NO
10-Dec-24	0.2	1477.0	NO
11-Dec-24	0	1411.9	NO
12-Dec-24	0	1467.9	NO
13-Dec-24	0	1463.3	NO
14-Dec-24	0	1447.0	NO
15-Dec-24	0	1513.7	NO
16-Dec-24	0	1505.8	NO
17-Dec-24	0	1481.5	NO
18-Dec-24	0	1495.6	NO
19-Dec-24	0	1550.9	NO
20-Dec-24	0	1548.4	NO
21-Dec-24	0	1624.9	NO
22-Dec-24	0	1709.5	NO
23-Dec-24	9	1816.1	NO
24-Dec-24	0	1906.3	NO
25-Dec-24	0	1744.9	NO
26-Dec-24	0	1946.0	NO
27-Dec-24	0	2033.6	NO
28-Dec-24	0	2143.4	NO
29-Dec-24	0	2156.3	NO
30-Dec-24	0	2267.0	NO
31-Dec-24	3.2	2258.0	NO
Monthly Total	18.20	51944.88	
Monthly Minimum	0.00	1411.91	
Monthly Mean	0.59	1675.64	
Monthly Maximum	9.00	2267.00	
Year to Date Total	646.10	478830.22	
Year to Date Minimum	0.00	1238.40	
Year to Date Mean	2.35	1741.20	
Year to Date Maximum	80.60	10775.24	

Narooma Sewage Treatment Plant - Monthly Result Summary - December 2024

Licensee: Eurobodalla Shire Council
 EPL No.: 1398
 Premises: Narooma Sewage Treatment Plant
 Address: Lakeside Drive, Narooma, NSW 2546



Anniversary Date: 1-Apr-24
 Published Date: 8-Jan-25

Licence Period: 01-Apr-24 to 31-Mar-25

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)		
Frequency	Special Frequency 2*	
Sampling Method	Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
3-Dec-24	440	9-Dec-24
10-Dec-24	26	20-Dec-24
17-Dec-24	130	28-Dec-24
23-Dec-24	540	28-Dec-24
30-Dec-24	51	3-Jan-25

Licence Point 4 - Ambient Water Monitoring (Monthly Results)		
Frequency	Special Frequency 2*	
Sampling Method	Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
3-Dec-24	<1	9-Dec-24
10-Dec-24	<1	20-Dec-24
17-Dec-24	<1	28-Dec-24
23-Dec-24	<1	28-Dec-24
30-Dec-24	<1	3-Jan-25

Licence Point 5 - Ambient Water Monitoring (Monthly Results)		
Frequency	Special Frequency 2*	
Sampling Method	Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
3-Dec-24	<1	9-Dec-24
10-Dec-24	<1	20-Dec-24
17-Dec-24	<1	28-Dec-24
23-Dec-24	1	28-Dec-24
30-Dec-24	1	3-Jan-25

* Special Frequency 2: at least weekly during the months of November, December, January, February and March

Licence Point 3 - Effluent Quality Monitoring (Year to Date Results)	
Year to Date	Faecal Coliforms (CFU/100mL)
Samples	9
Min	2
Mean	185.89
Median (50th %ile)	51
90th %ile	460
Max (100th %ile)	540

Licence Point 4 - Ambient Water Monitoring (Year to Date Results)	
Year to Date	Faecal Coliforms (CFU/100mL)
Samples	9
Min	<1
Mean	0.00
Median (50th %ile)	0
90th %ile	0
Max (100th %ile)	<1

Licence Point 5 - Ambient Water Monitoring (Year to Date Results)	
Year to Date	Faecal Coliforms (CFU/100mL)
Samples	9
Min	<1
Mean	0.44
Median (50th %ile)	0
90th %ile	1
Max (100th %ile)	1

Monthly Exceedance Report			
Date	Exceedance Type	Parameter	Description / Action
3-Dec-24	L3.1 Concentration Limits	Faecal Coliform	Faecal Coliform result 440 CFU/100ml exceeded 90 percentile limit (200 CFU/100ml) at monitoring point 3.
17-Dec-24	L3.1 Concentration Limits	pH	pH result 9.0 exceeded 100 percentile limit (6.5 - 8.5) at monitoring point 3.
23-Dec-24	L3.1 Concentration Limits	Faecal Coliform	Faecal Coliform result 540 CFU/100ml exceeded 90 percentile limit (200 CFU/100ml) at monitoring point 3.

Narooma Sewage Treatment Plant - Monthly Result Summary - December 2024

Licensee: Eurobodalla Shire Council
EPL No.: 1398
Premises: Narooma Sewage Treatment Plant
Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-24 to 31-Mar-25

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-24
Published Date: 8-Jan-25

EPA Licence Point Map

