Tuross Sewage Treatment Plant - Monthly Result Summary - June 2021



Licensee: Eurobodalla Shire Council EPL No.: 3108 Premises: Tuross Sewage Treatment Plant Address: 217 Kelly Road, Bingie, NSW, 2537 Licence Period: 01-Apr-21 to 31-Mar-22 EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp//viewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108 POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Required Month: Jun-21

Licence Point 1 (Discharge to Waters) and 4 (Discharge to Utilisation Area) - Concentration Limits				
Parameters	Unit of Measure	50 percentile concentration limit	100 percentile concentration limit	
Biological Oxygen Demand	(mg/L)	15	20	
Oil and Grease	(mg/L)		10	See Not
Total Suspended Solids	(mg/L)	20	30	
Total Nitrogen	(mg/L)			
Total Phosphorus	(mg/L)			

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Points 1 and 4 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)						
Sample Frequency	Monthly	Monthly	Monthly	Monthly	Monthly	
Sampling Method	Composite Sample	Grab Sample	Composite Sample	Composite Sample	Composite Sample	
Sampled Date Biologic	Biological Oxygen Demand	Oil and Grease	Total Suspended Solids	Total Nitrogen	Total Phosphorus	Obtained Date
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	
15-Jun-21	4.00	<5	7.00	8.98	3.28	26-Jun-21
100 Percentile Exceedance?	NO	NO	NO	NO	NO	

* Special Frequency 2: at least weekly during the months of November, December, January, February and March

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)					
Year to Date	Biological Oxygen Demand	Oil and Grease	Total Suspended Solids	Total Nitrogen	Total Phosphorus
fear to bate	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Samples	3	3	3	3	3
Min	4.00	<5	8.98	8.98	3.280
Mean	4.67	2.50	13.59	13.59	4.413
Median (50th %ile)	5.00	2.50	13.50	13.50	4.440
90th %ile	5.00	2.50	17.34	17.34	5.304
Max (100th %ile)	5.00	<5	18.30	18.30	5.520

Tuross Sewage Treatment Plant - Monthly Result Summary - June 2021

Licensee: Eurobodalla Shire Council

EPL No.: 3108

Premises: Tuross Sewage Treatment Plant

Address: 217 Kelly Road, Bingie, NSW, 2537

Licence Period: 01-Apr-21

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108
POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

to

31-Mar-22

	Licence Point 2 - Influent Volume Monitoring				
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	7000		
Sampling Method	Ultrasonic Flow Meter				
Sample Date	Rainfall	Plant Inflow	Exceedance		
Sample Date	(mm)	(kL)	(YES/NO)		
1-Jun-21	0	345.1	NO		
2-Jun-21	0	341.8	NO		
3-Jun-21	5.6	347.4	NO		
4-Jun-21	0	361.1	NO		
5-Jun-21	0	385.6	NO		
6-Jun-21	0	373.3	NO		
7-Jun-21	0	358.7	NO		
8-Jun-21	0	330.6	NO		
9-Jun-21	12.6	340.8	NO		
10-Jun-21	11.6	426.0	NO		
11-Jun-21	57.8	1845.2	NO		
12-Jun-21	0.2	961.4	NO		
13-Jun-21	0	744.9	NO		
14-Jun-21	0	606.4	NO		
15-Jun-21	0	463.9	NO		
16-Jun-21	15.8	548.0	NO		
17-Jun-21	2.4	854.2	NO		
18-Jun-21	5.8	665.1	NO		
19-Jun-21	0	634.5	NO		
20-Jun-21	0.8	545.0	NO		
21-Jun-21	0	476.4	NO		
22-Jun-21	0	446.1	NO		
23-Jun-21	0	443.1	NO		
24-Jun-21	1.4	411.1	NO		
25-Jun-21	0.2	469.1	NO		
26-Jun-21	0	459.3	NO		
27-Jun-21	0	459.2	NO		
28-Jun-21	0	434.6	NO		
29-Jun-21	0.2	431.5	NO		
30-Jun-21	1	433.1	NO		
Monthly Total	115.4	15942.5			
Monthly Minimum	0	330.6			
Monthly Mean	3.85	531.42			
Monthly Maximum	57.8	1845.2			
Year to Date Total	259.6	46227.5			
Year to Date Minimum	0	330.6			
Year to Date Mean	2.852747253	507.9945055			
Year to Date Maximum	57.8	1845.2			



Tuross Sewage Treatment Plant - Monthly Result Summary - June 2021



Monthly Exceedance Report				
Date	Exceedance Type	Parameter	Description / Action	
	Date	Date Exceedance Type	Date Exceedance Type Parameter	

