

Anniversary Date: Published Date: 1-Apr-21 16-Sep-22

Licensee: Eurobodalla Shire Council

Premises: Narooma Sewage Treatment Plant Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-21 to 31-Mar-22

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Required Month: Aug-22

Licenc	ce Point 1 - Discharge to Waters	- Point 1 Concentration Limits		
Parameters	Unit of Measure	90 percentile concentration limit	100 percentile concentration limit	
Biological Oxygen Demand	(mg/L)	10	15	
Oil and Grease	(mg/L)	5	10	See Note 1
pH	(pH Units)	-	6.5-8.5	
Total Suspended Solids Chlorophyll a	(mg/L) (mg/m3)	15	25	
Faecal Coliforms	(CFU/100mL)	200	600	
Total Nitrogen	(mg/L)	15	20	
Total Phosphorus	(mg/L)	8	10	
Ammonia	(mg/L)	2	5	

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Point 1 as described in Condition L3.

				Licence Point 3 - Effluent C	uality Monitoring (Monthly	Results)				
Sample Frequency	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	Special Frequency 2*	6 Times Per Year	6 Times Per Year	6 Times Per Year	
Sampling Method	Composite Sample	Grab Sample	Grab Sample	Composite Sample	Grab Sample	Grab Sample	Composite Sample	Composite Sample	Grab Sample	
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Chlorophyll a (mg/m3)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)	Obtained Date
9-Aug-22	<2	<5	7.80	<2	2.80	59	3.68	5.78	0.07	24-Aug-22
100 Percentile Exceedance?	NO	NO	NO	NO	NO	NO	NO	NO	NO	

<sup>\*</sup> Special Frequency 2: at least weekly during the months of November, December, January, February and March

	Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)								
Year to Date	Biological Oxygen Demand	Oil and Grease	pH	Total Suspended Solids	Chlorophyll a	Faecal Coliforms	Total Nitrogen	Total Phosphorus	Ammonia
real to bate	(mg/L)	(mg/L)	(pH Units)	(mg/L)	(mg/m3)	(CFU/100mL)	(mg/L)	(mg/L)	(mg/L)
Samples	5	5	5	5	5	5	5	5	5
Min	<2	<5	7.00	<2	1.00	59	2.75	3.780	0.07
Mean	2.60	2.50	7.36	5.00	4.74	330	6.94	4.708	0.51
Median (50th %ile)	3.00	2.50	7.30	2.00	3.50	120	4.45	4.520	0.30
90th %ile	4.00	2.50	7.68	11.80	8.56	736	12.38	5.652	1.03
Max (100th %ile)	4.00	<5	7.80	17.00	10.00	920	14.30	5.780	1.23

Licensee: Eurobodalla Shire Council EPL No.:

Premises: Narooma Sewage Treatment Plant Address: Lakeside Drive, Narooma, NSW 2546

01-Apr-21 31-Mar-22 Licence Period:

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

	Licence Point 2 - Influent Vo		
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	20000
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall	Plant Inflow	Exceedance
Sample Date	(mm)	(kL)	(YES/NO)
1-Aug-21	0	1526.5	NO
2-Aug-21	0	1532.1	NO
3-Aug-21	0	1502.6	NO
4-Aug-21	3.2	1382.0	NO
5-Aug-21	0	1432.5	NO
6-Aug-21	0	1529.6	NO
7-Aug-21	0.2	1512.7	NO
8-Aug-21	0	1497.6	NO
9-Aug-21	0	1485.6	NO
10-Aug-21	0	1441.3	NO
11-Aug-21	0	1492.3	NO
12-Aug-21	0	1383.3	NO
13-Aug-21	1.2	1466.0	NO
14-Aug-21	0.2	1416.0	NO
15-Aug-21	0	1438.1	NO
16-Aug-21	0	1439.7	NO
17-Aug-21	0	1438.1	NO
18-Aug-21	0.2	1419.2	NO
19-Aug-21	0.4	1385.3	NO
20-Aug-21	3.6	1369.2	NO
21-Aug-21	0	1498.7	NO
22-Aug-21	0	1558.1	NO
23-Aug-21	7.6	1534.2	NO
24-Aug-21	0	1549.5	NO
25-Aug-21	0.2	1555.7	NO
26-Aug-21	1	1434.9	NO
27-Aug-21	1	1457.5	NO
28-Aug-21	0.2	1440.2	NO
29-Aug-21	0	1490.9	NO
30-Aug-21	0	1374.3	NO
31-Aug-21	0	1389.1	NO
Monthly Total	19.00	45372.80	
•	0.00		
Monthly Minimum	1	1369.19	
Monthly Mean	0.61	1463.64	
Monthly Maximum	7.60	1558.06	
Year to Date Total	379.10	300413.74	
Year to Date Minimum	0.00	1369.19	
Year to Date Mean Year to Date Maximum	2.48 71.40	1963.49 10515.43	



1-Apr-21 16-Sep-22

Licensee: Eurobodalla Shire Council
EPL No.: 1398

Premises: Narooma Sewage Treatment Plant

Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-21 to 31-Mar-22

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Licence Point 4 - An	Licence Point 4 - Ambient Water Monitoring (Monthly Result)			
Frequency	Special Frequency 2*			
Sampling Method	Grab Sample			
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date		

<sup>\*</sup> Special Frequency 2: at least weekly during the months of November, December, January, February and March

Licence Point 4 - Ambi	Licence Point 4 - Ambient Water Monitoring (Year to Date Results)		
Year to Date	Faecal Coliforms		
rear to Date	(CFU/100mL)		
Samples			
Min			
Mean			
Median (50th %ile)			
90th %ile			
Max (100th %ile)			

Licence Point 5	- Ambient Water Monitoring	(Monthly Result)
Frequency Sampling Method	Special Frequency 2* Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date

eurobodalla Anniversary Date:
Shire council Published Date:

1-Apr-21

16-Sep-22

Licence Point 5 - Ambie	Licence Point 5 - Ambient Water Monitoring (Year to Date Results)				
V	Faecal Coliforms				
Year to Date	(CFU/100mL)				
Samples					
Min					
Mean					
Median (50th %ile)					
90th %ile					
Max (100th %ile)					

			Monthly Exceedance Report
Date	Exceedance Type	Parameter	Description / Action

Licensee: Eurobodalla Shire Council

EPL No.: 1398

Premises: Narooma Sewage Treatment Plant

Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-21 to 31-Mar-22

 $\textbf{EPL Link:} \ \underline{\text{https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031\&SYSUID=1\&LICID=1398}\\$ 

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/



