

Tomakin Sewage Treatment Plant - Monthly Result Summary - March 2023



Anniversary Date: 1-Apr-21
Published Date: 8-May-23

Licensee: Eurobodalla Shire Council
EPL No.: 2851
Premises: Tomakin Sewage Treatment Plant
Address: George Bass Drive, Tomakin, NSW 2537
Licence Period: 01-Apr-21 to 31-Mar-22
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183819&SYSUID=1&LICID=2851>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: **Mar-23**

Licence Point 1 - Discharge to Waters - Point 1 Concentration Limits			
Parameters	Unit of Measure	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	15
Oil and Grease	(mg/L)	5	10
pH	(pH Units)	-	6.5-8.5
Total Suspended Solids	(mg/L)	15	20
Chlorophyll a	(mg/m3)		
Faecal Coliforms	(CFU/100mL)	200	600
Total Nitrogen	(mg/L)	10	15
Total Phosphorus	(mg/L)	8	10
Ammonia	(mg/L)	2	5

See Note 1

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Point 1 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)										
Sample Frequency	Monthly	Monthly	Monthly	Monthly	Monthly	Special Frequency 2*	Monthly	Monthly	Monthly	
Sampling Method	Composite Sample	Grab Sample	Grab Sample	Composite Sample	Grab Sample	Grab Sample	Composite Sample	Composite Sample	Grab Sample	
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Chlorophyll a (mg/m3)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)	Obtained Date
7-Mar-23						9300				20-Feb-23
14-Mar-23						6100				17-Feb-23
21-Mar-23	3.00	<5	7.40	6.00	50.60	300	2.13	9.40	0.59	30-Mar-23
28-Mar-23						1600				6-Mar-23
100 Percentile Exceedance?	NO	NO	NO	NO	NO	YES	NO	NO	NO	

* Special Frequency 2: at least weekly during the months of November, December, January, February and March

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)									
Year to Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Chlorophyll a (mg/m3)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)
Samples	13	13	13	13	13	29	13	13	13
Min	<2	<5	7.10	<2	0.70	10	1.35	4.100	0.07
Mean	2.38	2.50	7.31	3.46	22.20	1208	4.13	6.565	0.46
Median (50th %ile)	2.00	2.50	7.30	2.00	7.90	280	3.65	6.160	0.37
90th %ile	4.00	2.50	7.40	6.00	54.76	3260	8.28	9.392	0.94
Max (100th %ile)	5.00	<5	7.40	12.00	115.40	9300	9.98	9.960	1.06

Tomakin Sewage Treatment Plant - Monthly Result Summary - March 2023

Licensee: Eurobodalla Shire Council
 EPL No.: 2851
 Premises: Tomakin Sewage Treatment Plant
 Address: George Bass Drive, Tomakin, NSW 2537



Anniversary Date: 1-Apr-21
 Published Date: 8-May-23

Licence Period: 01-Apr-21 to 31-Mar-22

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=1838198&SYSUID=1&LICID=2851>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Licence Point 2 - Influent Volume Monitoring			
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	14000
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall (mm)	Plant Inflow (kL)	Exceedance (YES/NO)
1-Mar-23	1	1098.6	NO
2-Mar-23	2.5	1116.8	NO
3-Mar-23	22	1192.3	NO
4-Mar-23	10	1646.1	NO
5-Mar-23	2.5	1360.6	NO
6-Mar-23	9.5	1507.8	NO
7-Mar-23	0	1378.5	NO
8-Mar-23	0	1141.9	NO
9-Mar-23	0	1129.3	NO
10-Mar-23	0	1131.6	NO
11-Mar-23	0	1194.1	NO
12-Mar-23	0	1472.8	NO
13-Mar-23	0	1572.5	NO
14-Mar-23	12.5	1487.9	NO
15-Mar-23	9	1302.0	NO
16-Mar-23	0.5	1133.5	NO
17-Mar-23	0	1233.4	NO
18-Mar-23	0	1169.4	NO
19-Mar-23	0	1329.5	NO
20-Mar-23	0.5	1235.5	NO
21-Mar-23	0	1184.1	NO
22-Mar-23	0	1063.0	NO
23-Mar-23	0	1070.6	NO
24-Mar-23	5	1171.8	NO
25-Mar-23	0.5	1190.4	NO
26-Mar-23	8.5	1289.1	NO
27-Mar-23	2.5	1309.6	NO
28-Mar-23	0.5	1093.6	NO
29-Mar-23	9	1330.9	NO
30-Mar-23	22	1610.4	NO
31-Mar-23	0	1212.3	NO
Monthly Total	118.00	39359.64	
Monthly Minimum	0.00	1063.01	
Monthly Mean	3.81	1269.67	
Monthly Maximum	22.00	1646.11	
Year to Date Total	1236.50	576626.04	
Year to Date Minimum	0.00	997.73	
Year to Date Mean	3.39	1579.80	
Year to Date Maximum	72.00	7833.41	

Tomakin Sewage Treatment Plant - Monthly Result Summary - March 2023

Licensee: Eurobodalla Shire Council
 EPL No.: 2851
 Premises: Tomakin Sewage Treatment Plant
 Address: George Bass Drive, Tomakin, NSW 2537
 Licence Period: 01-Apr-21 to 31-Mar-22
 EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183819&SYSUID=1&LICID=2851>
 POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-21
 Published Date: 8-May-23

Licence Point 4 - Ambient Water Monitoring (Monthly Result)

Frequency	Special Frequency 2*	
Sampling Method	Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
7-Mar-23	9	17-Mar-23
14-Mar-23	2	17-Mar-23
21-Mar-23	1	30-Mar-23
28-Mar-23	<1	1-Apr-23

* Special Frequency 2: at least weekly during the months of November, December, January, February and March

Licence Point 4 - Ambient Water Monitoring (Year to Date Results)

Year to Date	Faecal Coliforms (CFU/100mL)
Samples	22
Min	<1
Mean	38.50
Median (50th %ile)	1
90th %ile	62
Max (100th %ile)	490

Monthly Exceedance Report

Date	Exceedance Type	Parameter	Description / Action
7-Mar-23	Concentration Limit	Faecal Coliforms	Faecal Coliform result (9300 CFU/100mL) exceeded 100 percentile concentration limit (600 CFU/100mL) at monitoring point 3.
14-Mar-23	Concentration Limit	Faecal Coliforms	Faecal Coliform result (6100 CFU/100mL) exceeded 100 percentile concentration limit (600 CFU/100mL) at monitoring point 3.
21-Mar-23	Concentration Limit	Faecal Coliforms	Faecal Coliform result (300 CFU/100mL) exceeded 90 percentile concentration limit (200 CFU/100mL) at monitoring point 3.
21-Mar-23	Concentration Limit	Total Phosphorus	Total Phosphorus result (9.40 mg/L) exceeded 90 percentile concentration limit (8.0 mg/L) at monitoring point 3.
28-Mar-23	Concentration Limit	Faecal Coliforms	Faecal Coliform result (1600 CFU/100mL) exceeded 100 percentile concentration limit (600 CFU/100mL) at monitoring point 3.

Tomakin Sewage Treatment Plant - Monthly Result Summary - March 2023

Licensee: Eurobodalla Shire Council
EPL No.: 2851
Premises: Tomakin Sewage Treatment Plant
Address: George Bass Drive, Tomakin, NSW 2537
Licence Period: 01-Apr-21 to 31-Mar-22
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183819&SYSUID=1&LICID=2851>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-21
Published Date: 8-May-23

EPA Licence Point Map

