

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - JULY 2021



Anniversary Date: 1-Apr-21
Published Date: 5-Aug-21

Licensee: Eurobodalla Shire Council
EPL No.: 1397
Premises: Batemans Bay Sewage Treatment Plant
Address: George Bass Drive, Batemans Bay, NSW 2536
Licence Period: 1-Apr-21 to 31-Mar-22
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: Jul-21

Licence Point 1 - Discharge to Waters - Point 1 Concentration Limits			
Parameters	Unit of Measure	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	15
Oil and Grease	(mg/L)	5	10
pH	(pH Units)	-	6.5-8.5
Total Suspended Solids	(mg/L)	15	20
Faecal Coliforms	(CFU/100mL)	200	600
Total Nitrogen	(mg/L)	10	15
Total Phosphorus	(mg/L)	5	8
Ammonia	(mg/L)	2	5

See Note 1

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Point 1 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)									
Sample Frequency Sampling Method	Monthly Composite Sample	Monthly Grab Sample	Monthly Grab Sample	Monthly Composite Sample	Monthly Grab Sample	Monthly Composite Sample	Monthly Composite Sample	Monthly Grab Sample	
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)	Obtained Date
13-Jul-21	<2	<5	7.60	<2	110	6.25	2.68	0.02	23-Jul-21
100 Percentile Exceedance?	NO	NO	NO	NO	NO	NO	NO	NO	

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)								
Year to Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)
Samples	4	4	4	4	4	4	4	4
Min	<2	<5	7.30	<2	58	1.65	1.28	0.01
Mean	1.00	2.50	7.55	1.00	687	3.59	2.07	0.13
Median (50th %ile)	1.00	2.50	7.55	1.00	345	3.23	2.16	0.02
90th %ile	1.00	2.50	7.74	1.00	1574	5.47	2.56	0.33
Max (100th %ile)	<2	<5	7.80	<2	2000	6.25	2.68	0.46

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - JULY 2021

Licensee: Eurobodalla Shire Council
 EPL No.: 1397
 Premises: Batemans Bay Sewage Treatment Plant
 Address: George Bass Drive, Batemans Bay, NSW 2536
 Licence Period: 1-Apr-21 to 31-Mar-22
 EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>
 POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-21
 Published Date: 5-Aug-21

Licence Point 2 - Influent Volume Monitoring

Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	26565
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall (mm)	Plant Inflow (kL)	Exceedance (YES/NO)
1-Jul-21	0	4604.2	NO
2-Jul-21	2	4657.1	NO
3-Jul-21	1	4753.7	NO
4-Jul-21	0	4706.1	NO
5-Jul-21	0	4621.8	NO
6-Jul-21	0	4525.3	NO
7-Jul-21	0	4458.5	NO
8-Jul-21	0	4392.9	NO
9-Jul-21	0	4412.6	NO
10-Jul-21	0	4289.6	NO
11-Jul-21	3	4295.3	NO
12-Jul-21	0	4321.0	NO
13-Jul-21	0	4243.6	NO
14-Jul-21	0	4088.3	NO
15-Jul-21	0	3907.6	NO
16-Jul-21	0	4097.5	NO
17-Jul-21	0	4006.3	NO
18-Jul-21	0	4016.8	NO
19-Jul-21	0	4099.7	NO
20-Jul-21	0	3974.9	NO
21-Jul-21	0	3844.2	NO
22-Jul-21	0	4022.8	NO
23-Jul-21	0	3929.7	NO
24-Jul-21	1	3878.3	NO
25-Jul-21	0	4115.9	NO
26-Jul-21	0	4049.8	NO
27-Jul-21	0	3973.5	NO
28-Jul-21	0	3884.9	NO
29-Jul-21	0	3883.6	NO
30-Jul-21	0	3878.2	NO
31-Jul-21	0	3856.0	NO
Monthly Total	7	129789.7	
Monthly Minimum	0	3844.2	
Monthly Mean	0.23	4186.76	
Monthly Maximum	3	4753.7	
Year to Date Total	321.3	670652.3	
Year to Date Minimum	0	3844.2	
Year to Date Mean	2.63	5497.15	
Year to Date Maximum	74	25182.1	

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - JULY 2021

Licensee: Eurobodalla Shire Council

EPL No.: 1397

Premises: Batemans Bay Sewage Treatment Plant

Address: George Bass Drive, Batemans Bay, NSW 2536

Licence Period: 1-Apr-21 to 31-Mar-22

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-21

Published Date: 5-Aug-21

Licence Point 4 - Ambient Water Monitoring (Monthly Result)

Frequency	Monthly	
Sampling Method	Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
13-Jul-21	1	23-Jul-21

Licence Point 4 - Ambient Water Monitoring (Year to Date Results)

Year to Date	Faecal Coliforms (CFU/100mL)
Samples	4
Min	<1
Mean	1
Median (50th %ile)	1
90th %ile	1
Max (100th %ile)	2

Licence Point 5 - Ambient Water Monitoring (Monthly Result)

Frequency	Monthly	
Sampling Method	Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
13-Jul-21	<1	23-Jul-21

Licence Point 5 - Ambient Water Monitoring (Year To Date Results)

Year to Date	Faecal Coliforms (CFU/100mL)
Samples	4
Min	<1
Mean	0
Median (50th %ile)	0
90th %ile	0
Max (100th %ile)	<1

Batemans Bay Sewage Treatment Plant - Monthly Result Summary - JULY 2021

Licensee: Eurobodalla Shire Council
 EPL No.: 1397
 Premises: Batemans Bay Sewage Treatment Plant
 Address: George Bass Drive, Batemans Bay, NSW 2536
 Licence Period: 1-Apr-21 to 31-Mar-22
 EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206046&SYSUID=1&LICID=1397>
 POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-21
 Published Date: 5-Aug-21

Monthly Exceedance Report

Date	Exceedance Type	Parameter	Description / Action

Batemans Bay STP EPA Licence Point Map



