

Moruya Sewage Treatment Plant - Monthly Result Summary - January 2021



Anniversary Date: 1-Apr-21
Published Date: 18-Feb-22

Licensee: Eurobodalla Shire Council
EPL No.: 1614
Premises: Moruya Sewage Treatment Plant
Address: Queen Street, Moruya, NSW 2537

Licence Period: 1-Apr-21 to 31-Mar-22

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206032&SYSUID=1&LICID=1614>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: **Jan-21**

Licence Point 6 (Discharge to Utilisation Area) & 11 (Discharge to Waters) - Concentration Limits			
Parameters	Unit of Measure	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	15
Oil and Grease	(mg/L)	5	10
pH	(pH Units)	-	6.5-8.5
Total Suspended Solids	(mg/L)	15	20
Chlorophyll a	(mg/m3)		
Faecal Coliforms	(CFU/100mL)	200	600
Total Nitrogen	(mg/L)	10	15
Total Phosphorus	(mg/L)	1	2
Ammonia	(mg/L)	2	5

See Note 1

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Points 6 and 11 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)										
Sample Frequency Sampling Method	Monthly Composite Sample	Monthly Grab Sample	Monthly Grab Sample	Monthly Composite Sample	Monthly Grab Sample	Monthly Grab Sample	Monthly Composite Sample	Monthly Composite Sample	Monthly Grab Sample	
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Chlorophyll a (mg/m3)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)	Obtained Date
27-Jan-22	<2	<5	7.40	<2	2.10	720	4.33	0.13	0.05	10-Feb-22
100 Percentile Exceedance?	NO	NO	NO	NO	NO	YES	NO	NO	NO	

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)									
Year to Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Chlorophyll a (mg/m3)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)
Samples	11	11	11	11	11	11	11	11	11
Min	<2	<5	7.20	<2	1.00	350	4.33	0.110	0.01
Mean	2.18	2.50	7.34	4.00	5.29	10489	5.49	0.198	0.13
Median (50th %ile)	2.00	2.50	7.30	4.00	2.50	2400	5.25	0.205	0.05
90th %ile	3.00	2.50	7.50	6.00	15.20	45000	6.24	0.265	0.20
Max (100th %ile)	6.00	<5	7.60	7.00	15.20	48000	7.55	0.296	0.76

Moruya Sewage Treatment Plant - Monthly Result Summary - January 2021

Licensee: Eurobodalla Shire Council
 EPL No.: 1614
 Premises: Moruya Sewage Treatment Plant
 Address: Queen Street, Moruya, NSW 2537



Anniversary Date: 1-Apr-21
 Published Date: 18-Feb-22

Licence Period: 1-Apr-21 to 31-Mar-22

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206032&SYSUID=1&LICID=1614>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Licence Point 2 - Influent Volume Monitoring			
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	14000
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall (mm)	Plant Inflow (kL)	Exceedance (YES/NO)
1-Jan-22	0	860.0	NO
2-Jan-22	0	750.0	NO
3-Jan-22	0	750.0	NO
4-Jan-22	0.2	770.0	NO
5-Jan-22	0	760.0	NO
6-Jan-22	22	920.0	NO
7-Jan-22	20.8	1620.0	NO
8-Jan-22	49.8	3020.0	NO
9-Jan-22	0.6	2230.0	NO
10-Jan-22	0.2	1400.0	NO
11-Jan-22	0	1180.0	NO
12-Jan-22	15.6	1270.0	NO
13-Jan-22	3.4	1510.0	NO
14-Jan-22	10.8	1870.0	NO
15-Jan-22	0.2	1360.0	NO
16-Jan-22	39	3430.0	NO
17-Jan-22	0	1620.0	NO
18-Jan-22	0.4	1420.0	NO
19-Jan-22	0	1250.0	NO
20-Jan-22	0.6	1150.0	NO
21-Jan-22	0.2	1120.0	NO
22-Jan-22	0	990.0	NO
23-Jan-22	0	920.0	NO
24-Jan-22	0	810.0	NO
25-Jan-22	0	850.0	NO
26-Jan-22	0	770.0	NO
27-Jan-22	0	710.0	NO
28-Jan-22	0	730.0	NO
29-Jan-22	0	690.0	NO
30-Jan-22	11.8	810.0	NO
31-Jan-22	0.2	680.0	NO
Monthly Total	175.8	38220.0	
Monthly Minimum	0	680	
Monthly Mean	5.67	1232.90	
Monthly Maximum	49.8	3430	
Year to Date Total	978.5	290498.0	
Year to Date Minimum	0.0	470.0	
Year to Date Mean	3.07	910.65	
Year to Date Maximum	62.4	5470.0	

Moruya Sewage Treatment Plant - Monthly Result Summary - January 2021

Licensee: Eurobodalla Shire Council

EPL No.: 1614

Premises: Moruya Sewage Treatment Plant

Address: Queen Street, Moruya, NSW 2537

Licence Period: 1-Apr-21 to 31-Mar-22

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206032&SYSUID=1&LICID=1614>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-21

Published Date: 18-Feb-22

Licence Point 7 - Ambient Water Monitoring (Monthly Result)

Frequency Sampling Method	Monthly Grab Sample	Monthly Grab Sample	
Sampled Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Obtained Date
27-Jan-22	1.97	0.169	10-Feb-22

Licence Point 8 - Ambient Water Monitoring (Monthly Result)

Frequency Sampling Method	Monthly Grab Sample	Monthly Grab Sample	
Sampled Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Obtained Date
27-Jan-22	3.79	0.317	10-Feb-22

Licence Point 7 - Ambient Water Monitoring (Year to Date Results)

Year to Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples	11	11
Min	0.77	0.028
Mean	1.43	0.076
Median (50th %ile)	1.15	0.046
90th %ile	2.14	0.169
Max (100th %ile)	3.43	0.183

Licence Point 8 - Ambient Water Monitoring (Year to Date Results)

Year to Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples	11	11
Min	0.54	0.019
Mean	1.90	0.085
Median (50th %ile)	1.85	0.045
90th %ile	2.69	0.129
Max (100th %ile)	3.79	0.317

Licence Point 9 - Ambient Water Monitoring (Monthly Result)

Frequency Sampling Method	Monthly Grab Sample		
Sampled Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Obtained Date
27-Jan-22	0.26	0.013	10-Feb-22

Licence Point 10 - Ambient Water Monitoring (Monthly Result)

Frequency Sampling Method	Monthly Grab Sample		
Sampled Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Obtained Date
27-Jan-22	0.24	0.013	10-Feb-22

Licence Point 9 - Ambient Water Monitoring (Year To Date Results)

Year to Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples	11	11
Min	0.17	0.004
Mean	0.35	0.011
Median (50th %ile)	0.26	0.008
90th %ile	0.59	0.014
Max (100th %ile)	0.68	0.036

Licence Point 10 - Ambient Water Monitoring (Year To Date Results)

Year to Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples	11	11
Min	0.16	0.006
Mean	0.37	0.017
Median (50th %ile)	0.25	0.011
90th %ile	0.58	0.028
Max (100th %ile)	0.96	0.064

Moruya Sewage Treatment Plant - Monthly Result Summary - January 2021

Licensee: Eurobodalla Shire Council
 EPL No.: 1614
 Premises: Moruya Sewage Treatment Plant
 Address: Queen Street, Moruya, NSW 2537



Anniversary Date: 1-Apr-21
 Published Date: 18-Feb-22

Licence Period: 1-Apr-21 to 31-Mar-22

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206032&SYSUID=1&LICID=1614>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Monthly Exceedance Report

Date	Exceedance Type	Parameter	Description / Action
27-Jan-22	Concentration Limit	Faecal Coliforms	Faecal Coliform result (720 CFU/100mL) exceeded 100 percentile concentration limit (600 CFU/100mL) at monitoring point 3

EPA Licence Point Map

