

Tuross Sewage Treatment Plant - Monthly Result Summary - February 2026



Anniversary Date: 1-Apr-25
Published Date: 3-Mar-26

Licensee: Eurobodalla Shire Council
EPL No.: 3108
Premises: Tuross Sewage Treatment Plant
Address: 217 Kelly Road, Bingie, NSW, 2537
Licence Period: 01-Apr-25 to 31-Mar-26
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: Feb-26

Licence Point 1 (Discharge to Waters) and 4 (Discharge to Utilisation Area) - Concentration Limits				See Note 1
Parameters	Unit of Measure	50 percentile concentration limit	100 percentile concentration limit	
Biological Oxygen Demand	(mg/L)	15	20	
Oil and Grease	(mg/L)		10	
Total Suspended Solids	(mg/L)	20	30	
Total Nitrogen	(mg/L)			
Total Phosphorus	(mg/L)			

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Points 1 and 4 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)						
Sample Frequency Sampling Method	Monthly Composite Sample	Monthly Grab Sample	Monthly Composite Sample	Monthly Composite Sample	Monthly Composite Sample	
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	Total Suspended Solids (mg/L)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Obtained Date
17-Feb-26	5.00	<5	9.00	8.36	4.78	26-Feb-26
100 Percentile Exceedance?	NO	NO	NO	NO	NO	

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)					
Year to Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	Total Suspended Solids (mg/L)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples	12	12	12	12	12
Min	<2	<5	3.00	5.31	0.72
Mean	2.75	2.50	6.82	10.01	2.82
Median (50th %ile)	3.00	2.50	5.90	8.44	3.01
90th %ile	4.00	2.50	10.80	13.69	3.73
Max (100th %ile)	5.00	<5	12.00	26.00	4.78

Tuross Sewage Treatment Plant - Monthly Result Summary - February 2026

Licensee: Eurobodalla Shire Council

EPL No.: 3108

Premises: Tuross Sewage Treatment Plant

Address: 217 Kelly Road, Bingie, NSW, 2537

Licence Period: 01-Apr-25 to 31-Mar-26

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25

Published Date: 3-Mar-26

Licence Point 2 - Influent Volume Monitoring			
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	7000
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall (mm)	Plant Inflow (kL)	Exceedance (YES/NO)
1-Feb-26	12.4	483.5	NO
2-Feb-26	0.2	437.6	NO
3-Feb-26	0	428.1	NO
4-Feb-26	0	421.3	NO
5-Feb-26	0	434.2	NO
6-Feb-26	0	447.4	NO
7-Feb-26	0	483.6	NO
8-Feb-26	2.4	436.0	NO
9-Feb-26	0	447.8	NO
10-Feb-26	0	425.6	NO
11-Feb-26	0	437.3	NO
12-Feb-26	5.4	425.7	NO
13-Feb-26	0.4	456.7	NO
14-Feb-26	0	484.8	NO
15-Feb-26	0.2	485.5	NO
16-Feb-26	15.6	464.6	NO
17-Feb-26	0	420.0	NO
18-Feb-26	0	441.0	NO
19-Feb-26	0	429.2	NO
20-Feb-26	0	470.7	NO
21-Feb-26	0	451.9	NO
22-Feb-26	0	452.0	NO
23-Feb-26	0	399.9	NO
24-Feb-26	0	435.3	NO
25-Feb-26	0	390.1	NO
26-Feb-26	0	393.6	NO
27-Feb-26	6.4	402.2	NO
28-Feb-26	0.4	464.9	NO
Monthly Total	43.4	12350.6	
Monthly Minimum	0	390.13	
Monthly Mean	1.55	441.09	
Monthly Maximum	15.6	485.5	
Year to Date Total	765.8	188264.23	
Year to Date Minimum	0	346.3	
Year to Date Mean	2.29	563.67	
Year to Date Maximum	120	3365.3	

Tuross Sewage Treatment Plant - Monthly Result Summary - February 2026

Licensee: Eurobodalla Shire Council
EPL No.: 3108
Premises: Tuross Sewage Treatment Plant
Address: 217 Kelly Road, Bingie, NSW, 2537
Licence Period: 01-Apr-25 to 31-Mar-26
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25
Published Date: 3-Mar-26

Monthly Exceedance Report				
Date	Exceedance Type	Parameter	Description / Action	

EPA Licence Point Map

