

Moruya Sewage Treatment Plant - Monthly Result Summary - April 2020



Licensee: Eurobodalla Shire Council
 EPL No.: 1614
 Premises: Moruya Sewage Treatment Plant
 Address: Queen Street, Moruya, NSW 2537

Anniversary Date: 01-Apr-20
 Published Date: 15-May-20

Licence Period: 01-Apr-20 to 31-Mar-21

EPL Link: <http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=28981&SYSUID=1&LICID=1614>

POEO Public Register: <http://www.environment.nsw.gov.au/prpoeoapp/default.aspx>

Required Month: **Apr-20**

Licence Point / Type of Point: Licence Point 6 - Discharge to Utilisation Area

Parameters	Unit of Measure	50 percentile concentration limit	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	-	20
Oil and Grease	(mg/L)	-	-	10
Total Nitrogen	(mg/L)	-	15	-
Total Phosphorus	(mg/L)	-	1	-
Total Suspended Solids	(mg/L)	20	-	30

See Note 1

Licence Point/Type of Point Licence Point 11 - Discharge to Waters

Parameters	Unit of Measure	50 percentile concentration limit	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	-	20
Oil and Grease	(mg/L)	-	-	10
Total Nitrogen	(mg/L)	-	15	-
Total Phosphorus	(mg/L)	-	1	-
Total Suspended Solids	(mg/L)	20	-	30

See Note 1

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 11 and Point 6.

Note 2: The monitoring at Point 3 required by condition M2.1 is conducted by the licensee to determine compliance with limits specified for discharges to Point 11 and 6 as described in condition L3.

Licence Point / Type of Point: Licence Point 3 - Effluent Quality Monitoring

Sample Frequency	Monthly	Special Frequency 1	Monthly	Monthly	Monthly	Monthly	Monthly
Sampling Method	Composite	Grab	Grab	Composite	Composite	Composite	Composite
Parameters	Biological Oxygen Demand	Chlorophyll a	Oil and Grease	Total Nitrogen	Total Phosphorus	Total Suspended Solids	
Unit of Measure	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	
Sample Date							Obtained Date
21-Apr-20	<2	0.0032	<10	4.84	0.456	4	01-May-20
Minimum Value	<2	0.0032	<10	4.84	0.456	4	
Maximum Value	<2	0.0032	<10	4.84	0.456	4	

Note 1: Special Frequency 1 means collect and store sample monthly, at the same time as Biochemical Oxygen Demand or Total Suspended Solids sampling. If the Biochemical Oxygen Demand or Total Suspended Solids 100 percentile concentration limit is exceeded as per condition L3.3, then analyse the

Note 2: For the purpose of this licence, a composite sample is defined as at least three grab samples forming a pooled sample, with the first and last samples taken at least seven hours apart.

100 Percentile - Licence Condition

Sample Date	Biological Oxygen Demand			Oil and Grease			Total Suspended Solids		
	Measurement	Actual 100 Percentile to Sample Date	Exceedance	Measurement	Actual 100 Percentile to Sample Date	Exceedance	Measurement	Actual 100 Percentile to Sample Date	Exceedance
21-Apr-20	<2	2	NO	<10	10	NO	4.00	4	NO

Moruya Sewage Treatment Plant - Monthly Result Summary - April 2020



Anniversary Date: 01-Apr-20
Published Date: 15-May-20

Licensee: Eurobodalla Shire Council
EPL No.: 1614
Premises: Moruya Sewage Treatment Plant
Address: Queen Street, Moruya, NSW 2537
Licence Period: 01-Apr-20 to 31-Mar-21
EPL Link: <http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=28981&SYSUID=1&LICID=1614>
POEO Public Register: <http://www.environment.nsw.gov.au/prpoeoapp/default.aspx>

Licence Point / Type of Point: Licence Point 7 - Ambient Water Monitoring			
Sample Frequency	Monthly	Monthly	
Sampling Method	Grab	Grab	
Parameters	Total Nitrogen	Total Phosphorus	
Unit of Measure	(mg/L)	(mg/L)	
Sample Date			Obtained Date
21-Apr-20	1.32	0.049	01-May-20

Licence Point / Type of Point: Licence Point 9 - Ambient Water Monitoring			
Sample Frequency	Monthly	Monthly	
Sampling Method	Grab	Grab	
Parameters	Total Nitrogen	Total Phosphorus	
Unit of Measure	(mg/L)	(mg/L)	
Sample Date			Obtained Date
21-Apr-20	0.29	0.012	01-May-20

Licence Point / Type of Point: Licence Point 8 - Ambient Water Monitoring			
Sample Frequency	Monthly	Monthly	
Sampling Method	Grab	Grab	
Parameters	Total Nitrogen	Total Phosphorus	
Unit of Measure	(mg/L)	(mg/L)	
Sample Date			Obtained Date
21-Apr-20	1.09	0.038	01-May-20

Licence Point / Type of Point: Licence Point 10 - Ambient Water Monitoring			
Sample Frequency	Monthly	Monthly	
Sampling Method	Grab	Grab	
Parameters	Total Nitrogen	Total Phosphorus	
Unit of Measure	(mg/L)	(mg/L)	
Sample Date			Obtained Date
21-Apr-20	0.29	0.016	01-May-20

Moruya Sewage Treatment Plant - Monthly Result Summary - April 2020

Licensee: Eurobodalla Shire Council
 EPL No.: 1614
 Premises: Moruya Sewage Treatment Plant
 Address: Queen Street, Moruya, NSW 2537
 Licence Period: 01-Apr-20 to 31-Mar-21
 EPL Link: <http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=28981&SYSUID=1&LICID=1614>
 POEO Public Register: <http://www.environment.nsw.gov.au/prpoeoapp/default.aspx>



Anniversary Date: 01-Apr-20
 Published Date: 15-May-20

Licence Point / Type of Point:		Licence Point 2 - Influent Volume Monitoring		
Sample Frequency	Daily (Continuous)	Maximum Daily Flow (kL)	14000	
Sampling Method	Ultrasonic Flow Meter			
Parameters	Rainfall	Flow	Exceedance	
Unit of Measure	(mm)	(kL)	(YES/NO)	
Sample Date				
1-Apr-20	0.6	617	NO	
2-Apr-20	8.2	589	NO	
3-Apr-20	1.4	581	NO	
4-Apr-20	0.2	617	NO	
5-Apr-20	0	523	NO	
6-Apr-20	0	524	NO	
7-Apr-20	0	494	NO	
8-Apr-20	0	510	NO	
9-Apr-20	29.8	904	NO	
10-Apr-20	3	869	NO	
11-Apr-20	0	726	NO	
12-Apr-20	0	583	NO	
13-Apr-20	0	553	NO	
14-Apr-20	0	545	NO	
15-Apr-20	0	567	NO	
16-Apr-20	0	556	NO	
17-Apr-20	0	565	NO	
18-Apr-20	0	524	NO	
19-Apr-20	6.8	523	NO	
20-Apr-20	0.2	520	NO	
21-Apr-20	0	504	NO	
22-Apr-20	0	486	NO	
23-Apr-20	0	493	NO	
24-Apr-20	0	505	NO	
25-Apr-20	0	456	NO	
26-Apr-20	0	453	NO	
27-Apr-20	0	498	NO	
28-Apr-20	0	519	NO	
29-Apr-20	0	476	NO	
30-Apr-20	0	532	NO	
Monthly Total	50	16812		
Monthly Minimum	0	453		
Monthly Maximum	30	904		

Moruya Sewage Treatment Plant - Monthly Result Summary - April 2020

Licensee: Eurobodalla Shire Council
EPL No.: 1614
Premises: Moruya Sewage Treatment Plant
Address: Queen Street, Moruya, NSW 2537



Anniversary Date: 01-Apr-20
Published Date: 15-May-20

Licence Period: 01-Apr-20 to 31-Mar-21
EPL Link: <http://www.environment.nsw.gov.au/prpoeapp/ViewPOEOLicence.aspx?DOCID=28981&SYSUID=1&LICID=1614>

POEO Public Register: <http://www.environment.nsw.gov.au/prpoeapp/default.aspx>

Exceedance Report

Date	Exceedance Type	Parameter	Description / Action

Moruya Sewage Treatment Plant - Monthly Result Summary - April 2020

Licensee: Eurobodalla Shire Council
EPL No.: 1614
Premises: Moruya Sewage Treatment Plant
Address: Queen Street, Moruya, NSW 2537

Licence Period: 01-Apr-20 to 31-Mar-21

EPL Link: <http://www.environment.nsw.gov.au/prpoeapp/ViewPOEOLicence.aspx?DOCID=28981&SYSUID=1&LICID=1614>

POEO Public Register: <http://www.environment.nsw.gov.au/prpoeapp/default.aspx>



Anniversary Date: 01-Apr-20
Published Date: 15-May-20

