

Moruya Sewage Treatment Plant - Monthly Result Summary - June 2020



Licensee: Eurobodalla Shire Council
 EPL No.: 1614
 Premises: Moruya Sewage Treatment Plant
 Address: Queen Street, Moruya, NSW 2537
 Licence Period: 01-Apr-20 to 31-Mar-21
 EPL Link: <http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=28981&SYSUID=1&LICID=1614>
 POEO Public Register: <http://www.environment.nsw.gov.au/prpoeoapp/default.aspx>

Anniversary Date: 01-Apr-20
 Published Date: 07-Aug-20

Required Month: Jun-20

Licence Point / Type of Point: Licence Point 6 - Discharge to Utilisation Area

Parameters	Unit of Measure	50 percentile concentration limit	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	-	20
Oil and Grease	(mg/L)	-	-	10
Total Nitrogen	(mg/L)	-	15	-
Total Phosphorus	(mg/L)	-	1	-
Total Suspended Solids	(mg/L)	20	-	30

See Note 1

Licence Point/Type of Point Licence Point 11 - Discharge to Waters

Parameters	Unit of Measure	50 percentile concentration limit	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	-	20
Oil and Grease	(mg/L)	-	-	10
Total Nitrogen	(mg/L)	-	15	-
Total Phosphorus	(mg/L)	-	1	-
Total Suspended Solids	(mg/L)	20	-	30

See Note 1

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 11 and Point 6.
 Note 2: The monitoring at Point 3 required by condition M2.1 is conducted by the licensee to determine compliance with limits specified for discharges to Point 11 and 6 as described in condition L3.

Licence Point / Type of Point: Licence Point 3 - Effluent Quality Monitoring

Sample Frequency	Monthly	Special Frequency 1	Monthly	Monthly	Monthly	Monthly	
Sampling Method	Composite	Grab	Grab	Composite	Composite	Composite	
Parameters	Biological Oxygen Demand	Chlorophyll a	Oil and Grease	Total Nitrogen	Total Phosphorus	Total Suspended Solids	
Unit of Measure	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	
Sample Date							Obtained Date
16-Jun-20	5	0.0017	<5	4.33	0.165	4	26-Jun-20
Minimum Value	5	0.0017	<5	4.33	0.165	4	
Maximum Value	5	0.0017	<5	4.33	0.165	4	

Note 1: Special Frequency 1 means collect and store sample monthly, at the same time as Biochemical Oxygen Demand or Total Suspended Solids sampling. If the Biochemical Oxygen Demand or Total Suspended Solids 100 percentile concentration limit is exceeded as per condition L3.3, then analyse the
 Note 2: For the purpose of this licence, a composite sample is defined as at least three grab samples forming a pooled sample, with the first and last samples taken at least seven hours apart.

100 Percentile - Licence Condition

Sample Date	Biological Oxygen Demand			Oil and Grease			Total Suspended Solids		
	Measurement	Actual 100 Percentile to Sample Date	Exceedance	Measurement	Actual 100 Percentile to Sample Date	Exceedance	Measurement	Actual 100 Percentile to Sample Date	Exceedance
16-Jun-20	5	5	NO	<5	5	NO	4/01/1900	4	NO

Moruya Sewage Treatment Plant - Monthly Result Summary - June 2020



Anniversary Date: 01-Apr-20
Published Date: 07-Aug-20

Licensee: Eurobodalla Shire Council
EPL No.: 1614
Premises: Moruya Sewage Treatment Plant
Address: Queen Street, Moruya, NSW 2537
Licence Period: 01-Apr-20 to 31-Mar-21
EPL Link: <http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=28981&SYSUID=1&LICID=1614>
POEO Public Register: <http://www.environment.nsw.gov.au/prpoeoapp/default.aspx>

Licence Point / Type of Point: Licence Point 7 - Ambient Water Monitoring			
Sample Frequency	Monthly	Monthly	
Sampling Method	Grab	Grab	
Parameters	Total Nitrogen	Total Phosphorus	
Unit of Measure	(mg/L)	(mg/L)	
Sample Date			Obtained Date
16-Jun-20	1.40	0.020	26-Jun-20

Licence Point / Type of Point: Licence Point 9 - Ambient Water Monitoring			
Sample Frequency	Monthly	Monthly	
Sampling Method	Grab	Grab	
Parameters	Total Nitrogen	Total Phosphorus	
Unit of Measure	(mg/L)	(mg/L)	
Sample Date			Obtained Date
16-Jun-20	0.21	0.011	26-Jun-20

Licence Point / Type of Point: Licence Point 8 - Ambient Water Monitoring			
Sample Frequency	Monthly	Monthly	
Sampling Method	Grab	Grab	
Parameters	Total Nitrogen	Total Phosphorus	
Unit of Measure	(mg/L)	(mg/L)	
Sample Date			Obtained Date
16-Jun-20	1.31	0.019	26-Jun-20

Licence Point / Type of Point: Licence Point 10 - Ambient Water Monitoring			
Sample Frequency	Monthly	Monthly	
Sampling Method	Grab	Grab	
Parameters	Total Nitrogen	Total Phosphorus	
Unit of Measure	(mg/L)	(mg/L)	
Sample Date			Obtained Date
16-Jun-20	0.21	0.012	26-Jun-20

Moruya Sewage Treatment Plant - Monthly Result Summary - June 2020

Licensee: Eurobodalla Shire Council
 EPL No.: 1614
 Premises: Moruya Sewage Treatment Plant
 Address: Queen Street, Moruya, NSW 2537
 Licence Period: 01-Apr-20 to 31-Mar-21
 EPL Link: <http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=28981&SYSUID=1&LICID=1614>
 POEO Public Register: <http://www.environment.nsw.gov.au/prpoeoapp/default.aspx>



Anniversary Date: 01-Apr-20
 Published Date: 07-Aug-20

Licence Point / Type of Point:		Licence Point 2 - Influent Volume Monitoring	
Sample Frequency	Daily (Continuous)	Maximum Daily Flow (kL)	14000
Sampling Method	Ultrasonic Flow Meter		
Parameters	Rainfall	Flow	Exceedance
Unit of Measure	(mm)	(kL)	(YES/NO)
Sample Date			
1-Jun-20	0	473	NO
2-Jun-20	0	472	NO
3-Jun-20	0	451	NO
4-Jun-20	0	490	NO
5-Jun-20	0	476	NO
6-Jun-20	0	479	NO
7-Jun-20	0	492	NO
8-Jun-20	0	479	NO
9-Jun-20	0	462	NO
10-Jun-20	0	452	NO
11-Jun-20	0	511	NO
12-Jun-20	0	461	NO
13-Jun-20	0	450	NO
14-Jun-20	0.2	462	NO
15-Jun-20	0.8	475	NO
16-Jun-20	0	456	NO
17-Jun-20	0	466	NO
18-Jun-20	0	493	NO
19-Jun-20	0	461	NO
20-Jun-20	0.8	448	NO
21-Jun-20	3.6	463	NO
22-Jun-20	4.8	472	NO
23-Jun-20	0	460	NO
24-Jun-20	0	491	NO
25-Jun-20	0	491	NO
26-Jun-20	0.2	467	NO
27-Jun-20	0	443	NO
28-Jun-20	0	457	NO
29-Jun-20	0	471	NO
30-Jun-20	0	480	NO
Monthly Total	10.4	14104	
Monthly Minimum	0.0	443	
Monthly Maximum	4.8	511	

Moruya Sewage Treatment Plant - Monthly Result Summary - June 2020

Licensee: Eurobodalla Shire Council
EPL No.: 1614
Premises: Moruya Sewage Treatment Plant
Address: Queen Street, Moruya, NSW 2537

Licence Period: 01-Apr-20 to 31-Mar-21

EPL Link: <http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=28981&SYSUID=1&LICID=1614>

POEO Public Register: <http://www.environment.nsw.gov.au/prpoeoapp/default.aspx>



Anniversary Date: 01-Apr-20
Published Date: 07-Aug-20

Exceedance Report

Date	Exceedance Type	Parameter	Description / Action

Moruya Sewage Treatment Plant - Monthly Result Summary - June 2020

Licensee: Eurobodalla Shire Council
EPL No.: 1614
Premises: Moruya Sewage Treatment Plant
Address: Queen Street, Moruya, NSW 2537

Licence Period: 01-Apr-20 to 31-Mar-21

EPL Link: <http://www.environment.nsw.gov.au/prpoeapp/ViewPOEOLicence.aspx?DOCID=28981&SYSUID=1&LICID=1614>

POEO Public Register: <http://www.environment.nsw.gov.au/prpoeapp/default.aspx>



Anniversary Date: 01-Apr-20
Published Date: 07-Aug-20

