

Tuross Sewage Treatment Plant - Annual Result Summary 2019-2020

Licensee: Eurobodalla Shire Council

EPL No.: 3108

Premises: Tuross Sewage Treatment Plant

Address: 217 Kelly Road, Bingie, NSW 2537

Licence Period: 1-Apr-19 to 30-Mar-20

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



EPA Licence Point 2 - Influent Volume Monitoring

Parameter	Units of measure	No. of measurements required by licence	No. of times measured during year	EPA Licence Point 2 - Influent Volume Monitoring			50	50	90	90	100	100	Exceedance (yes/no)
				Min. value	Mean value	Max. value	percentile value	percentile limit	percentile value	percentile limit	percentile value	percentile limit	
Daily Influent Volume	kL/Day	365	362	226	414	1916	375	-	511	-	1916	7000	No

EPA Licence Point 3 - Effluent Quality Monitoring

Pollutant	Units of measure	No. of measurements required by licence	No. of times measured during year	EPA Licence Point 3 - Effluent Quality Monitoring			50	50	90	90	100	100	Exceedance (yes/no)
				Min. value	Mean value	Max. value	percentile value	percentile limit	percentile value	percentile limit	percentile value	percentile limit	
Biological Oxygen Demand	mg/L	12	13	<2	7.38	13.00	7.00	15.00	10.00	-	13.00	20.00	No
Oil & Grease	mg/L	12	13	<3	4.77	<10	3.00	-	10.00	-	10.00	10.00	No
Total Suspended Solids	mg/L	12	13	2.00	15.62	27.00	16.00	20.00	22.80	-	27.00	30.00	No
Total Nitrogen	mg/L	12	13	6.35	11.41	22.70	10.60	-	15.92	-	22.70	-	No
Total Phosphorus	mg/L	12	13	0.44	5.66	8.26	5.96	-	7.73	-	8.26	-	No

