Tuross Sewage Treatment Plant - Monthly Result Summary - July 2021



Licensee: Eurobodalla Shire Council EPL No.: 3108 Premises: Tuross Sewage Treatment Plant Address: 217 Kelly Road, Bingie, NSW, 2537 Licence Period: 01-Apr-21 to 31-Mar-22 EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108 POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Required Month: Jul-21

Licence Point 1 (Dis	charge to Waters) and 4 (Discharg	ge to Utilisation Area) - Conce	ntration Limits	
Parameters	Unit of Measure	50 percentile concentration limit	100 percentile concentration limit	
Biological Oxygen Demand	(mg/L)	15	20	
Oil and Grease	(mg/L)		10	See No
Total Suspended Solids	(mg/L)	20	30	
Total Nitrogen	(mg/L)			
Total Phosphorus	(mg/L)			

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Points 1 and 4 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)						
Sample Frequency	Monthly	Monthly	Monthly	Monthly	Monthly	
Sampling Method	Composite Sample	Grab Sample	Composite Sample	Composite Sample	Composite Sample	
Sampled Date	Biological Oxygen Demand	Oil and Grease	Total Suspended Solids	Total Nitrogen	Total Phosphorus	Obtained Date
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	obtained bate
13-Jul-21	7.00	<5	14.00	18.60	5.60	23-Jul-21
100 Percentile Exceedance?	NO	NO	NO	NO	NO	

* Special Frequency 2: at least weekly during the months of November, December, January, February and March

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)					
Year to Date	Biological Oxygen Demand	Oil and Grease	Total Suspended Solids	Total Nitrogen	Total Phosphorus
real to bate	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Samples	4	4	4	4	4
Min	4.00	<5	8.98	8.98	3.280
Mean	5.25	2.50	14.85	14.85	4.710
Median (50th %ile)	5.00	2.50	15.90	15.90	4.980
90th %ile	6.40	2.50	18.51	18.51	5.576
Max (100th %ile)	7.00	<5	18.60	18.60	5.600

Tuross Sewage Treatment Plant - Monthly Result Summary - July 2021

Licensee: Eurobodalla Shire Council

EPL No.: 3108

Premises: Tuross Sewage Treatment Plant

Address: 217 Kelly Road, Bingie, NSW, 2537

Licence Period: 01-Apr-21

to EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108 POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

31-Mar-22

	Licence Point 2 - Influent Volume Monitoring					
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	7000			
Sampling Method	Ultrasonic Flow Meter					
Sample Date	Rainfall	Plant Inflow	Exceedance			
Sumple Date	(mm)	(kL)	(YES/NO)			
1-Jul-21	9	458.3	NO			
2-Jul-21	1	554.0	NO			
3-Jul-21	0	526.9	NO			
4-Jul-21	0	462.9	NO			
5-Jul-21	0	427.2	NO			
6-Jul-21	0.2	407.0	NO			
7-Jul-21	0	406.9	NO			
8-Jul-21	0.2	396.8	NO			
9-Jul-21	0	380.0	NO			
10-Jul-21	7.8	437.1	NO			
11-Jul-21	0.4	452.1	NO			
12-Jul-21	0	390.5	NO			
13-Jul-21	0	380.7	NO			
14-Jul-21	0	341.4	NO			
15-Jul-21	0	376.2	NO			
16-Jul-21	0	365.0	NO			
17-Jul-21	0	385.9	NO			
18-Jul-21	0	388.7	NO			
19-Jul-21	0	327.7	NO			
20-Jul-21	0	346.2	NO			
21-Jul-21	0	324.2	NO			
22-Jul-21	0	360.2	NO			
23-Jul-21	0.2	333.5	NO			
24-Jul-21	0.4	388.5	NO			
25-Jul-21	0	403.9	NO			
26-Jul-21	0	357.5	NO			
27-Jul-21	0	352.0	NO			
28-Jul-21	0	353.3	NO			
29-Jul-21	0	321.1	NO			
30-Jul-21	0	360.9	NO			
31-Jul-21	0	369.3	NO			
Monthly Total	19.2	12135.9				
Monthly Minimum	0	321.1				
Monthly Mean	0.62	391.48				
Monthly Maximum	9	554				
Year to Date Total	278.8	58363.4				
Year to Date Minimum	0	321.1				
Year to Date Mean	2.285245902	478.3885246				
Year to Date Maximum	57.8	1845.2				



1-Apr-21 5-Aug-21

Tuross Sewage Treatment Plant - Monthly Result Summary - July 2021



Monthly Exceedance Report				
Date	Exceedance Type	Parameter	Description / Action	

