

## Moruya Sewage Treatment Plant - Monthly Result Summary - January 2023



Anniversary Date: 1-Apr-21  
Published Date: 23-Feb-23

Licensee: Eurobodalla Shire Council  
EPL No.: 1614  
Premises: Moruya Sewage Treatment Plant  
Address: Queen Street, Moruya, NSW 2537

Licence Period: 1-Apr-21 to 31-Mar-22

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206032&SYSUID=1&LICID=1614>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: **Jan-23**

Licence Point 6 (Discharge to Utilisation Area) & 11 (Discharge to Waters) - Concentration Limits			
Parameters	Unit of Measure	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	15
Oil and Grease	(mg/L)	5	10
pH	(pH Units)	-	6.5-8.5
Total Suspended Solids	(mg/L)	15	20
Chlorophyll a	(mg/m3)		
Faecal Coliforms	(CFU/100mL)	200	600
Total Nitrogen	(mg/L)	10	15
Total Phosphorus	(mg/L)	1	2
Ammonia	(mg/L)	2	5

See Note 1

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Points 6 and 11 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)										
Sample Frequency Sampling Method	Monthly Composite Sample	Monthly Grab Sample	Monthly Grab Sample	Monthly Composite Sample	Monthly Grab Sample	Monthly Grab Sample	Monthly Composite Sample	Monthly Composite Sample	Monthly Grab Sample	
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Chlorophyll a (mg/m3)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)	Obtained Date
24-Jan-23	<2	<5	7.30	3.00	9.70	270	5.22	0.09	0.02	3-Feb-23
100 Percentile Exceedance?	NO	NO	NO	NO	NO	NO	NO	NO	NO	

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)									
Year to Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Chlorophyll a (mg/m3)	Faecal Coliforms (CFU/100mL)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)
Samples	11	11	11	11	11	11	11	11	11
Min	<2	<5	7.20	3.00	0.90	270	3.99	0.085	0.01
Mean	2.64	2.50	7.45	5.18	9.59	4679	6.42	0.168	0.10
Median (50th %ile)	3.00	2.50	7.40	4.00	5.80	5200	5.73	0.150	0.02
90th %ile	4.00	2.50	7.60	7.00	16.60	10000	8.82	0.246	0.35
Max (100th %ile)	5.00	<5	7.70	12.00	40.50	10000	12.80	0.315	0.63

## Moruya Sewage Treatment Plant - Monthly Result Summary - January 2023

Licensee: Eurobodalla Shire Council

EPL No.: 1614

Premises: Moruya Sewage Treatment Plant

Address: Queen Street, Moruya, NSW 2537

Licence Period: 1-Apr-21 to 31-Mar-22

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206032&SYSUID=1&LICID=1614>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-21

Published Date: 23-Feb-23

Licence Point 2 - Influent Volume Monitoring			
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	14000
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall (mm)	Plant Inflow (kL)	Exceedance (YES/NO)
1-Jan-23	0	665.0	NO
2-Jan-23	0	637.0	NO
3-Jan-23	12.6	796.0	NO
4-Jan-23	4.8	766.0	NO
5-Jan-23	4.4	827.0	NO
6-Jan-23	0	740.0	NO
7-Jan-23	0	642.0	NO
8-Jan-23	0	588.0	NO
9-Jan-23	0	623.0	NO
10-Jan-23	0	608.0	NO
11-Jan-23	0	565.0	NO
12-Jan-23	0	582.0	NO
13-Jan-23	0	521.0	NO
14-Jan-23	0	520.0	NO
15-Jan-23	0.4	507.0	NO
16-Jan-23	0	510.0	NO
17-Jan-23	0	524.0	NO
18-Jan-23	13.4	670.0	NO
19-Jan-23	1.6	612.0	NO
20-Jan-23	0	584.0	NO
21-Jan-23	0	540.0	NO
22-Jan-23	7.4	548.0	NO
23-Jan-23	0.2	607.0	NO
24-Jan-23	0	599.0	NO
25-Jan-23	0.2	602.0	NO
26-Jan-23	0	598.0	NO
27-Jan-23	0	632.0	NO
28-Jan-23	0	611.0	NO
29-Jan-23	0	672.0	NO
30-Jan-23	0	999.0	NO
31-Jan-23	0	751.0	NO
Monthly Total	45	19646.0	
Monthly Minimum	0	507	
Monthly Mean	1.45	633.74	
Monthly Maximum	13.4	999	
Year to Date Total	628.3	274385.0	
Year to Date Minimum	0.0	0.0	
Year to Date Mean	2.06	896.68	
Year to Date Maximum	49.6	5125.0	

## Moruya Sewage Treatment Plant - Monthly Result Summary - January 2023

Licensee: Eurobodalla Shire Council

EPL No.: 1614

Premises: Moruya Sewage Treatment Plant

Address: Queen Street, Moruya, NSW 2537

Licence Period: 1-Apr-21 to 31-Mar-22

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206032&SYSUID=1&LICID=1614>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-21

Published Date: 23-Feb-23

### Licence Point 7 - Ambient Water Monitoring (Monthly Result)

Frequency Sampling Method	Monthly Grab Sample	Monthly Grab Sample	Obtained Date
Sampled Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	
24-Jan-23	1.3	0.077	3-Feb-23

### Licence Point 8 - Ambient Water Monitoring (Monthly Result)

Frequency Sampling Method	Monthly Grab Sample	Monthly Grab Sample	Obtained Date
Sampled Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	
24-Jan-23	2.9	0.070	3-Feb-23

### Licence Point 7 - Ambient Water Monitoring (Year to Date Results)

Year to Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples	11	11
Min	0.85	0.045
Mean	2.03	0.140
Median (50th %ile)	1.18	0.086
90th %ile	4.64	0.246
Max (100th %ile)	7.37	0.485

### Licence Point 8 - Ambient Water Monitoring (Year to Date Results)

Year to Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples	11	11
Min	1.07	0.062
Mean	2.76	0.137
Median (50th %ile)	2.32	0.137
90th %ile	4.61	0.187
Max (100th %ile)	5.89	0.248

### Licence Point 9 - Ambient Water Monitoring (Monthly Result)

Frequency Sampling Method	Monthly Grab Sample	Total Phosphorus (mg/L)	Obtained Date
Sampled Date	Total Nitrogen (mg/L)		
24-Jan-23	0.19	0.005	3-Feb-23

### Licence Point 10 - Ambient Water Monitoring (Monthly Result)

Frequency Sampling Method	Monthly Grab Sample	Total Phosphorus (mg/L)	Obtained Date
Sampled Date	Total Nitrogen (mg/L)		
24-Jan-23	0.2	0.007	3-Feb-23

### Licence Point 9 - Ambient Water Monitoring (Year To Date Results)

Year to Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples	11	11
Min	0.15	0.003
Mean	0.39	0.010
Median (50th %ile)	0.34	0.008
90th %ile	0.67	0.020
Max (100th %ile)	0.86	0.023

### Licence Point 10 - Ambient Water Monitoring (Year To Date Results)

Year to Date	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)
Samples	11	11
Min	0.17	0.006
Mean	0.41	0.020
Median (50th %ile)	0.33	0.011
90th %ile	0.66	0.045
Max (100th %ile)	1.26	0.068

## Moruya Sewage Treatment Plant - Monthly Result Summary - January 2023

Licensee: Eurobodalla Shire Council  
 EPL No.: 1614  
 Premises: Moruya Sewage Treatment Plant  
 Address: Queen Street, Moruya, NSW 2537



Anniversary Date: 1-Apr-21  
 Published Date: 23-Feb-23

Licence Period: 1-Apr-21 to 31-Mar-22

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206032&SYSUID=1&LICID=1614>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

### Monthly Exceedance Report

Date	Exceedance Type	Parameter	Description / Action
24-Jan-23	Concentration Limit	Faecal Coliforms	Faecal Coliform result (270 CFU/100mL) exceeded 90 percentile concentration limit (200 CFU/100mL) at monitoring point 3 (Prior to finishing pond)

### EPA Licence Point Map

