

Narooma Sewage Treatment Plant - Monthly Result Summary - February 2026



Anniversary Date: 1-Apr-25
Published Date: 3-Mar-26

Licensee: Eurobodalla Shire Council
EPL No.: 1398
Premises: Narooma Sewage Treatment Plant
Address: Lakeside Drive, Narooma, NSW 2546
Licence Period: 01-Apr-25 to 31-Mar-26
EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398>
POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>

Required Month: Feb-26

Licence Point 1 - Discharge to Waters - Point 1 Concentration Limits			
Parameters	Unit of Measure	90 percentile concentration limit	100 percentile concentration limit
Biological Oxygen Demand	(mg/L)	10	15
Oil and Grease	(mg/L)	5	10
pH	(pH Units)	-	6.5-8.5
Total Suspended Solids	(mg/L)	15	25
Chlorophyll a	(mg/m3)		
Faecal Coliforms	(CFU/100mL)	200	600
Total Nitrogen	(mg/L)	15	20
Total Phosphorus	(mg/L)	8	10
Ammonia	(mg/L)	2	5

See Note 1

Note 1: A 100 Percentile Concentration Limit of “10 mg/L and no visible oil and grease” applies for Point 1.
Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Point 1 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)									
Sample Frequency	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	
Sampling Method	Composite Sample	Grab Sample	Grab Sample	Composite Sample	Grab Sample	Composite Sample	Composite Sample	Grab Sample	
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Chlorophyll a (mg/m3)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)	Obtained Date
17-Feb-26	3.00	<5	8.80	15.00	51.92	7.30	6.79	0.03	26-Feb-26
100 Percentile Exceedance?	NO	NO	YES	NO	NO	NO	NO	NO	

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)								
Year to Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	pH (pH Units)	Total Suspended Solids (mg/L)	Chlorophyll a (mg/m3)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Ammonia (mg/L)
Samples	12	12	12	12	12	12	12	12
Min	<2	<5	7.10	<2	0.77	1.53	1.770	0.03
Mean	1.92	2.50	7.91	5.50	21.03	7.13	6.063	0.53
Median (50th %ile)	1.00	2.50	7.75	5.50	14.82	6.83	6.145	0.29
90th %ile	2.90	2.50	8.69	8.00	54.35	15.24	8.074	0.96
Max (100th %ile)	7.00	<5	8.80	15.00	58.32	16.20	9.500	2.81

Narooma Sewage Treatment Plant - Monthly Result Summary - February 2026

Licensee: Eurobodalla Shire Council

EPL No.: 1398

Premises: Narooma Sewage Treatment Plant

Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-25 to 31-Mar-26

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25
Published Date: 3-Mar-26

Licence Point 2 - Influent Volume Monitoring			
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	20000
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall (mm)	Plant Inflow (kL)	Exceedance (YES/NO)
1-Feb-26	15.2	1726.8	NO
2-Feb-26	0.4	1530.8	NO
3-Feb-26	0	1446.1	NO
4-Feb-26	0	1467.6	NO
5-Feb-26	0	1467.6	NO
6-Feb-26	0	1440.5	NO
7-Feb-26	0	1470.9	NO
8-Feb-26	4.2	1504.5	NO
9-Feb-26	0.2	1502.4	NO
10-Feb-26	0	1492.1	NO
11-Feb-26	0	1499.9	NO
12-Feb-26	9	1558.4	NO
13-Feb-26	0	1541.8	NO
14-Feb-26	0.2	1520.7	NO
15-Feb-26	21	1745.9	NO
16-Feb-26	0	1769.0	NO
17-Feb-26	0	1561.1	NO
18-Feb-26	0.2	1490.3	NO
19-Feb-26	0	1493.9	NO
20-Feb-26	0	1484.5	NO
21-Feb-26	0	1526.9	NO
22-Feb-26	4.2	1554.4	NO
23-Feb-26	2.4	1522.8	NO
24-Feb-26	0	1488.6	NO
25-Feb-26	2	1410.8	NO
26-Feb-26	7.6	1543.6	NO
27-Feb-26	0.2	1442.8	NO
28-Feb-26	0.06	1507.5	NO
Monthly Total	66.86	42711.72	
Monthly Minimum	0.00	1410.79	
Monthly Mean	2.39	1525.42	
Monthly Maximum	21.00	1769.02	
Year to Date Total	1194.16	633026.26	
Year to Date Minimum	0.00	1304.00	
Year to Date Mean	3.58	1895.29	
Year to Date Maximum	126.00	12101.00	

Narooma Sewage Treatment Plant - Monthly Result Summary - February 2026

Licensee: Eurobodalla Shire Council

EPL No.: 1398

Premises: Narooma Sewage Treatment Plant

Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-25 to 31-Mar-26

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25

Published Date: 3-Mar-26

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)		
Frequency	Special Frequency 2*	
Sampling Method	Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
3/02/2026	76	13/02/2026
10/02/2026	14	14/02/2026
17/02/2026	7400	26/02/2026
24/02/2026	200	27/02/2026

Licence Point 4 - Ambient Water Monitoring (Monthly Results)		
Frequency	Special Frequency 2*	
Sampling Method	Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
3/02/2026	<1	13/02/2026
10/02/2026	<1	14/02/2026
17/02/2026	1	26/02/2026
24/02/2026	<1	27/02/2026

Licence Point 5 - Ambient Water Monitoring (Monthly Results)		
Frequency	Special Frequency 2*	
Sampling Method	Grab Sample	
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date
3-Feb-26	<1	13/02/2026
10-Feb-26	<1	14/02/2026
17-Feb-26	<1	26/02/2026
24-Feb-26	2	27/02/2026

* Special Frequency 2: at least weekly during the months of November, December, January, February and March

Licence Point 3 - Effluent Quality Monitoring (Year to Date Results)	
Year to Date	Faecal Coliforms (CFU/100mL)
Samples	17
Min	4
Mean	560.71
Median (50th %ile)	21
90th %ile	678
Max (100th %ile)	7400

Licence Point 4 - Ambient Water Monitoring (Year to Date Results)	
Year to Date	Faecal Coliforms (CFU/100mL)
Samples	17
Min	<1
Mean	2.76
Median (50th %ile)	0
90th %ile	8.2
Max (100th %ile)	23

Licence Point 5 - Ambient Water Monitoring (Year to Date Results)	
Year to Date	Faecal Coliforms (CFU/100mL)
Samples	17
Min	<1
Mean	8.71
Median (50th %ile)	0
90th %ile	5.6
Max (100th %ile)	130

Monthly Exceedance Report			
Date	Exceedance Type	Parameter	Description / Action
17-Feb-26	L3.1 Concentration Limits	pH	pH result (8.8 pH Units) exceeded 100 percentile concentration limit (8.5) at monitoring point 3.
17-Feb-26	L3.1 Concentration Limits	Faecal Colifoms	Faecal Coliform result (7'400 CFU/100mL) exceeded 100 percentile concentration limit (600 CFU/100mL) at monitoring point 3.

Narooma Sewage Treatment Plant - Monthly Result Summary - February 2026

Licensee: Eurobodalla Shire Council

EPL No.: 1398

Premises: Narooma Sewage Treatment Plant

Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-25 to 31-Mar-26

EPL Link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398>

POEO Public Register: <https://apps.epa.nsw.gov.au/prpoeoapp/>



Anniversary Date: 1-Apr-25
Published Date: 3-Mar-26

EPA Licence Point Map

