

Anniversary Date: Published Date: 1-Apr-21 4-Nov-21

Licensee: Eurobodalla Shire Council

Premises: Narooma Sewage Treatment Plant Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-21 to 31-Mar-22

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Required Month: Sep-21

Licenc	e Point 1 - Discharge to Waters	- Point 1 Concentration Limits		
Parameters	Unit of Measure	90 percentile concentration limit	100 percentile concentration limit	
Biological Oxygen Demand	(mg/L)	10	15	
Oil and Grease	(mg/L)	5	10	See Not
pH	(pH Units)	-	6.5-8.5	
Total Suspended Solids Chlorophyll a	(mg/L) (mg/m3)	15	25	
Faecal Coliforms	(CFU/100mL)	200	600	
Total Nitrogen	(mg/L)	15	20	
Total Phosphorus	(mg/L)	8	10	
Ammonia	(mg/L)	2	5	

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Point 1 as described in Condition L3.

	Licence Point 3 - Effluent Quality Monitoring (Monthly Results)									
Sample Frequency	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	6 Times Per Year	Special Frequency 2*	6 Times Per Year	6 Times Per Year	6 Times Per Year	
Sampling Method	Composite Sample	Grab Sample	Grab Sample	Composite Sample	Grab Sample	Grab Sample	Composite Sample	Composite Sample	Grab Sample	
Sampled Date	Biological Oxygen Demand	Oil and Grease	pH	Total Suspended Solids	Chlorophyll a	Faecal Coliforms	Total Nitrogen	Total Phosphorus	Ammonia	Obtained Date
Sampled Date	(mg/L)	(mg/L)	(pH Units)	(mg/L)	(mg/m3)	(CFU/100mL)	(mg/L)	(mg/L)	(mg/L)	Obtained Date
7-Sep-21	2.00	<5	7.40	<2	1.90	60	9.40	5.74	1.22	17-Sep-21
100 Percentile Exceedance?	NO	NO	NO	NO	NO	NO	NO	NO	NO	

^{*} Special Frequency 2: at least weekly during the months of November, December, January, February and March

	Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)								
Year to Date	Biological Oxygen Demand	Oil and Grease	pH	Total Suspended Solids	Chlorophyll a	Faecal Coliforms	Total Nitrogen	Total Phosphorus	Ammonia
real to Date	(mg/L)	(mg/L)	(pH Units)	(mg/L)	(mg/m3)	(CFU/100mL)	(mg/L)	(mg/L)	(mg/L)
Samples	6	6	6	6	6	6	6	6	6
Min	<2	<5	7.20	<2	0.60	60	4.94	3.880	0.11
Mean	1.33	2.50	7.53	1.67	2.53	368	9.64	5.217	0.38
Median (50th %ile)	1.00	2.50	7.50	1.00	2.00	300	9.49	5.360	0.14
90th %ile	2.00	2.50	7.80	3.00	4.95	720	12.75	6.230	0.88
Max (100th %ile)	2.00	<5	8.00	3.00	7.10	760	12.80	6.600	1.22

Licensee: Eurobodalla Shire Council

EPL No.:

Premises: Narooma Sewage Treatment Plant Address: Lakeside Drive, Narooma, NSW 2546

01-Apr-21 Licence Period: 31-Mar-22

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

	Licence Point 2 - Influent Vo	olume Monitoring	
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	20000
Sampling Method	Ultrasonic Flow Meter		
Sample Date	Rainfall	Plant Inflow	Exceedance
Sumple Date	(mm)	(kL)	(YES/NO)
1-Sep-21	0	1530.0	NO
2-Sep-21	0	1460.0	NO
3-Sep-21	0	3090.0	NO
4-Sep-21	0	5200.0	NO
5-Sep-21	24.8	5200.0	NO
6-Sep-21	10.4	2010.0	NO
7-Sep-21	0	1770.0	NO
8-Sep-21	0	1610.0	NO
9-Sep-21	0	1500.0	NO
10-Sep-21	0	1540.0	NO
11-Sep-21	0	1440.0	NO
12-Sep-21	0	1440.0	NO
13-Sep-21	0	1390.0	NO
14-Sep-21	0	1400.0	NO
15-Sep-21	0	1420.0	NO
16-Sep-21	1.4	1370.0	NO
17-Sep-21	0.2	1380.0	NO
18-Sep-21	0.2	1360.0	NO
19-Sep-21	0.2	1360.0	NO
20-Sep-21	0	1360.0	NO
21-Sep-21	0	1370.0	NO
22-Sep-21	0	1350.0	NO
23-Sep-21	0	1350.0	NO
24-Sep-21	0	1320.0	NO
25-Sep-21	0	1390.0	NO
26-Sep-21	0	1340.0	NO
27-Sep-21	0	1370.0	NO
28-Sep-21	0	1290.0	NO
29-Sep-21	0	1440.0	NO
30-Sep-21	0	1410.0	NO
·			
Monthly Total	37.20	52460.00	
Monthly Minimum	0.00	1290.00	
Monthly Mean	1.24	1748.67	
Monthly Maximum	24.80	5200.00	
Year to Date Total	263.60	342692.01	
Year to Date Minimum	0.00	1290.00	
Year to Date Mean	1.44	1872.63	
Year to Date Maximum	25.60	16220.00	



1-Apr-21 4-Nov-21

Licensee: Eurobodalla Shire Council EPL No.: 1398

Premises: Narooma Sewage Treatment Plant

Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-21 to 31-Mar-22

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Licence Point 4 - Ambient Water Monitoring (Monthly Result)					
Frequency	Special Frequency 2*				
Sampling Method	Grab Sample				
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date			

* Special Frequence	v 2: at least weekly	during t	the months of N	ovember. D	ecember.	January	. February	and March

Licence Point 4 - Ambi	Licence Point 4 - Ambient Water Monitoring (Year to Date Results)					
Year to Date	Faecal Coliforms					
rear to Date	(CFU/100mL)					
Samples						
Min						
Mean						
Median (50th %ile)						
90th %ile						
Max (100th %ile)						

Licence Point 5 - Ambient Water Monitoring (Monthly Result)					
Frequency	Special Frequency 2*				
Sampling Method	Grab Sample				
Sampled Date	Faecal Coliforms (CFU/100mL)	Obtained Date			

Licence Point 5 - Ambient Water Monitoring (Year to Date Results)				
Year to Date	Faecal Coliforms			
rear to Date	(CFU/100mL)			
Samples				
Min				
Mean				
Median (50th %ile)				
90th %ile				
May (100th %ile)				

			Monthly Exceedance Report
Date	Exceedance Type	Parameter	Description / Action



1-Apr-21 4-Nov-21

Licensee: Eurobodalla Shire Council
EPL No.: 1398

Premises: Narooma Sewage Treatment Plant

Address: Lakeside Drive, Narooma, NSW 2546

Licence Period: 01-Apr-21 to 31-Mar-22

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=206031&SYSUID=1&LICID=1398

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/



