Tuross Sewage Treatment Plant - Monthly Result Summary - July 2022



Anniversary Date: 1-Apr-21

Published Date: 26-Aug-22

Licensee: Eurobodalla Shire Council EPL No.: 3108

Premises: Tuross Sewage Treatment Plant Address: 217 Kelly Road, Bingie, NSW, 2537

Jul-22

01-Apr-21 31-Mar-22

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Required Month:

Licence Point 1 (Discharge to Waters) and 4 (Discharge to Utilisation Area) - Concentration Limits				
Parameters	Unit of Measure	50 percentile concentration limit	100 percentile concentration limit	
Biological Oxygen Demand Oil and Grease	(mg/L) (mg/L)	15	20 10	Se
Total Suspended Solids	(mg/L)	20	30	361
Total Nitrogen Total Phosphorus	(mg/L) (mg/L)			

Note 1: A 100 Percentile Concentration Limit of "10 mg/L and no visible oil and grease" applies for Point 1.

Note 2: The monitoring at Point 3, required by Condition M2.1, is conducted by the licensee to determine compliance with limits specified for discharges to Points 1 and 4 as described in Condition L3.

Licence Point 3 - Effluent Quality Monitoring (Monthly Results)						
Sample Frequency	Monthly	Monthly	Monthly	Monthly	Monthly	
Sampling Method	Composite Sample	Grab Sample	Composite Sample	Composite Sample	Composite Sample	
Sampled Date	Biological Oxygen Demand (mg/L)	Oil and Grease (mg/L)	Total Suspended Solids (mg/L)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Obtained Date
12-Jul-22	5.00	<5	5.00	14.20	2.18	26-Jul-22
100 Percentile Exceedance?	NO	NO	NO	NO	NO	

Licence Point 3 - Effluent Quality Monitoring (Year To Date Results)						
Year to Date	Biological Oxygen Demand	Oil and Grease	Total Suspended Solids	Total Nitrogen	Total Phosphorus	
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	
Samples	4	4	4	4	4	
Min	<2	<5	3.00	5.03	1.44	
Mean	3.25	2.50	5.25	10.78	1.88	
Median (50th %ile)	3.50	2.50	5.50	11.05	1.84	
90th %ile	4.70	2.50	6.70	15.46	2.33	
Max (100th %ile)	5.00	<5	7.00	16.00	2.40	

Tuross Sewage Treatment Plant - Monthly Result Summary - July 2022

Licensee: Eurobodalla Shire Council

EPL No.: 3108

Premises: Tuross Sewage Treatment Plant Address: 217 Kelly Road, Bingie, NSW, 2537

Licence Period: 01-Apr-21 to 31-Mar-22

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

Licence Point 2 - Influent Volume Monitoring						
Sample Frequency	Daily (Continuous)	Maximum Daily flow (kL)	7000			
Sampling Method	Ultrasonic Flow Meter					
Sample Date	Rainfall	Plant Inflow	Exceedance			
Jampie Zate	(mm)	(kL)	(YES/NO)			
1-Jul-22	2.4	373.3	NO			
2-Jul-22	8	413.4	NO			
3-Jul-22	13	583.3	NO			
4-Jul-22	1.8	532.0	NO			
5-Jul-22	0	478.8	NO			
6-Jul-22	0.2	474.2	NO			
7-Jul-22	0.2	464.2	NO			
8-Jul-22	0	493.8	NO			
9-Jul-22	5.8	498.7	NO			
10-Jul-22	3	519.5	NO			
11-Jul-22	0.4	534.4	NO			
12-Jul-22	0.2	487.3	NO			
13-Jul-22	0	465.8	NO			
14-Jul-22	0	465.0	NO			
15-Jul-22	0	485.3	NO			
16-Jul-22	0	485.3	NO			
17-Jul-22	0	451.1	NO			
18-Jul-22	0	416.2	NO			
19-Jul-22	0	395.2	NO			
20-Jul-22	0.6	394.9	NO			
21-Jul-22	1.2	384.2	NO			
22-Jul-22	0.6	435.0	NO			
23-Jul-22	0	458.9	NO			
24-Jul-22	0.2	479.9	NO			
25-Jul-22	0	427.7	NO			
26-Jul-22	6.2	408.1	NO			
27-Jul-22	0	410.1	NO			
28-Jul-22	1.2	414.4	NO			
29-Jul-22	0.2	434.7	NO			
30-Jul-22	0	448.2	NO			
31-Jul-22	0	416.0	NO			
Monthly Total	45.2	14128.7				
Monthly Minimum	0	373.3				
Monthly Mean	1.46	455.76				
Monthly Maximum	13	583.3				
Year to Date Total	175.5	74640.26				
Year to Date Minimum	0	373.3				
Year to Date Mean	1.43852459	611.8054098				
Year to Date Maximum	18.6	3494				



Anniversary Date: Published Date: 1-Apr-21 26-Aug-22

Tuross Sewage Treatment Plant - Monthly Result Summary - July 2022

Monthly Exceedance Report

Licensee: Eurobodalla Shire Council

EPL No.: 3108

Premises: Tuross Sewage Treatment Plant Address: 217 Kelly Road, Bingie, NSW, 2537

Exceedance Type

cence Period: 01-Apr-21 to 31-Mar-22

EPL Link: https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=183820&SYSUID=1&LICID=3108

POEO Public Register: https://apps.epa.nsw.gov.au/prpoeoapp/

eurobodalla shire council

Anniversary Date:

Published Date:

1-Apr-21 26-Aug-22

Description / Action

EPA License Point 2 - Influent volume monitoring EPA License Point 3 - Effluent quality monitoring EPA Licence Point 4 - Discharge to Utilisation Area EPA Licence Point 1 - Discharge to Waters LEGEND Sewerage Treatment Plant Boundary ∇ EPA License Points Sewerage Treatment Plant Facility